


NOTICE

**CERTAIN DATA
CONTAINED IN THIS
DOCUMENT MAY BE
DIFFICULT TO READ
IN MICROFICHE
PRODUCTS.**

12
4-22-92 JS ①

PNL-8058
UC-350

Energy Use Baseline Study for the National Naval Medical Center



April 1992

Prepared for the U.S. Department of Energy
Federal Energy Management Program
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute



DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes **any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST LABORATORY
operated by
BATTELLE MEMORIAL INSTITUTE
for the
UNITED STATES DEPARTMENT OF ENERGY
under Contract DE-AC06-76RLO 1830

Printed in the United States of America

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831;
prices available from (615) 576-8401. FTS 626-8401.

Available to the public from the National Technical Information Service,
U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

PNL--8058

DE92 011673

ENERGY USE BASELINING STUDY FOR
THE NATIONAL NAVAL MEDICAL CENTER

G. B. Parker
M. A. Halverson

April 1992

Prepared for
the U.S. Department of Energy
Federal Energy Management Program
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Richland, Washington 99352

MASTER

REPRODUCTION OF THIS DOCUMENT IS UNLIMITED

JP

PREFACE

The Naval Facilities Engineering Command (NAVFACENGCOM) has directed that Chesapeake Division Naval Facilities Engineering Command (CHESDIV) and the other engineering field divisions develop and implement a Shared Energy Savings (SES) program. CHESDIV has selected several possible sites and is working to implement the program. CHESDIV is also developing the contracts for the proposed projects that require an energy usage baseline for current energy consumption be developed for the SES project sites.

CHESDIV is managing the development of this project and has entered into an interagency agreement with the U.S. Department of Energy (DOE) Federal Energy Management Program (FEMP). The goal of DOE/FEMP is to facilitate energy efficiency improvements at federal facilities. This is accomplished by a balanced program of technology development, facility assessment, and use of cost-sharing procurement mechanisms. Technology development focuses upon the tools and procedures used to identify and evaluate efficiency improvements, such as the ASEAM simulation model and the Federal Life Cycle Costing procedures. For facility assessment, FEMP provides metering equipment and trained analysts to federal agencies that exhibit a commitment to improve energy use efficiency. To assist in procurement of energy efficiency measures, FEMP helps federal agencies devise and implement shared energy savings and utility demand side management projects.

Pacific Northwest Laboratory (PNL)^(a) supports the FEMP mission as the lead laboratory for energy systems modernization. Under this charter, the Laboratory and its contractors work with federal facility energy managers to assess energy efficiency improvements at federal facilities nationwide. PNL subcontracted with SBW Consulting, Inc. to assist in this project.

(a) Pacific Northwest Laboratory is operated by Battelle Memorial Institute for the U.S. Department of Energy under Contract DE-AC06-76RLO 1830.

EXECUTIVE SUMMARY

This report provides an energy consumption profile for fourteen buildings at the National Naval Medical Center (NNMC) in Bethesda, Maryland. Recommendations are also made for viable energy efficiency projects funded with assistance from the servicing utility (Potomac Electric Power Company) in the form of rebates and incentives available in their Demand Side Management (DSM) program and through Shared Energy Savings (SES) projects. This report also provides estimates of costs and potential energy savings of the recommended projects.

The majority of the data collection summaries and analysis results are presented in the Technical Appendix to this report, which follows Section 4.0. This appendix will be useful in the design, contracting, and execution of any energy efficiency project. The buildings evaluated are identified below.

NNMC Buildings Selected for Energy Efficiency Project Evaluation

<u>Building No.</u>	<u>Building Use</u>	<u>Building Area, ft²</u>
1	Dental Clinic	244,846
2	Personnel Support and Service	105,104
4	Administration 1	16,534
6	Administration 2	19,908
7	Medical/Old Hospital	83,844
8	Hospital	100,235
9	Service Block of Replacement Hospital	582,479
10	Nursing Tower of Replacement Hospital	328,000
12	Medical Hold	52,601
14	Facilities Management Building	27,720
16	Central Plant	47,744
50	Bachelor Enlisted Quarters	47,557
54	Medical Warehouse/Parking	330,040
55	South Parking Garage	386,107

The project recommendations are based upon an analysis of utility billing and central plant records, energy audit data, short-duration individual building electrical profile data, National Climate Center weather data from the Washington National Airport, and knowledge of other shared energy savings projects.

Selected buildings were metered to estimate their individual usage (both base [non-work period] and peak load) for periods ranging from 2 to 9 days. The results of the metering are summarized below.

Summary of Building Metering

<u>Building</u>	<u>Ave. Base Evening or Weekend Load, kW</u>	<u>Peak Workday Load, kW</u>
4	40	110
6	60	90
10	300	450
12	40	90
14	12	60
50	25	60
55B	100	50(a)

(a) Usage higher at night.

There is a significant non-work period baseload compared with the work-day peak load in Buildings 4, 6, 10 and 12, indicating that either lights are left on during non-working hours or that there is a significant plug load from equipment left on. A detailed equipment usage schedule audit was not performed. For Buildings 10 and 12, the activities in those building related to 24-hour operation may explain this observation.

From these metered data and historical energy consumption data, three primary energy savings project opportunities were identified: 1) replacement of incandescent and fluorescent fixtures with energy-efficient fixtures; 2) installation of lighting controls; and 3) incorporation of a thermal energy storage system with the existing chilled water production and distribution systems to reduce electrical consumption during periods of peak demand. Although the site is space-limited for a thermal energy storage system sized to serve the entire complex, a smaller system could be designed to serve a percentage of the load and still be life-cycle cost-effective.

These three projects are particularly cost-effective because of the availability of the servicing electric utility rebates and financial incentives for these technologies.

An additional opportunity exists for the use of gas-driven prime movers for chillers to meet additional demand as it occurs. This opportunity may or may not be attractive, depending upon the future need to replace existing chillers and the future demand requirements. This option needs to be thoroughly evaluated to assess cost-effectiveness.

The estimated capital or per unit cost and savings for each measure in the buildings surveyed are shown below.^(a) The costs do not include any utility rebate. Approximately 90% of the incandescent replacements, fluorescent upgrades and lighting controls would be in Buildings 1-10 (the hospital facilities).

Energy Efficiency Project Opportunities

<u>Measure</u>	<u>Cost, \$</u>	<u>Savings, \$/yr</u>	<u>Cost/unit</u>
Replace Incandescents	7,600	4,600	\$0.0203/kWh
Upgrade Fluorescents	1,040,000	440,000	\$0.0245/kWh
Lighting Controls			
Switching	15/fixture	20%	-
Occupancy	60/room	30%	-
Dimming	50/fixture	40%	
Thermal Energy Storage	NA	NA	\$800-\$1800/kW
Gas Chillers	NA	NA	\$700-\$800/ton

NA = Not Available.

The servicing electric utility, PEPCO, was contacted and presently offers attractive incentives (rebates) for both the lighting retrofit and the thermal energy storage project that will further improve project economics. It is likely that the utility will be open to discussing a "custom" program for the NNMCM, given the significant load savings available from a single customer. Such a program, combined with SES where applicable, would allow the

(a) Source for lighting retrofit values: Fort Lewis Electric Energy Baseline and Efficiency Resource Assessment. PNL-7763. Pacific Northwest Laboratory, Richland, Washington. October 1991.

NNMC to design significant cost-effective energy savings projects. Also, utility incentives will offset some of the additional costs associated with implementing an SES project at a site of the complexity of NNMC. These additional costs and complexities include the relatively tight space constraints that exist for the siting of a sizeable thermal energy storage facility, as well as the unique lighting requirements for medical clinics and customer service facilities. PEPCO's current "standard" incentive programs for the Maryland service territory are summarized below:

Program	Incentive
Commercial Lighting	A variety of direct rebates for controls, ballast, lamp, and fixture replacements. Rebates ranging from \$6 to \$60 are available and current custom programs
Thermal Energy Storage	Feasibility study plus \$250/kW for first 500 kW plus \$200/kW for any additional load deferred qualify for up to a \$300/kW rebate.
Curtailable Load	Special incentive rates proportional to the amount of load curtailed.

The monitoring and data collection undertaken in this study provided a "snapshot" of current and historical energy usage at the facility. The information provided a knowledge base to recommend viable energy conservation project opportunities.

Successful energy efficiency improvement projects linked with an SES solicitation require fair and simple methods to assess and share the risks and savings associated with the project. This includes determination of a projected baseline of how the system or building would use energy in lieu of the energy efficiency project. For projects at the central plant, this would include detailed flow, temperature and electrical consumption measurements. For lighting retrofit and control projects, "before and after" end-use metering of a representative sample, combined with engineering calculations, is generally sufficient.

The actual baseline development for SES contracting will need to be specific to the particular project and agreed upon between NAVFAC and the SES

contractor. It is our recommendation that the material in this report (particularly the attachments) be provided to SES proposers to aid in the development and evaluation of specific projects.

CONTENTS

PREFACE	iii
EXECUTIVE SUMMARY	v
1.0 INTRODUCTION	1.1
2.0 DATA SUMMARY AND FINDINGS	2.1
2.1 ELECTRIC UTILITY SUBSTATION USAGE	2.2
2.2 ELECTRIC UTILITY TARIFF ASSESSMENT	2.3
2.3 ELECTRIC USAGE COMPONENT DATA SUMMARY	2.3
2.4 STEAM AND CHILLED WATER PRODUCTION	2.4
2.5 ELECTRICAL MEASUREMENTS FOR SELECTED BUILDINGS	2.5
2.6 MAJOR CONNECTED ELECTRICAL LOADS FOR SELECTED BUILDINGS	2.6
3.0 ENERGY EFFICIENCY AND SHARED ENERGY SAVINGS PROJECTS IDENTIFICATION	3.1
3.1 LIGHTING EFFICIENCY RETROFITS	3.2
3.2 LIGHTING CONTROLS	3.3
3.3 THERMAL ENERGY STORAGE SYSTEMS	3.4
3.4 GAS ENGINE-DRIVEN CHILLERS	3.6
4.0 COMPREHENSIVE ENERGY USAGE BASELINING	4.1
4.1 LIGHTING AND CONTROLS RETROFITS	4.1
4.2 CENTRAL PLANT	4.1
4.3 GAS ENGINE-DRIVEN CHILLERS	4.2
TECHNICAL APPENDIX	A.1
Attachment 1: Source of Collected Data	1.1
Attachment 2: Electric Utility Substation Usage	2.1
Attachment 3: Electric Utility Tariff Data Summary	3.1
Attachment 4: Electric Usage Component Data Summary	4.1

Attachment 5:	Steam and Chilled Water Production Data Summary .	5.1
Attachment 6:	Electrical Measurements for Selected Buildings .	6.1
Attachment 7:	Major Connected Electrical Loads for Selected Buildings	7.1
Attachment 8:	Field Notes	8.1
Attachment 9:	PEPCO Incentives and FEMP Model Program	9.1

1.0 INTRODUCTION

This report provides an energy consumption evaluation of fourteen buildings and the central energy plant at the National Naval Medical Center (NNMC) in Bethesda, Maryland. Recommendations are also made for implementing energy efficiency projects funded with assistance from the servicing utility (Potomac Electric Power Company) in the form of rebates and incentives available in their Demand Side Management (DSM) program and through Shared Energy Savings (SES) projects. This report also provides estimates of costs and potential energy and dollar savings of the recommended projects.

The recommendations are based upon an analysis of utility billing and central plant records, energy audit data, short-duration individual building electrical profile data, National Climate Center weather data from the Washington National Airport, and knowledge of other shared energy savings projects. Preliminary findings were discussed with NNMC and NAVFAC staff to obtain their insights as well. Because the analyses were conducted using historical data combined with selected short-term electrical energy usage monitoring data, guidelines are given for more comprehensive data collection to support SES and/or utility DSM project development.

The majority of the data collection summaries and results are presented in the Technical Appendix at the end of this report. This appendix will be useful in the design, contracting, and execution of any energy efficiency project. The attachments in the appendix are organized according to the specific investigations undertaken for this project. Supporting data were entered into electronic spreadsheets that will also be useful for project development and subsequent analysis.

The attachments in the Technical Appendix include:

- Attachment 1: Sources of Collected Data
- Attachment 2: Electric Utility Substation Usage
- Attachment 3: Electric Utility Tariff Data Summary
- Attachment 4: Electric Cost Component Data Summary
- Attachment 5: Steam and Chilled Water Production Data Summary
- Attachment 6: Electrical Measurements for Selected Buildings

Attachment 7: Major Connected Loads for Selected Buildings

Attachment 8: Field Notes

Attachment 9: PEPCO Incentives and FEMP Federal Site/Utility Program

Section 2.0 of this report provides a summary of the data and findings of this study. In Section 3.0, the energy efficiency and SES project opportunities are reviewed. Section 4.0 is a discussion of more comprehensive energy use baselining that will be most effective to quantify energy efficiency and SES project performance. The Technical Appendix concludes this report.

2.0 DATA SUMMARY AND FINDINGS

A summary of the data, analysis results and their impact on energy and energy savings projects is presented in this section. Detailed discussions of the data summaries and analyses are found in the Technical Appendix at the end of this report.

The Navy identified fourteen buildings for evaluation. These are identified in Table 2.1. These buildings are provided with chilled water and steam from Building 16, the central heating and cooling plant. Electricity is provided to these buildings through a single substation that also serves other buildings at the facility.

The data collection effort began with a summary and review of purchased utility costs for NNMC during fiscal year (FY) 1989. The utility costs are summarized in Table 2.2. Because of the significant costs, the analyses and subsequent projects identified focused upon energy savings in the electrical loads and steam (fuel oil) usage.

TABLE 2.1. NNMC Buildings Selected for Energy Efficiency Project Evaluation

<u>Building No.</u>	<u>Building Use</u>	<u>Building Area, ft²</u>
1	Dental Clinic	244,846
2	Personnel Support and Service	105,104
4	Administration 1	16,534
6	Administration 2	19,908
7	Medical/Old Hospital	83,844
8	Hospital	100,235
9	Service Block of Replacement Hospital	582,479
10	Nursing Tower of Replacement Hospital	328,000
12	Medical Hold	52,601
14	Facilities Management Building	27,720
16	Central Plant	47,744
50	Bachelor Enlisted Quarters	47,557
54	Medical Warehouse/Parking	330,040
55	South Parking Garage	386,107

TABLE 2.2. Purchased Utility Costs in FY 1989

<u>Utility</u>	<u>Cost, \$</u>	<u>%</u>
Electricity	4,947,068	56.4
Fuel Oil	2,089,032	23.8
Natural Gas	12,871	0.1
Water	739,349	8.4
Sewage Disposal	<u>980,614</u>	<u>11.2</u>
Total	8,768,934	100.0

2.1 ELECTRIC UTILITY SUBSTATION USAGE (Attachment 2, Technical Appendix)

2.1.1 Data Summary

The electric utility usage for both the Jones Bridge and Wisconsin Avenue substations for October 1984 through September 1990 was examined. The average daily electrical consumption for the past 15 months was examined in relation to the outdoor temperature.

2.1.2 Findings

- Total electrical consumption is about 100,000 MWh per year, with about 17% of the consumption going to the Jones Bridge substation.
- Electrical consumption has been increasing at a rate of about 2.5% per year, primarily due to additions of new buildings.
- Monthly consumption ranges from 6,000 to 7,000 MWh for October to May, rising to 10,000 MWh in July and decreasing to 8,000 MWh in August and September.

2.1.3 Impact

Baseline NNMC electrical energy usage is about 83,000 MWh and is increasing at a faster rate than the Uniformed Services University of Health Sciences buildings (<0.5%/year). The site is summer-peaking with large electrical cooling loads year-round and therefore shows a significant opportunity for peak shifting or clipping.

2.2 ELECTRIC UTILITY TARIFF ASSESSMENT (Attachment 3, Technical Appendix)

2.2.1 Data Summary

Billing records for each substation from May 1988 through April 1989 were examined. The various components of the billing record were disaggregated and examined.

2.2.2 Findings

- The electric utility tariff assessment primarily provides information that will be useful in evaluation of cost savings for various SES projects.

2.2.3 Impact

The site has significant on-peak demand costs. The design of SES and energy efficiency projects should take into consideration the potential for peak demand reductions during different billing periods to maximize the energy savings.

2.3 ELECTRIC USAGE COMPONENT DATA SUMMARY (Attachment 4, Technical Appendix)

2.3.1 Data Summary

Electric demand and consumption were examined in relationship to outdoor temperature.

2.3.2 Findings

- Electric demand and consumption were found to be directly related to outdoor temperature. As the temperature increases, both demand and consumption increase.
- Electric demand ranged from 10,000 kW in the winter to 17,000 kW in the summer months.

2.3.3 Impact

These findings provide additional confirmation that significant electrical cooling loads are driving both consumption (kWh) and demand (kW).

2.4 STEAM AND CHILLED WATER PRODUCTION (Attachment 5, Technical Appendix)

2.4.1 Data Summary

Central plant records for July 1988 through September 1990 were evaluated to estimate the electrical usage of the chillers and to ascertain the relationship between building heating and cooling loads and outdoor temperature.

2.4.2 Findings

- Steam usage varies from 20 million pounds per month in warm months to 74 million pounds per month in cold months.
- Chilled water usage varies from 13 million Btu in cold months to 50 million Btu in warm months.
- Onsite temperature measurements are typically 4 to 6°F above measurements from Washington National Airport for the months of January through April.
- Steam usage is very temperature dependent, with lower temperatures leading to high steam usage. The straight-line relationship in the data suggests that the steam plant and the distribution system are operating with a high level of efficiency with few losses and relatively high combustion efficiency--particularly at the lower temperatures.
- Chillers consume from 40 MWh per day in winter to 130 MWh per day in the summer.
- Chilled water usage is also temperature dependent, with higher temperatures leading to higher chilled water usage. The chilled water production follows the outdoor temperature increase directly, but increases even faster at higher temperatures. The reason for this is likely twofold: as outdoor temperature increases, the coefficient of performance (efficiency) of the chiller drops while cooling requirements increase *combined* with a change in efficiency as the balance point (the temperature at which cooling is required to maintain a set inside temperature) changes with the season and building loads. This relationship in the chiller data suggests that the chillers and the distribution system are operating within expected levels of efficiency with few losses.
- The remaining base electrical load of the NNMC is about 160 to 180 MWh per day.

2.4.3 Impact

Significant amounts of steam and chilled water are used throughout the year. Chiller electrical loads are a major portion of the electrical demand. Depending upon the utility incentives, the site may be good candidate for thermal energy storage. High efficiency lighting retrofits will also reduce the chiller electrical loads by reducing the cooling demand in buildings.

2.5 ELECTRICAL MEASUREMENTS FOR SELECTED BUILDINGS

(Attachment 6, Technical Appendix)

2.5.1 Data Summary

Selected buildings were metered at the electrical service entrance for periods ranging from 2 to 9 days. Plots of the electrical usage were examined.

2.5.2 Findings

The results of this analysis are primarily the plots and charts that show the electrical load for each building. The data are summarized below in Table 2.3.

2.5.3 Impact

There is a significant non-work period baseload compared to the workday peak load in Buildings 4, 6, 10 and 12, indicating that either lights are left on during non-working hours or there is a significant plug load from equipment

TABLE 2.3. Summary of Building Metering

<u>Building</u>	<u>Ave. Base Evening or Weekend Load, kW</u>	<u>Peak Workday Load, kW</u>
4	40	110
6	60	90
10	300	450
12	40	90
14	12	60
50	25	60
55B	100	50(a)

(a) Usage higher at night.

left on. A detailed equipment usage schedule audit was not performed. For Buildings 10 and 12, the activities in those building related to 24-hour operation may explain this observation.

Given the significant baseload consumption, there is significant potential for both load (and corresponding consumption) reduction in all buildings metered.

2.6 MAJOR CONNECTED ELECTRICAL LOADS FOR SELECTED BUILDINGS

(Attachment 7, Technical Appendix)

2.6.1 Data Summary

The connected loads of electrical equipment were estimated at selected buildings based on construction documents and limited surveys.

2.6.2 Findings

The results of the connected load analysis and the lighting and HVAC notes used are included in Attachment 7. For Buildings 1-10 (the largest users), lighting and HVAC loads are nearly equal and constitute approximately 90% of the connected electrical load and therefore about 90% of the demand (kW) and usage (kWh) for the buildings.

2.6.3 Impact

Lighting retrofits will likely have a significant impact on energy usage and demand, and are included in the serving utilities DSM incentive programs. Lighting retrofits will also reduce air conditioning load (10 to 15% reduction).

3.0 ENERGY EFFICIENCY AND SHARED ENERGY SAVINGS PROJECTS IDENTIFICATION

This section reviews the analysis products in the Technical Appendix attachments and identifies potential shared energy savings project opportunities. The most viable project opportunities include:

1. Lighting Efficiency Retrofits
2. Lighting Controls
3. Thermal Energy Storage
4. Gas Engine-Driven Chillers

Recommendations are given for viable energy efficiency projects and institute shared energy savings solicitations in these areas. The servicing utility, Potomac Electric Power Company (PEPCO), was contacted. PEPCO's current incentive programs are summarized below. These programs are described in greater detail in Attachment 9.

<u>Program</u>	<u>Incentive</u>
Commercial Lighting	A variety of direct rebates for controls, ballast, lamp, and fixture replacements. Rebates ranging from \$6 to \$60 are available and current custom programs qualify for up to a \$300/kW rebate.
Thermal Energy Storage	Feasibility study plus \$250/kW for first 500 kW plus \$200/kW for any additional load deferred.
Curtaillable Load	Special incentive rates proportional to the amount of load curtailed.

These standard programs, available to all PEPCO customers in Maryland, should be the starting point for development of a custom energy efficiency program for the NNMC. Therefore, also included in Attachment 9 is a description of a Federal Agency Energy Efficiency Model Program that outlines a process developed by DOE/FEMP to implement cost-shared energy efficiency programs between federal agencies and their servicing utilities. It is likely that the utility will be open to discussing such a "custom" program with the NNMC, given the significant load savings available from a single customer.

Such a program, combined with SES where applicable, would allow the NNMC to design significant cost-effective energy savings projects.

3.1 LIGHTING EFFICIENCY RETROFITS

The lighting systems employed in most of the NNMC buildings are primarily old-technology fluorescent and in good condition. Overall approximately 70% of the lighting capacity at the selected buildings is fluorescent, with less than 10% incandescent. The remaining lighting is mercury, sodium and halide. There are cost-effective efficiency improvements using new-technology fluorescent fixtures, and other improvements--particularly at the parking garages and Buildings 9 and 10.

The exterior lighting of the parking lot fixtures is predominantly mercury-vapor, and these could be cost-effectively upgraded to sodium fixtures. This would also be accompanied by a controls upgrade indicated below.

Buildings 9 and 10 have a significant number of incandescent lamps in recessed fixtures. These lamps should be replaced with compact fluorescent lamps to reduce frequency of replacement and energy consumption.

The estimated costs and savings for a lighting retrofit are given below.^(a) Note that while the majority of the lighting is already fluorescent, there are opportunities for greatly improving fluorescent fixture performance with new technologies. As noted above, significant incentives are available from the utility for lighting retrofits (see Attachment 8).

<u>Measure</u>	<u>Cost, \$</u>	<u>Savings, \$/yr</u>	<u>Cost/Unit</u>
Replace Incandescents	7,600	4,600	\$0.0203/kWh
Upgrade Fluorescents	1,040,000	440,000	\$0.0245/kWh

The estimated costs were calculated assuming that individual incandescent fixtures are 75 watt bulbs, and an 18 watt compact fluorescent can

(a) Fort Lewis Electric Energy Baseline and Efficiency Resource Assessment. PNL-7763. Pacific Northwest Laboratory, Richland, Washington. October 1991.

replace the incandescent for an installed cost of about \$16.00. The compact fluorescent will use about 18 watts, saving 75% of the energy. Based on an energy cost of \$0.05/kWh and an annual usage of 3500 hours, the dollar savings are \$14.00 per bulb. This is a capital investment of \$7600 and a reduction of about 26,000 watts in the lighting load. For 3500 hours usage, approximately 91,000 kWh and 25 kW are saved over the course of the year. Estimated demand charges are \$7/kW.

Assuming that the fluorescent fixtures are standard 2 x 4 fixtures, upgrades will cost approximately \$40 per fixture and these fixtures can save about 50% of the energy usage. For the estimated 26,000 fixtures in the buildings surveyed (about 10% of the square footage of the NNMCC), the capital cost is 1,040,000, with energy savings of 1,750,000 kWh and 500 Kw per year.

3.2 LIGHTING CONTROLS

The staff at NNMCC has an effective program to turn off the interior lights during unoccupied periods. However, the hallway lights in Building 1 to 10 are left on 24 hours a day although they are seldom needed. The use of occupancy/motion detector on approximately 75% of these lights would be viable to cut electrical consumption and extend lamp life. These detectors would need to be set to keep the lights on for approximately one-half ($\frac{1}{2}$) hour after motion is detected to keep from having the hallway lights come on and off excessively during the occupied periods.

Buildings 9 and 10 could benefit from daylighting controls (effective with fluorescent fixtures) to automatically dim the downlights in the large interior sunspace and along perimeter offices. These controls would dim or extinguish particular fixtures in the daylight areas to maintain adequate lighting levels. Occupancy controls should also be included in individual offices where appropriate. This technology would save energy during hours of peak electrical demand. The lighting controls for the parking garages appear to operate irregularly. The combination of time clocks and solar sensors currently used is the correct approach, but apparently the mechanical time clocks or other aspects of the control system are not operating correctly.

Consequently, we would recommend the replacement of the control system in conjunction with an upgrade the fixture efficiencies in the parking garages.

All control systems will save both kW and kWh if properly installed and operated. PEPCO offers incentives for installing lighting controls. The basic idea is to turn off lights when they are not needed and turning off lights cannot help but save energy.

Estimating the cost and potential savings of a lighting control system is difficult without a detailed survey of the lighting system in each building. If, as in the parking garage, adequate controls are already installed, the cost to reactivate the control system is minimal. If controls must be installed, as in Buildings 9 and 10, the cost is primarily a function of the number of points of control. An estimate of the energy savings from controls is given below.

<u>Measure</u>	<u>Cost, \$</u>	<u>Savings</u>	<u>Cost/kWh</u>
Lighting Controls			
Switching	\$15/fixture	20%	NA
Occupancy	\$60/room	30%	NA
Dimming	\$50/fixture	40%	NA

NA = not available

3.3 THERMAL ENERGY STORAGE SYSTEMS

During the summer months the majority of electrical costs are for peak demand charges and on-peak energy consumption. Examination of data shows that approximately 40% of these charges are due to the operation of the central plant chillers. Consequently, methods to shift chiller electrical consumption to other times of the day (off-peak) will reduce overall electrical energy cost. Integrating the system with the large and constant chilled water production of the central plant will ensure higher thermal storage utilization.

This would involve the construction of a thermal energy storage plant to store chilled water or ice generated during the off-peak hours of the day. This stored water or ice could then be used during the peak periods to offset the use of electric chillers. Such a system would also allow the chillers to

be operated at higher efficiencies by providing more constant loads for the chillers to meet. Furthermore, the system will provide additional cooling capacity to meet peak demands that may occur in the future.

Thermal storage capital costs are about \$800 to \$1300 per kW shifted for large systems (Buildings 1, 9 and 10) and about \$1300 to \$1800 per kW shifted for smaller systems (Buildings 2, 3, 5 and 7). Buildings 4, 6 and 8 show somewhat lower costs for small systems, with capital costs ranging from \$800 to \$1400 per kW shifted. Note that thermal storage systems will not reduce electrical consumption. Shifting the cooling load from the peak to offpeak hours does not appreciably change the total electrical consumption. Estimated costs are given below.

<u>Measure</u>	<u>Peak kW savings</u>	<u>Estimated Cost</u>
Thermal Energy Storage	8,000 to 10,000	\$800/kW to \$1800/kW

An assessment of thermal energy storage was done for the National Naval Medical Center by Morrison & Associates in the summer of 1990. This assessment was only a preliminary assessment of the potential and should not be taken as a detailed analysis. Equipment was sized for individual buildings rather than for a single central thermal storage plant. This idea may be viable for the NNMC due to the lack of sufficient space for a large central plant. The results of the Morrison & Associates thermal storage calculation are listed below in Table 3.1.

TABLE 3.1 Thermal Energy Storage Savings for Selected Buildings

<u>Building</u>	<u>kW Shifted</u>	<u>Capital, \$</u>	<u>Annual Savings, \$</u>	<u>Simple Payback, yr</u>
1	2024	2.0-2.6M	170,000	12.2
2	448	0.6-0.8M	41,000	17.0
3&5	425	0.5-0.7M	38,000	12.5
4&6	496	0.4-0.6M	43,000	9.8
7	305	0.4-0.5M	30,000	12.6
8	482	0.5-0.7M	43,000	11.3
9	3457	2.9-4.0M	310,000	9.2
10	1470	1.4-1.9M	136,000	10.0
Total	9107	8.7-11.8M	811,000	10.7

Capital includes credit for utility rebate of \$250/kW for the first 500 kW and \$200/kW for any kW above 500 kW that is shifted to off-peak. The low end of the capital cost range does not include a new chiller necessary to achieve extra cooling capacity. Savings and kW shifted are calculated with a simple design week calculation and not with a complete annual energy analysis. Simple payback in the table is based on the low range of the capital costs.

A detailed economic evaluation of thermal storage at NNMC that includes the current (or negotiated) utility incentives was not undertaken, however PEPCO will pay part of the costs for such an assessment. As noted above, PEPCO presently offers attractive incentives (rebates) that will further improve project economics. This will offset some of the additional costs and complexities associated with implementing a thermal storage SES project at a site of the complexity of NNMC. These additional costs and complexities include the relatively tight space constraints that exist for the siting of a sizeable thermal energy storage facility, and the unique lighting requirements for medical clinics and customer service facilities. Nonetheless, these issues do not appear to be insurmountable.

3.4 GAS ENGINE-DRIVEN CHILLERS

This is an alternative strategy to reduce the electrical charges stemming from the electric chiller operation. It may be possible to retrofit the existing chillers with natural gas engines, although this may present significant integration and warranty liabilities. A better approach would be the installation of gas prime movers for new additions to chiller capacity. If such a system is instituted it would probably be cost effective to also integrate a heat recovery system to offset boiler plant energy requirements.

A recent study in the Washington, D.C., region performed for the Pentagon Building by Washington Gas & Light estimated that the cost of gas chillers would be about \$700 to \$800 per installed ton. Natural gas has recently been brought onto the site at NNMC and the gas utility may offer an incentive program for use of gas fired equipment. The estimated cost for a gas-driven chiller system is given below.

<u>Measure</u>	<u>Estimated kW savings</u>	<u>Estimated Cost</u>
Gas Chillers	As needed to meet new load	\$700/ton - \$800/ton

As pointed out above, this option is probably only attractive if there is a need for additional cooling capability or if there is a need to replace an existing chiller at the site. This option should not be considered "peak shaving" as much as a "maintenance of current peak." Gas chillers will also reduce electrical consumption in direct proportion to the number of hours that chiller is operated.

4.0 COMPREHENSIVE ENERGY USAGE BASELINING

The monitoring and data collection undertaken in this study provided a "snapshot" of current energy usage at the Bethesda facility. The information provided a knowledge base to recommend viable energy conservation project opportunities.

Successful energy efficiency improvement projects linked with an SES solicitation require fair and simple methods to assess and share the risks and savings associated with the project. This includes determination of a projected baseline of how the system or building would use energy in lieu of the energy efficiency project.

The actual baseline development for SES contracting will need to be specific to the particular project and agreed upon between NAVFAC and the SES contractor. It is our recommendation that the material in this report (particularly the attachments) be provided to SES proposers to aid in the development and evaluation of specific projects.

4.1 LIGHTING AND CONTROLS RETROFITS

For lighting retrofit and control projects, "before and after" end-use metering of a representative sample of buildings, combined with engineering calculations, is generally sufficient.

4.2 CENTRAL PLANT

For any SES central plant modification projects the best approach to determination of savings will be the direct measurement of energy flows. For the thermal energy storage system it will be necessary to accurately measure the time and quantities of chilled water delivered to and extracted from storage. A value can be placed on these energy flows by comparison with the existing chilled water system energy costs to meet equivalent demands. The instrumentation would include flow metering, temperature measurements for heat balance and for outside temperature, and electrical consumption of the entire

central plant. These measurements are typically made for the proper operation of the system so no additional measurement burden is imposed to develop energy use baselines and savings levels.

To determine the economic performance of the thermal energy storage facility, it will be necessary to measure the quantities of chilled water provided to and from the system. The procedure would be to calculate the energy costs to charge the system, and subtract this from the energy costs that would have occurred had the chillers been used to deliver cooling when the thermal storage system is discharged. This would principally be driven by the time of day utility tariff, with a minor adjustment for differences in the chiller coefficient of performance.

4.3 GAS ENGINE-DRIVEN CHILLERS

In the case of gas engine-driven chillers (gas prime movers), it is necessary to measure the energy input to the systems as well as the system outputs. This includes gas delivery and chilled water flow metering, temperatures and electrical consumption data. Once again, these measurements are typically integrated with the control and maintenance systems. Provisions to ensure that the systems are operated for a minimum number of hours during the year is likely required to protect the SES contractor from conditions where NNMC unilaterally ceases or reduces site activities.

Technical Appendix

TECHNICAL APPENDIX

Most of the data presented in the attachments to this document were summarized using electronic spreadsheet programs. These spreadsheets include "named graphs" for many of the figures included in the attachment. The tables were produced using the ALWAYS® LOTUS 123 add-in program. Other plots were produced using the GRAPHWRITER® program.

The spreadsheets are labeled and include formulas for many of the entries so that supplemental data can be added with ease and modifications to meet specific requirements are possible. These files are available from CHESDIV.

Attachment 1: Sources of Collected Data

ATTACHMENT 1: SOURCES OF COLLECTED DATA

Information of various types were obtained by PNL and NNMC staff during the period of May 1989 through January 1991. At the outset PNL staff conducted the following site data collection efforts:

1. A coordination meeting was held with NNMC and Chesapeake NAVFACENGCOM staff to discuss the objectives and coordinate the site survey.
2. The construction documents for the eighteen buildings selected for study were reviewed and copies of critical drawings were obtained. Each building was visited subsequently to confirm some of this information.
3. Historical energy consumption measurements pertaining to the electric meters at NNMC were obtained in either electronic or tabular form.
4. The energy consumption meters at NNMC were inventoried to identify the type, frequency of data collection, location, and metered loads.
5. Central plant logs were reviewed and data for an arbitrarily selected summer and winter week were obtained.
6. Electric load profile data provided by PEPCO for the Wisconsin Ave. substation were reviewed.
7. A wrap up meeting with NNMC and Chesapeake NAVFACENGCOM staff was held to discuss preliminary observations and progress.

After these data were reviewed and analyzed recommendations for further site data collection were developed. Many were rejected due to cost constraints and the following supplemental data collection activities occurred:

1. Additional PEPCO billing data, and central plant records were obtained and selected data assembled into electronic spreadsheets for analysis. These data appear in Attachments 2 through 5.
2. Local Climatological Data summaries for National airport were obtained for the period October 1989 through December 1990 for comparison with on-site temperatures reported in the central plant records, and to compare the weather conditions during this period with historical averages. These data appear in Attachments 4 and 45

3. Time series (hourly) electrical consumption measurements for each of the electrical mains for buildings 1-8, 9-10, 12, 14, 50, 54, and 55 were made by NNMC staff using PNL Dranetz 808 power analyzers. These data are summarized in Attachment 6.
4. Construction documents were reviewed and selected surveys were conducted to estimate the electrical capacities of major connected loads. These data are summarized in Attachment 7.
5. Lighting surveys were conducted for each of the buildings indicated above to determine the installed capacities by type and to estimate the lighting levels during occupied and unoccupied periods. This involved a walk-through inspection of the buildings during both periods, selected measurement of lighting footcandle levels, and detailed review of construction documents. These data and other field notes are summarized in Attachment 8.

Attachment 2: Electric Utility Substation Usage

ATTACHMENT 2: ELECTRIC UTILITY SUBSTATION USAGE

The total electrical consumption for the facility is metered by PEPCO at two substations known as Jones Bridge and Wisconsin Ave. The total consumption is approximately 100,000 MWh/year, with the Jones Bridge substation constituting approximately 17% of this total. The Jones Bridge substation principally services the Uniformed Services University of Health Sciences (USUHS) buildings that are not part of this evaluation.

Historical data by month from Oct 1984 through September 1990 are presented and displayed graphically and in tables following the figures. These data indicate that with the exception of fiscal year 1986, electrical use is increasing at a rate averaging 2.5% per year while USUHS loads increased at an average annual rate of less than 0.5%. This is in part due to the additions of new buildings to NNMC over the years and additional electronic equipment utilization. This trend introduces uncertainties for whole facility electrical use baselining as it is difficult to predict, but impossible to ignore.

The attachment also includes a folded plot that compares monthly Wisconsin Ave. feeder measurements over the past six years. The plot shows similar profiles for periods of interest. Electrical consumption is typically between 6,000 and 7,000 MWh for October through May, rising to 10,000 MWh in July and then decreasing back to 8,000 MWh in August and September. This shows a clear seasonal dependence, with significantly higher loads during the summer months, when electrical rates are highest.


Also included in the attachment is a plot depicting the relationship of average daily electrical consumption to outdoor temperature for the most recent 15 months. The month and year are located to correspond to the averages during the respective billing periods. This plot shows a clear relationship between electrical usage and outdoor temperature. Once the temperature climbs above 50 or 60°F, the electrical usage starts to rise significantly.

**TOTALIZED NNMC ELECTRICITY FROM PEPCO UTILITY FEEDERS
MEGAWATT-HOURS PER FISCAL YEAR BY MONTH**

	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	FY
JB84	2543	1439	1339	1485	1371	1312	1275	1437	1328	1346	1374	1329	17577
WA84	3267	6578	5737	5927	5527	5300	5481	7188	7620	8311	8571	7556	77064
TOTAL	5810	8017	7075	7412	6898	6612	6756	8625	8948	9657	9945	8885	94641
JB85	1309	1510	1386	1579	1440	1462	1375	1423	1371	1499	1396	1448	17198
WA85	6238	6573	5670	6167	5594	5870	6233	6778	7050	8543	8180	7773	80668
TOTAL	7547	8083	7056	7746	7034	7332	7608	8201	8420	10043	9576	9221	97866
JB86	1581	1230	1587	1494	1517	1040	1103	1227	1546	1620	1619	1511	17074
WA86	6763	5862	6497	5832	5934	5577	5640	6847	8022	9383	6208	7853	80420
TOTAL	8343	7093	8085	7326	7451	6617	6743	8074	9568	11002	7827	9364	97494
JB87	1324	1201	1657	1394	1534	1102	1235	1313	1483	1682	1574	1622	17121
WA87	6770	5784	6543	5431	5883	5614	5780	7052	8652	9121	8555	8329	83513
TOTAL	8094	6985	8200	6825	7417	6716	7014	8365	10135	10803	10129	9951	100634
JB88	1369	1396	1586	1471	1510	1367	1355	1346	1510	1419	1378	1506	17212
WA88	6223	5755	6897	6349	6625	6162	6122	6684	8237	8844	8512	7864	84275
TOTAL	7592	7151	8482	7820	8135	7529	7477	8030	9747	10263	9890	9370	101486
JB89	1390	1563	1501	1499	1446	1394	1401	1548	1420	1472	1506	1468	17608
WA89	6503	7056	6366	6338	6096	6111	6328	7582	8495	9858	8264	8541	87537
TOTAL	7893	8619	7867	7836	7543	7505	7729	9130	9915	11330	9770	10009	105145
JB90	1417	1629	1468	1702	1511	1404	1547	1482	1473	1561	1390	1487	18072
WA90	6786	7561	6690	7720	6715	6449	7311	7171	7842	9346	8080	7813	89483
TOTAL	8203	9189	8158	9422	8226	7853	8858	8653	9314	10907	9470	9300	107555


NNMC ELECTRICITY CONSUMPTION

METERED BY PEPCO SUBSTATIONS



NNMC LESS USUHS ELECTRICAL USE

BY FISCAL YEAR MONTHS 1985-90



ANNUAL PEPCO ELECTRIC FEEDER TOTALS - MWH

FEEDER	FY84	FY85	FY86	FY87	FY88	FY89	FY90
USUHS	17,577	17,198	17,074	17,121	17,212	17,608	18,072
NNMC	77,064	80,668	80,420	83,513	84,275	87,537	89,483
TOTAL	94,641	97,866	97,493	100,634	101,486	105,145	107,555

ANNUAL PEPCO ELECTRIC FEEDER AVERAGES - MW

FEEDER	FY84	FY85	FY86	FY87	FY88	FY89	FY90
USUHS	2.01	1.96	1.95	1.95	1.96	2.01	2.06
NNMC	8.80	9.21	9.18	9.53	9.62	9.99	10.21
TOTAL	10.80	11.17	11.13	11.49	11.59	12.00	12.28


ANNUAL CHANGE IN ELECTRIC FEEDER AVERAGE - KW

FEEDER	FY84	FY85	FY86	FY87	FY88	FY89	FY90
USUHS		-43.28	-14.19	5.38	10.33	45.22	53.06
NNMC		411.47	-28.38	353.13	86.95	372.42	222.11
TOTAL		368.20	-42.57	358.50	97.28	417.64	275.17


ANNUAL CHANGE IN ELECTRIC FEEDER AVERAGES - %

FEEDER	FY84	FY85	FY86	FY87	FY88	FY89	FY90
USUHS		-2.2%	-0.7%	0.3%	0.5%	2.3%	2.6%
NNMC		4.7%	-0.3%	3.8%	0.9%	3.9%	2.2%
TOTAL		3.4%	-0.4%	3.2%	0.8%	3.6%	2.3%

MONTHLY ELECTRICAL USE FROM NNMCM BILLS



DAILY ELECTRIC USE VERSUS TEMPERATURE




Attachment 3: Electric Utility Tariff Data Summary


ATTACHMENT 3: ELECTRIC UTILITY TARIFF DATA SUMMARY

Billing records for the period May 1988 through April 1989 are given in this attachment for each of the substations feeders. The contribution of each component of the utility bill to the total is tabulated and graphed. It is important to appreciate the value of peak demand reductions and energy savings during different billing periods when devising SES projects. Since the PEPCO tariff changed effective June 1, 1989, the last three figures in this attachment compares what the bills will be like in the coming year if the consumption is identical to the prior year.


NNMC ELECTRICAL COST ELEMENTS PEPCO BILLING FOR WISCONSIN FEED



NNMC ELECTRIC BILL MAY88-APR89 CHARGES
FOR WISCONSIN FEED TOTAL OF \$4,026,649




NNMC PEPCO BILLING COMPONENTS FOR WISCONSIN STREET FEEDER



NNMC PEPCO ELECTRIC ENERGY RATES INCLUDING FUEL RATE RIDER ADJUSTMENTS

DOLLARS PER KILOWATT-HOUR



OTHER INCLUDES MD ENVIRONMENTAL
SURCHARGE AND MONTGOMERY COUNTY
ENERGY TAXES

TOTAL IS CALCULATED BY DIVIDING THE MONTHLY BILL
BY THE TOTAL KILOWATT-HOURS CONSUMED IN THE
MONTH, THUS INCLUDING DEMAND AND OTHER COSTS

NNMC ELECTRIC BILLING DATA FROM PEPCO
CONSUMPTION DATA
WISCONSIN STREET SUBSTATION

BILLING PERIOD	MAXIMUM DEMAND KW	ON-PEAK KW	CURTAIL CREDIT KW	CURTAIL PENALTY KW	OFF-PEAK KWH	INT-PEAK KWH	ON-PEAK KWH	TOTAL KWH
MAY88	13946	13946	0		3,158,189	1,726,805	1,798,638	6,683,632
JUN88	15395.4	15309.2	2309.2		4,206,463	1,957,961	2,049,603	8,214,027
JUL88	15851.4	15851.4	1241.9	109.5	4,356,975	2,168,502	2,318,574	8,844,051
AUG88	15598.1	15481.5	981.5		4,176,430	2,138,958	2,196,614	8,512,002
SEP88	14057.5	14022			4,127,930	1,835,604	1,900,955	7,864,489
OCT88	12086.2				3,254,818	1,574,070	1,573,970	6,502,858
NOV88	11169				3,772,633	1,607,288	1,675,754	7,055,675
DEC88	11062.6				3,069,357	1,612,893	1,683,317	6,365,567
JAN89	10413.9				3,413,588	1,427,578	1,496,123	6,337,289
FEB89	11123.4				2,959,182	1,527,030	1,610,037	6,096,249
MAR89	13180.8				2,899,957	1,589,131	1,670,909	6,159,997
APR89	12633.5				2,991,995	1,629,525	1,706,550	6,328,070
TOTAL					42,387,517	20,795,345	21,781,044	84,963,906
AVERAGE	13043.15	14922.02	1133.15	109.5	3,532,293	1,732,945	1,815,087	7,080,326

NNMC ELECTRIC BILLING DATA FROM PEPKO

RATE DATA

WISCONSIN STREET SUBSTATION

BILLING PERIOD	MAXIMUM DEMAND PER KW	ON-PEAK DEMAND PER KW	CURTAIL CREDIT PER KW	CURTAIL PENALTY PER KW	OFF-PEAK PER KWH	INT-PEAK PER KWH	ON-PEAK PER KWH	OTHER PER KWH
MAY88	7.4500	5.3000			0.0251	0.0330	0.0401	0.001138
JUN88	7.4500	5.3000	8.2947		0.0251	0.0330	0.0401	0.001138
JUL88	7.4500	5.3000	8.2947	16.5894	0.0251	0.0330	0.0401	0.001167
AUG88	7.4500	5.3000	8.2947		0.0251	0.0330	0.0401	0.001167
SEP88	7.4500	5.3000			0.0241	0.0320	0.0391	0.001167
OCT88	7.4500				0.0241	0.0333	0.0354	0.001167
NOV88	7.4500				0.0241	0.0333	0.0354	0.001167
DEC88	7.4500				0.0241	0.0333	0.0354	0.001167
JAN89	7.4500				0.0241	0.0333	0.0354	0.001167
FEB89	7.5000				0.0235	0.0328	0.0349	0.001167
MAR89	7.5000				0.0235	0.0328	0.0349	0.001167
APR89	7.5000				0.0225	0.0318	0.0339	0.001167
TOTAL								
AVERAGE	7.4625	5.3000	8.2947	16.5894	0.0242	0.0329	0.0371	0.0012


NNMC ELECTRIC BILLING DATA FROM PEPCO
COST DATA
WISCONSIN STREET SUBSTATION

BILLING PERIOD	DISTRIBUTION COST	PRODUCTION COST	OFF-PEAK COST	INT-PEAK COST	ON-PEAK COST	OTHER COST
MAY88	\$103,897.70	\$73,913.80	\$79,300.23	\$57,035.33	\$72,147.44	\$7,605.40
JUN88	\$114,695.73	\$81,138.76	\$105,621.76	\$64,670.28	\$82,185.89	\$9,346.92
JUL88	\$118,092.93	\$84,012.42	\$109,401.03	\$71,624.32	\$92,944.57	\$10,321.55
AUG88	\$116,205.85	\$82,051.95	\$104,867.65	\$70,648.50	\$88,066.24	\$9,934.03
SEP88	\$104,728.38	\$74,316.60	\$99,393.12	\$58,736.03	\$74,279.79	\$9,178.36
OCT88	\$90,042.19		\$78,402.71	\$52,460.92	\$59,240.91	\$7,589.25
NOV88	\$83,209.45		\$90,875.94	\$53,568.01	\$59,303.83	\$8,234.01
DEC88	\$82,416.37		\$73,935.29	\$53,754.82	\$59,570.56	\$7,429.01
JAN89	\$77,583.56		\$82,227.19	\$47,578.60	\$52,968.57	\$7,396.01
FEB89	\$83,425.50		\$69,557.64	\$50,095.29	\$56,178.51	\$7,114.71
MAR89	\$98,856.00		\$68,165.52	\$52,132.56	\$58,294.77	\$7,189.08
APR89	\$94,751.25		\$67,276.20	\$51,795.11	\$57,792.66	\$7,385.25
TOTAL	\$1,167,904.91	\$395,433.53	\$1,029,024.28	\$684,099.77	\$812,973.74	\$98,723.58
AVERAGE	\$97,325.41	\$79,086.71	\$85,752.02	\$57,008.31	\$67,747.81	\$8,226.96

NNMC ELECTRIC BILLING DATA FROM PEP
COST DATA ADJUSTMENTS
WISCONSIN STREET SUBSTATION

BILLING PERIOD	DISCOUNT	CURTAIL CREDIT	CURTAIL PENALTY	TOTAL COST
MAY88	\$12,835.10			\$381,064.80
JUN88	\$14,452.37	\$19,154.12		\$424,052.85
JUL88	\$15,229.72	\$10,301.19	\$1,816.54	\$462,682.45
AUG88	\$14,839.88	\$8,141.25		\$448,793.09
SEP88	\$13,353.80			\$407,278.48
OCT88	\$8,038.30			\$279,697.68
NOV88	\$7,871.37			\$287,319.87
DEC88	\$7,640.83			\$269,465.22
JAN89	\$7,200.83			\$260,553.10
FEB89	\$7,559.83			\$258,811.82
MAR89	\$8,412.93			\$276,225.00
APR89	\$8,295.11			\$270,705.36
TOTAL	\$125,730.07	\$37,596.56	\$1,816.54	\$4,026,649.72
AVERAGE	\$10,477.51	\$12,532.19	\$1,816.54	\$335,554.14

NNMC ELECTRIC BILL JUN88-MAY89 CHARGES
FOR USUHS FEED TOTAL OF \$829,253.27



UTILITY CHARGE



NNMC ELECTRIC BILLING DATA FROM PEP
CO
CONSUMPTION DATA
JONES BRIDGE SUBSTATION

BILLING PERIOD	MAXIMUM DEMAND KW	ON-PEAK KW	CURTAIL CREDIT KW	CURTAIL PENALTY KW	OFF-PEAK KWH	INT-PEAK KWH	ON-PEAK KWH	TOTAL KWH
MAY88	2675.5	2626.6	0		612,089	356,918	377,429	1,346,436
JUN88	2695.7	2655.4	0		754,736	363,766	391,546	1,510,048
JUL88	2652.5	2652.5	0	0	663,626	361,716	393,265	1,418,607
AUG88	2695.7	2655.7	0		626,625	362,787	388,557	1,377,969
SEP88	2754.7	2754.7			755,529	365,173	385,271	1,505,973
OCT88	2737.4				658,747	351,146	380,008	1,389,901
NOV88	2723				806,232	368,495	388,159	1,562,886
DEC88	2780.6				698,081	386,682	416,336	1,501,099
JAN89	2728.8				784,061	343,760	370,921	1,498,742
FEB89	2750.4				677,794	370,344	398,192	1,446,330
MAR89	2723				629,590	367,053	397,628	1,394,271
APR89	2753.3				637,556	367,898	398,575	1,404,029
TOTAL					8,304,666	4,365,738	4,685,887	17,356,291
AVERAGE	2722.55	2676.98	0	0	692,056	363,812	390,491	1,446,358

NNMC ELECTRIC BILLING DATA FROM PEP
CO
COST DATA
JONES BRIDGE SUBSTATION

BILLING PERIOD	DISTRIBUTION COST	PRODUCTION COST	OFF-PEAK COST	INT-PEAK COST	ON-PEAK COST	OTHER COST
MAY88	\$19,932.48	\$13,920.98	\$15,369.19	\$11,788.79	\$15,299.93	\$1,532.16
JUN88	\$20,082.97	\$14,073.62	\$18,950.97	\$12,014.97	\$15,864.60	\$1,718.33
JUL88	\$19,761.13	\$14,058.25	\$16,663.25	\$11,947.27	\$15,933.36	\$1,655.62
AUG88	\$20,082.97	\$14,287.21	\$15,734.18	\$11,982.63	\$15,745.05	\$1,608.19
SEP88	\$20,522.51	\$14,599.91	\$18,191.78	\$11,684.88	\$15,216.32	\$1,757.58
OCT88	\$20,393.63		\$15,868.03	\$11,702.07	\$13,605.20	\$1,622.08
NOV88	\$20,286.35		\$19,420.68	\$12,281.27	\$13,892.67	\$1,824.00
DEC88	\$20,715.47		\$16,815.51	\$12,887.42	\$14,886.42	\$1,751.89
JAN89	\$20,329.56		\$18,886.62	\$11,456.90	\$13,284.71	\$1,749.14
FEB89	\$20,628.00		\$15,932.02	\$12,149.40	\$14,047.87	\$1,687.97
MAR89	\$20,422.50		\$14,798.95	\$12,041.43	\$14,028.26	\$1,627.22
APR89	\$20,649.75		\$14,335.70	\$11,693.78	\$13,654.52	\$1,638.59
	\$243,807.32	\$70,939.97	\$200,966.88	\$143,630.81	\$175,458.91	\$20,172.77
AVERAGE	\$20,317.28	\$14,187.99	\$16,747.24	\$11,969.23	\$14,621.58	\$1,681.06


**NNMC ELECTRIC BILLING DATA FROM PEP
CO
RATE DATA
JONES BRIDGE SUBSTATION**

BILLING PERIOD	MAXIMUM DEMAND PER KW	ON-PEAK DEMAND PER KW	CURTAIL CREDIT PER KW	CURTAIL PENALTY PER KW	OFF-PEAK PER KWH	INT-PEAK PER KWH	ON-PEAK PER KWH	OTHER PER KWH
MAY88	7.4500	5.3000			0.0251	0.0330	0.0405	0.001138
JUN88	7.4500	5.3000	ERR		0.0251	0.0330	0.0405	0.001138
JUL88	7.4500	5.3000	ERR	ERR	0.0251	0.0330	0.0405	0.001167
AUG88	7.4500	5.3000	ERR		0.0251	0.0330	0.0405	0.001167
SEP88	7.4500	5.3000			0.0241	0.0320	0.0395	0.001167
OCT88	7.4500				0.0241	0.0333	0.0358	0.001167
NOV88	7.4500				0.0241	0.0333	0.0358	0.001167
DEC88	7.4500				0.0241	0.0333	0.0358	0.001167
JAN89	7.4500				0.0241	0.0333	0.0358	0.001167
FEB89	7.5000				0.0235	0.0328	0.0353	0.001167
MAR89	7.5000				0.0235	0.0328	0.0353	0.001167
APR89	7.5000				0.0225	0.0318	0.0343	0.001167
TOTAL								
AVERAGE	7.4625	5.3000	ERR	ERR	0.0242	0.0329	0.0375	0.0012

NNMC ELECTRIC BILLING DATA FROM PEP
CO
COST DATA ADJUSTMENTS
JONES BRIDGE SUBSTATION

BILLING PERIOD	DISCOUNT	CURTAIL CREDIT	CURTAIL PENALTY	TOTAL COST
MAY88	\$2,510.24			\$75,333.29
JUN88	\$2,585.41	\$0.00		\$80,120.05
JUL88	\$2,542.86	\$0.00	\$0.00	\$77,476.02
AUG88	\$2,555.70	\$0.00		\$76,884.53
SEP88	\$2,628.43			\$79,344.55
OCT88	\$1,802.67			\$61,388.34
NOV88	\$1,859.46			\$65,845.51
DEC88	\$1,887.36			\$65,169.35
JAN89	\$1,822.17			\$63,884.76
FEB89	\$1,856.00			\$62,589.26
MAR89	\$1,828.84			\$61,089.52
APR89	\$1,843.95			\$60,128.39
TOTAL	\$25,723.09	\$0.00	\$0.00	\$829,253.57
AVERAGE	\$2,143.59	\$0.00	\$0.00	\$69,104.46

NNMC ELECTRICAL COST COMPARISON OF ACTUAL 88-89 VERSUS NEW PEPCO RATES



NNMC ELECTRICAL COST COMPARISON OF ACTUAL 88-89 VERSUS NEW PEPCO RATES



ELECTRICAL COST COMPARISON FOR THE NATIONAL NAVAL MEDICAL CENTER




FIGURE 3: NNMC ELECTRIC UTILITY CHARGES
COMPARISON OF COST USING 1988-89 CONSUMPTION
AND ACTUAL AND PROJECTED RATE STRUCTURES

Attachment 4: Electric Usage Component Data Summary


ATTACHMENT 4: ELECTRIC USAGE COMPONENT DATA SUMMARY

The relationship of electrical demand and consumption to outdoor temperature was analyzed. The demand and on peak energy both increase as the average outdoor temperature increases. The relationship between the demand and consumption and the average outdoor temperature is directly proportional and nearly a straight line. Those months where the electrical demand or energy usage do not fall on this straight line are due to months when absorption chillers are used to meet cooling requirements and unusual process loads such as research equipment are used heavily.

A set of plots of monthly electrical demand and on-peak, off-peak, and intermediate billing period consumption levels were also produced. These plots again reveal that electrical demand and on-peak electrical consumption are strongly related to outdoor temperature, due to the fact that high cooling requirements occur during warmer periods.


The balance of material in this attachment are 15-minute kilowatt hour plots supplied by PEPCO for typical working and non-working days within each of four seasons. These plots reveal that baseline non-working day consumption levels are almost constant for the Wisconsin Ave. substation at about 7.5 megawatts (the values of kWh per 15 minute interval must be multiplied by 4 to derive kW demands) in the winter and increase to about 12 MW in the summer. On working days these baseload levels typically increase to approximately 10 and 16 megawatts respectively.

NNMC ELECTRIC DEMAND VERSUS AVERAGE TEMPERATURE EXCLUDING MARCH 1989







A LINEAR CURVE IS FIT TO THESE DATA
R-SQUARE IS .967, EQUATION FORM IS: $y = A + Bx$
WITH A=5991.5 AND B=120.112

MONTHLY NNMC ELECTRIC CONSUMPTION VERSUS AVERAGE OUTDOOR TEMPERATURE



A LINEAR CURVE IS FIT TO THESE DATA
R-SQUARE IS .928, EQUATION FORM IS: $y = A + Bx$
WITH A=109866.77 AND B=2132.91



MULT = 2.5338

PLOT OF KILOWATT HOURS VERSUS TIME - 15 MINUTE INTERVALS

2730147002 4-202 NAVAL MEDICAL CTR FROM 880330 TO 880428

PLOT FOR DATE 880409

52700229
Apr. 19, 1988

KWH

3611.25
3539.03
3466.81
3394.59
3322.37
3250.15
3177.93
3105.71
3033.49
2961.27
2889.05
2816.83
2744.61
2672.39
2600.17
2527.95
2455.73
2383.51
2311.29
2239.07
2166.85
2094.63
2022.41
1950.19
1877.97
1805.75
1733.53
1661.31
1589.09
1516.87
1444.65
1372.43
1300.21
1227.99
1155.77
1083.55
1011.33
939.11
866.89
794.67
722.45
650.23
578.01
505.79
433.57
361.35
289.13
216.91
144.69
72.47
0.25

4.5

HOUR ENDS

...1...2...3...4...5...6...7...8...9...10...11...12...1...2...3...4...5...6...7...8...9...10...11...12


PLOT OF KILOWATT HOURS VERSUS TIME - 15 MINUTE INTERVALS

2730147002 4-202 NAVAL MEDICAL CTR FROM 880330 TO 880428

PLOT FOR DATE 880408

Friday
April 8, 1988


KWH



PLOT OF KILOWATT HOURS VERSUS TIME - 15 MINUTE INTERVALS

2730147002 4-202 HAVAL MEDICAL CTR FROM 880728 TO 880826 PLOT FOR DATE 880731

Sunday
July 31,
1987



PLOT OF KILOWATT HOURS VERSUS TIME - 15 MINUTE INTERVALS


2730147002 4-202 NAVAL MEDICAL CTR FROM 880728 TO 880826

PLOT FOR DATE 880801

Mon day
August 1,
1988


KWH

4875.00
4777.50
4680.00
4582.50
4485.00
4387.50
4290.00
4192.50
4095.00
3997.50
3900.00
3802.50
3705.00
3607.50
3510.00
3412.50
3315.00
3217.50
3120.00
3022.50
2925.00
2827.50
2730.00
2632.50
2535.00
2437.50
2340.00
2242.50
2145.00
2047.50
1950.00
1852.50
1755.00
1657.50
1560.00
1462.50
1365.00
1267.50
1170.00
1072.50
975.00
877.50
780.00
682.50
585.00
487.50
390.00
292.50
195.00
97.50
0.00



Sunday
October 30,
1988

PLOT FOR DATE 881030



4.9

1..2...3...4...5...6...7...8...9...10...11...12

PLOT OF KILOHATT HOURS VERSUS TIME - 15 MINUTE INTERVALS

2/30147002 4-202 NAVAL MEDICAL CTR FROM 881026 TO 881128

PLOT FOR DATE 881031

*11/01/88
Oct 31, 1988*

KWH


3490.00
3420.20
3350.40
3280.60
3210.80
3141.00
3071.20
3001.40
2931.60
2861.80
2792.00
2722.20
2652.40
2582.60
2512.80
2443.00
2373.20
2303.40
2233.60
2163.80
2094.00
2024.20
1954.40
1884.60
1814.80
1745.00
1675.20
1605.40
1535.60
1465.80
1396.00
1326.20
1256.40
1186.60
1116.80
1047.00
977.20
907.40
837.60
767.80
698.00
628.20
558.40
488.60
418.80
349.00
279.20
209.40
139.60
69.80
0.00

Summary
January 8, 1989

PLOT OF KILOWATT HOURS VERSUS TIME - 15 MINUTE INTERVALS

2730147002 4-202 NAVAL MEDICAL CTR FROM 881229 TO 890130 PLOT FOR DATE 890106

KNH



HOUR ENDS


Sund 11 Mon Day
January 9, 1989

PLOT OF KILOWATT HOURS VERSUS TIME - 15 MINUTE INTERVALS

2730147002 4-202 NAVAL MEDICAL CTR FROM 881229 TO 890130

PLOT FOR DATE 890109

KWH



Attachment 5: Steam and Chilled Water Production Data Summary

ATTACHMENT 5: STEAM AND CHILLED WATER PRODUCTION DATA SUMMARY

The central plant at NNMCC provides steam and chilled water to most of the buildings at the facility, including the USUHS complex. The central plant records for the period July 1988 through September 1990 were evaluated to estimate the electrical usage of the chillers, and to understand the sensitivity of the building heating and cooling loads to outside air temperature.

A plot of the steam and chilled water delivery for each month during this period reveals the strong seasonal dependence of these loads and the baseline energy use levels. Monthly steam production varies from a low of approximately 20 million pounds per month to a high in excess of 74 million pounds, with a peak production of approximately 2.6 million pounds per day. Monthly chilled water production varies from a base level of approximately 13 million kBtu to a high of over 50 million kBtu. When chilled water usage is high, steam usage is low. Similarly, when steam usage is high, the chilled water usage is low.

The relationship between steam and chilled water production and outdoor temperature was explored by obtaining weather data collected on-site by NNMCC staff and at Washington National Airport by the National Oceanographic and Atmospheric Administration. The monthly average temperature data were compared graphically with the historical average conditions. This analysis revealed that December of 1989 was significantly (11°F) colder than the average and the months following were significantly warmer. The plot also reveals that on-site temperature measurements during the months of January through April 1990 range from 4 to 6°F above the Washington National Airport measurements while temperatures in other months are within 2°F. This may be due to the placement of the NNMCC temperature sensor on the power plant wall adjacent to the power transformers. It is also possible that the wintertime temperatures at NNMCC are higher than at Washington National Airport due to the density of buildings and unique microclimate effects.

Plots of monthly chilled water and steam production versus the NOAA temperature data reveal the strong relationship of these loads to outdoor temperature. Chilled water usage begins to rise as soon as the outside temperature rises above 50 or 60°F. Steam usage decreases as the temperature

rises. The relationships are not exact and there is a significant amount of scatter, indicating that other factors influence consumption levels.

The electrical consumption of the chillers was estimated from the monthly ton-hours of chilled water production. This analysis revealed that the chillers consume from 40 MWh/day in the winter to a high of approximately 130 MWh/day in the summer. This quantity was subtracted from the PEPCO metered average daily electrical consumption to render an estimate of the other electrical loads. These loads are estimated to lie in the range of 160 to 180 MWh/day. The variation is in part due to the number of days in the utility billing period. Assumed values were used prior to June 1989.

Plots of monthly chilled water production and fuel oil consumption as a function of average outdoor air temperature were prepared and analyzed to develop statistical curve fits. The fuel oil consumption levels are directly related to the outdoor temperature, with more fuel oil being consumed in the colder months. The chilled water production follows the outdoor temperature increase directly, but increases even faster at higher temperatures. The reason for this is likely twofold: as outdoor temperatures increase the coefficient of performance (efficiency) of the chiller drops while cooling requirements increase *combined* with a change in efficiency as the balance point (the temperature at which cooling is required to maintain a set inside temperature) changes with the season and building loads.

NNMC CENTRAL PLANT RECORDS **MONTHLY STEAM AND CHILLED WATER PRODUCTION DATA**


MONTH	STEAM		PRODUCED TOTAL POUNDS	OIL CONSUMED GALLON	CHILLED		WATER TOTAL TON-HR	EQUIVALENT ELEC MMBTU		BRITISH THERMAL CHILL WATER MMBTU		STEAM MMBTU
	PK-DAY POUNDS				PK-DAY TON-HR							
7-88	792,540		21,264,000	158,687	164,148		4,325,093	30,185		51,901		20,605
8-88	765,776		35,066,400	261,690	152,529		3,890,201	29,052		46,682		33,979
9-88	764,388		28,608,756	213,498	131,277		2,380,163	26,841		28,562		27,722
10-88	1,609,509		41,618,964	310,589	66,876		1,706,595	22,195		20,479		40,329
11-88	1,958,400		44,705,934	333,626	65,884		1,306,084	24,081		15,673		43,320
12-88	2,172,600		52,076,014	388,627	44,190		1,190,020	21,725		14,280		50,462
1-89	2,660,976		63,493,015	473,828	40,185		1,217,352	21,631		14,608		61,525
2-89	2,662,812		58,515,360	436,682	54,490		1,033,656	20,806		12,404		56,701
3-89	2,100,384		57,867,915	431,850	65,610		1,453,353	20,857		17,440		56,074
4-89	1,995,732		40,694,685	303,692	64,860		1,690,939	21,598		20,291		39,433
5-89	1,262,556		34,622,676	246,074	97,755		2,303,968	25,877		27,648		33,549
6-89	1,136,433		21,291,460	158,891	155,534		3,404,722	28,993		40,857		20,631
7-89	829,260		18,806,250	137,072	176,295		3,899,106	33,646		46,789		18,223
8-89	1,315,000		19,799,016	154,318	154,879		3,567,346	28,205		42,808		19,185
9-89	1,294,380		20,478,540	154,322	110,108		2,962,095	29,150		35,545		19,844
10-89	1,656,072		34,719,473	249,780	59,365		2,012,494	23,162		24,150		33,643
11-89	1,853,136		46,412,499	335,836	51,817		1,618,974	25,804		19,428		44,974
12-89	2,374,560		74,238,507	558,604	50,493		1,389,222	22,834		16,671		71,937
1-90	2,569,941		56,185,782	404,214	45,796		1,570,357	26,347		18,844		54,444
2-90	2,660,184		48,442,452	355,150	45,796		1,250,977	22,917		15,012		46,941
3-90	2,591,259		51,007,701	362,013	93,627		1,842,927	22,009		22,115		49,426
4-90	1,714,824		41,351,310	302,497	92,137		2,019,191	24,951		24,230		40,069
5-90	1,490,322		29,515,332	223,263	118,496		2,447,093	24,476		29,365		28,600
6-90	873,936		21,311,064	165,716	142,048		3,165,195	26,763		37,982		20,650
7-90	897,192		19,569,924	148,934	152,880		4,180,162	31,898		50,162		18,963
8-90	1,061,208		28,115,892	224,389	162,680		4,093,324	27,578		49,120		27,244
9-90	918,612		21,096,864	160,432	150,554		2,709,796	26,666		32,518		20,443

**NNMC CLIMATE DATA
ACTUAL ON-SITE, NOAA, AND NORMALS**

MONTH	ONSITE TEMP DEGREE	NOAA TEMP DEGREE	DELTA TEMP DEGREE	NOAA NORMAL DEGREE	NOAA DELTA DEGREE	NOAA DEW POINT	NOAA SUN MINUTES
7-88	81.7						
8-88	80.4						
9-88	67.5						
10-88	53.7						
11-88	49.0						
12-88	38.6						
1-89	39.9						
2-89	38.1						
3-89	46.1						
4-89	53.8						
5-89	62.6						
6-89	77.3						
7-89	78.4						
8-89	76.4						
9-89	61.8						
10-89	58.2	60.6	-2.4	59.4	1.2	50.5	12,303
11-89	46.2	48.0	-1.8	48.7	-0.7	35.3	9,846
12-89	27.4	27.9	-0.5	38.9	-11.0	16.8	6,878
1-90	49.5	43.6	5.9	35.2	8.4	31.9	6,828
2-90	51.2	45.2	6.0	37.5	7.7	32.2	8,260
3-90	58.0	50.2	7.8	45.8	4.4	36.2	11,478
4-90	61.9	56.8	5.1	56.7	0.1	43.3	12,633
5-90	68.2	64.3	3.9	66.0	-1.7	51.7	10,630
6-90	74.0	75.0	-1.0	74.5	0.5	62.3	16,388
7-90	79.7	79.4	0.3	78.9	0.5	67.9	13,849
8-90	73.9	76.5	-2.6	77.6	-1.1	66.3	11,099
9-90	67.1	69.6	-2.5	71.1	-1.5	58.6	12,353


NNMC CENTRAL PLANT ENERGY DELIVERY

MONTHLY STEAM AND CHILL WATER PRODUCED




MONTHLY AVERAGE TEMPERATURES FOR NNMC


ON-SITE, NOAA, AND NOAA AVERAGES



NNMC CHILL WATER USE VERSUS TEMPERATURE




NNMC STEAM PRODUCED VERSUS TEMPERATURE




NNMC ELECTRICAL USE SHARE ESTIMATES

CHILLERS AND OTHER DEVICES



ESTIMATED CHILLER ELECTRICITY VS TEMP


FOR NNMC CENTRAL PLANT CHILLERS



NNMC CENTRAL PLANT PRODUCTION DATA


MONTH	STEAM POUNDS	CHILLER TON-HRS	OIL USE GALLONS	AVG TEMP DEGREE F	MONTH
JAN88	68820403	903077	506095	33	JAN88
FEB88	60618951	978143	449344	39	FEB88
MAR88	51679510	1302720	384958	48	MAR88
APR88	44705934	1427323	335527	56	APR88
MAY88	30283758	2101071	236345	67	MAY88
JUN88	26973118	2936993	197427	75	JUN88
JUL88	21264000	4325093	153487	82	JUL88
AUG88	35066400	3890201	264874	80	AUG88
SEP88	28608756	2380163	223459	68	SEP88
OCT88	41618964	1706595	315306	54	OCT88
NOV88	45151718	1306084	326982	49	NOV88
DEC88	64361909	1190020	451676	39	DEC88
JAN89	63493015	1217352	444566	40	JAN89
FEB89	58515360	1033656	444131	38	FEB89
MAR89	57867915	1453353	428586	46	MAR89
APR89	40694685	1690939	301682	54	APR89
MAY89	34622676	2303968	246064	63	MAY89
JUN89	21291460	3404722	158042	77	JUN89

MONTHLY NNMC FUEL OIL CONSUMPTION VERSUS AVERAGE OUTDOOR TEMPERATURE EXCLUDING AUGUST 1988



A LINEAR CURVE IS FIT TO THESE DATA
R-SQUARE IS .966, EQUATION FORM IS: $y = A + Bx$
WITH $A=731326$ AND $B=-7358.69$

MONTHLY NNMC CHILLER PRODUCTION VERSUS AVERAGE OUTDOOR TEMPERATURE



5.10

AN EXPONENTIAL CURVE IS FIT TO THESE DATA
R-SQUARE IS .961, EQUATION FORM IS: $y = Ae^{Bx}$
WITH A=331420.00 AND B=.02981

Attachment 6: Electrical Measurements for Selected Buildings

ATTACHMENT 6: ELECTRICAL MEASUREMENTS FOR SELECTED BUILDINGS

The electrical consumption profiles of selected buildings were developed from hourly time series measurement of the building service entrances for periods ranging from 2 to 9 days. There were some problems getting the equipment installed and operating properly, but these were resolved for all but one of the assigned buildings.


This attachment provides a set of tables and figures for each of the buildings. Note that Buildings 3 and 4 provide power collectively to Buildings 1-8. The line plot for each building indicates the average daily electrical consumption profile for weekdays and weekends. The area plot displays the time series data upon which these averages are based.

Three tables are provided on a single page for each building with sufficient data. The top table indicates the average weekday hourly values for electric power, power factor, KVAR, average voltage, and amperage for each electrical phase. The next table provides the same information for average weekends. The bottom table indicates the average loads for each of the days the building was monitored. If p.m. or a.m. is indicated only a partial day of data predominating during that period was acquired.

For Building 55 only partial data are available due to a problem with the configuration of the instrumentation at that site. Apparently the power meter was configured to only record values when power levels exceeded 70% of the peak. Consequently we do not know the minimum power levels for this building.


NNMC Building 3 Electrical Load

AVERAGE DAILY PROFILES



NNMC Building 3 Electrical Load

TIME SERIES




NNMC BUILDING 3 ELECTRICAL LOAD					AVERAGE WEEKDAY PROFILE		
TIME	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	43.17	0.87	24.78	123.08	158.18	113.13	132.69
2	43.49	0.87	24.96	122.81	159.27	115.96	132.58
3	43.06	0.87	24.66	122.61	161.91	120.18	135.88
4	43.15	0.87	24.6	122.33	158.75	114.9	131.14
5	43.9	0.87	24.44	122.58	163.49	123.12	137.7
6	52.5	0.9	25.15	122.58	177.87	159.36	165.19
7	73.27	0.95	24.91	122.91	221.79	214.3	223.06
8	92.92	0.95	29.08	122.93	287.35	262.48	269.41
9	99.39	0.95	31.21	122.94	299.17	270.84	280.17
10	99.51	0.95	31.47	123.14	297.92	266.93	278.5
11	101.3	0.95	32.07	123.38	296.67	271.11	285.83
12	103.68	0.95	32.05	123.07	320.35	277.37	296.85
13	103.67	0.96	31.13	122.88	320.44	273.76	295.98
14	105.09	0.96	31.97	122.04	329.39	278.38	294.85
15	101.58	0.95	32.24	123.19	299.76	277.5	281.7
16	82.46	0.95	27.44	123.02	231.84	229.22	223.88
17	63.37	0.94	23.85	122.80	182.1	193.6	160.71
18	52.17	0.92	22.52	122.96	157.71	153.71	136.31
19	43.64	0.88	22.84	123.04	150.07	127.94	128.44
20	44.94	0.87	25.3	123.08	163.17	116.62	137.48
21	44.24	0.87	25.27	123.22	161.67	115.27	134.65
22	43.33	0.87	24.91	122.78	157.48	111.93	135.46
23	42.97	0.87	24.66	122.96	158.41	112.6	133.77
24	43.61	0.87	25.09	122.99	158.88	115.66	134.33

NNMC BUILDING 3 ELECTRICAL LOAD					AVERAGE WEEKEND PROFILE		
TIME	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	39.66	0.87	22.87	122.64	143.21	109.34	120.95
2	39.81	0.87	22.83	122.75	141.07	109.6	119.36
3	39.71	0.86	23.16	122.94	144.27	111.64	120.81
4	39.93	0.87	22.89	123.00	141.79	110.12	120.84
5	40.07	0.87	22.98	123.07	146.54	111.64	123.37
6	40.55	0.87	23.09	122.57	144.86	115.72	120.4
7	37.9	0.89	19.65	122.53	130.7	123.14	100.95
8	38.5	0.89	19.57	122.57	131.8	125.65	93.03
9	40.85	0.9	19.77	122.77	139.94	129.04	98.28
10	41.45	0.9	19.77	123.03	146.99	125.81	98.89
11	42.44	0.91	19.78	123.20	149.89	130.57	99.96
12	44.56	0.91	20.44	122.62	156.45	146.47	102.05
13	44.32	0.91	20.5	122.78	155.72	135.06	96.57
14	43.79	0.91	20.41	123.13	155.49	140.67	99.31
15	44.45	0.91	20.53	122.94	147.42	138.34	102.48
16	42.26	0.9	20.09	122.88	135.49	141.51	105.77
17	39.84	0.89	19.74	123.17	127.11	129.55	96.04
18	40.15	0.89	20.24	123.29	131.01	132.81	93.29
19	39.09	0.89	20.29	122.89	131.51	133.65	96.91
20	43.93	0.88	24.15	123.17	150.06	132.76	123.47
21	43.08	0.87	23.82	123.34	150.32	130.45	123.11
22	42.03	0.87	23.36	122.83	151.55	125.56	121.04
23	41.29	0.87	23.24	123.15	148.56	122.14	120.64
24	40.04	0.86	23.36	122.97	149.02	112.31	123.97


NNMC BUILDING 3 ELECTRICAL LOAD					AVERAGE DAILY LOADS		
DAY	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
MONDAY PM	64.04	0.87	26.93	122.77	204.7	177.58	177.73
TUESDAY	67.59	0.9	27.82	122.90	222.91	181.04	199.28
WEDNESDAY	64.54	0.91	26.87	122.96	205.48	176.93	186.12
THURSDAY	67.78	0.91	27.08	122.99	220.09	182.3	195.38
FRIDAY	67.55	0.91	26.19	123.04	211.4	189.25	199.97
SATURDAY	40.57	0.88	21.55	123.11	144.37	119.78	109.78
SUNDAY	41.91	0.89	21.49	122.74	143.2	132.19	108.68
MONDAY AM	57.39	0.9	24.43	122.61	192.21	168.04	163.16

NNMC BUILDING 4 ELECTRICAL LOAD

AVERAGE WEEKDAY PROFILE




NNMC BUILDING 4 ELECTRICAL LOAD



TIME	NNMC BUILDING 4 ELECTRICAL LOAD				AVERAGE WEEKDAY PROFILE		
	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1.00	57.61	0.72	54.71	282.09	87.15	96.31	100.14
2.00	58.42	0.73	55.07	282.48	86.80	95.38	98.05
3.00	57.64	0.73	53.94	281.81	86.55	94.34	95.91
4.00	56.96	0.73	53.72	280.65	86.44	93.97	96.33
5.00	57.23	0.72	54.75	283.04	88.24	94.61	100.37
6.00	58.90	0.74	53.86	281.45	91.92	97.02	102.94
7.00	67.21	0.78	54.35	282.84	99.36	110.50	116.70
8.00	75.76	0.80	56.82	282.53	101.90	121.70	127.90
9.00	76.45	0.80	57.98	283.90	100.10	116.50	118.43
10.00	86.99	0.82	59.10	283.85	108.95	120.65	123.95
11.00	93.49	0.84	59.63	283.16	114.30	127.42	137.67
12.00	75.09	0.78	59.22	283.96	98.12	109.82	118.32
13.00	74.54	0.78	59.25	283.70	98.98	111.37	121.05
14.00	76.38	0.80	57.75	283.15	103.08	114.35	124.67
15.00	74.32	0.78	58.66	283.77	101.80	111.12	115.17
16.00	67.70	0.77	56.47	282.96	95.17	103.51	105.47
17.00	61.11	0.74	55.10	281.70	90.98	99.10	102.61
18.00	59.90	0.74	54.46	282.07	88.05	96.17	99.98
19.00	61.68	0.75	54.80	281.61	89.31	97.21	101.12
20.00	61.23	0.74	54.83	283.18	89.51	96.76	99.74
21.00	62.19	0.74	55.60	284.16	90.57	101.57	101.06
22.00	64.73	0.77	53.08	280.97	95.13	106.65	108.74
23.00	75.64	0.81	54.46	282.00	103.28	112.79	118.30
24.00	59.75	0.73	55.90	282.86	87.72	97.72	101.66


NNMC BUILDING 10 ELECTRIC LOADS

AVERAGE DAILY PROFILES



NNMC BUILDING 10 ELECTRIC LOADS

TIME SERIES




TIME	NNMC BUILDING 10 ELECTRIC LOADS				AVERAGE WEEKDAY PROFILE		
	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	339.08	0.82	240.10	281.64	661.34	656.73	158.06
2	337.60	0.81	241.23	281.34	665.24	656.18	158.30
3	334.73	0.81	238.78	281.27	649.73	645.76	163.61
4	335.29	0.81	239.61	281.77	659.20	647.58	160.77
5	341.02	0.81	242.85	282.14	681.88	662.82	154.31
6	369.11	0.83	249.07	281.76	741.37	725.39	153.79
7	393.00	0.88	218.01	280.63	615.29	750.47	214.37
8	320.39	0.99	52.97	281.28	462.13	635.77	238.29
9	308.72	0.99	43.99	281.52	474.07	547.71	246.46
10	312.44	0.99	44.52	281.62	492.68	544.71	246.07
11	315.22	0.99	44.92	280.88	483.30	545.86	241.74
12	329.80	0.99	46.99	280.71	541.58	614.94	236.01
13	334.18	0.99	51.14	281.22	545.53	619.15	235.36
14	346.45	0.98	58.12	281.09	588.86	649.90	239.07
15	379.68	0.92	152.08	281.52	683.64	723.71	236.26
16	436.28	0.85	272.10	282.22	814.73	808.35	210.64
17	416.05	0.85	261.65	281.90	800.10	774.64	162.84
18	396.86	0.85	249.12	281.06	772.23	746.63	151.02
19	387.73	0.84	248.44	281.41	750.84	722.51	153.48
20	385.01	0.84	246.67	281.61	750.88	726.46	150.69
21	380.20	0.84	246.14	281.31	743.05	725.72	152.04
22	374.21	0.84	245.58	281.49	727.32	712.88	150.93
23	355.71	0.83	240.82	281.68	685.75	678.73	153.79
24	343.23	0.82	240.90	281.72	664.45	660.59	157.01


TIME	NNMC BUILDING 10 ELECTRIC LOADS				AVERAGE WEEKDAY PROFILE		
	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	339.62	0.82	238.16	282.45	658.69	660.11	155.89
2	337.72	0.81	244.50	283.04	661.19	658.80	154.77
3	336.84	0.81	241.69	282.11	660.19	655.94	157.02
4	339.36	0.81	241.26	282.81	664.79	650.87	157.62
5	338.20	0.81	241.55	282.69	662.27	658.87	153.36
6	343.64	0.82	237.66	281.19	660.75	655.54	160.71
7	353.97	0.83	237.87	280.41	692.41	680.41	149.85
8	359.54	0.82	252.11	282.99	718.80	698.34	143.55
9	369.99	0.83	252.22	282.29	744.91	723.60	144.17
10	369.31	0.82	252.97	281.58	742.49	713.54	145.50
11	368.76	0.83	248.99	281.44	727.37	704.34	150.55
12	367.32	0.83	246.84	280.81	725.94	706.27	147.62
13	364.52	0.83	247.36	281.31	722.80	702.22	147.40
14	361.57	0.83	244.14	280.80	708.60	689.16	149.81
15	360.31	0.83	245.66	280.52	715.71	695.94	148.61
16	359.26	0.83	239.10	281.03	701.40	686.30	152.04
17	362.35	0.83	243.46	281.75	718.17	698.72	148.42
18	367.10	0.84	240.68	280.90	720.24	695.16	149.25
19	361.89	0.84	236.12	281.80	698.67	683.94	152.79
20	359.19	0.83	236.64	281.21	694.50	678.15	153.55
21	356.51	0.83	238.40	282.34	693.12	674.19	151.92
22	357.75	0.83	235.73	281.42	697.10	676.15	155.61
23	349.97	0.83	238.60	282.36	676.96	672.00	152.06
24	347.29	0.82	241.27	281.36	674.77	671.86	155.04

DAY	NNMC BUILDING 10 ELECTRIC LOADS				AVERAGE DAILY LOADS		
	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	378.49	0.87	210.92	281.37	710.56	719.31	172.25
2	358.71	0.88	185.18	281.87	666.13	671.96	192.79
3	354.04	0.88	180.98	281.40	639.02	668.25	190.03
4	355.71	0.88	182.64	281.22	648.47	679.12	187.84
5	360.21	0.88	183.43	281.35	656.44	674.68	188.83
6	353.64	0.83	241.90	281.56	698.68	675.18	154.44
7	357.36	0.83	243.34	281.82	696.47	690.69	148.65
8	345.83	0.85	209.18	281.55	633.96	667.68	175.89

AVERAGE DAILY PROFILES



TIME SERIES




TIME	NNMC BUILDING 12 ELECTRICAL LOAD				AVERAGE WEEKDAY PROFILE		
	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	39.94	0.89	20.65	123.15	117.64	113.81	138.14
2	39.01	0.88	20.52	123.10	113.46	109.93	136.79
3	38.25	0.88	20.64	123.03	111.29	108.63	132.18
4	37.24	0.88	20.52	122.78	110.52	104.03	135.95
4	37.75	0.88	20.75	123.11	110.20	106.29	131.08
6	45.10	0.91	20.76	122.75	129.79	130.19	152.25
7	64.45	0.95	21.68	122.59	186.55	196.55	198.22
8	75.03	0.95	23.98	123.20	212.24	215.18	210.01
9	75.39	0.95	24.60	123.21	213.54	217.59	222.04
10	78.24	0.95	24.63	123.08	213.82	220.42	226.51
11	81.05	0.95	25.76	122.65	227.29	238.57	231.72
12	82.07	0.95	26.32	123.00	232.19	240.96	246.16
13	77.48	0.95	25.44	122.69	213.21	216.46	227.44
14	78.56	0.95	25.97	122.85	218.38	224.37	234.20
15	84.82	0.95	28.40	122.98	233.57	233.63	253.70
16	69.01	0.94	24.86	123.05	181.78	197.69	204.60
17	56.07	0.92	23.86	123.24	148.73	160.90	177.27
18	55.69	0.92	24.11	123.08	153.51	153.04	182.37
19	53.47	0.91	23.42	123.12	149.34	149.44	176.03
20	50.22	0.91	22.40	122.93	143.00	141.62	168.58
21	53.73	0.92	22.46	123.21	150.53	155.03	173.84
22	51.63	0.91	23.03	122.91	142.24	152.40	169.52
23	49.33	0.91	21.82	122.94	133.79	146.92	161.93
24	41.42	0.89	21.48	123.07	116.50	119.41	139.37

TIME	NNMC BUILDING 12 ELECTRICAL LOAD				AVERAGE WEEKDAY PROFILE		
	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	40.94	0.89	20.69	123.16	118.76	115.52	138.02
2	40.36	0.89	20.26	122.76	115.52	114.76	132.77
3	39.71	0.89	20.07	122.59	114.68	112.34	135.66
4	39.47	0.89	20.36	122.67	118.02	108.82	137.39
4	39.38	0.89	20.44	122.73	112.66	112.37	140.69
6	43.64	0.89	21.74	122.98	123.46	114.85	150.70
7	38.04	0.88	20.39	122.86	110.03	103.68	138.66
8	42.37	0.89	21.51	122.79	122.15	120.29	149.62
9	45.96	0.90	22.11	122.59	145.91	119.98	156.72
10	46.48	0.90	22.58	122.84	135.57	129.20	148.65
11	48.42	0.91	21.99	123.11	115.96	154.67	166.49
12	50.53	0.91	23.36	122.95	124.10	156.34	167.54
13	53.11	0.91	23.82	123.28	138.49	156.32	169.25
14	52.43	0.91	24.28	123.33	130.36	146.72	164.22
15	51.57	0.91	23.03	123.11	148.31	149.64	170.70
16	55.29	0.91	24.80	123.31	150.64	176.67	187.49
17	51.52	0.91	23.50	123.60	136.20	153.17	175.80
18	47.82	0.90	22.84	123.39	131.11	133.41	153.65
19	46.68	0.89	23.42	123.30	139.06	137.29	144.64
20	51.06	0.91	22.84	122.87	143.20	146.87	166.21
21	51.18	0.91	23.24	123.60	147.02	152.66	167.89
22	49.65	0.90	23.44	123.60	140.19	142.65	154.20
23	48.66	0.90	22.59	123.39	135.32	134.37	154.47
24	41.72	0.89	20.79	123.31	122.62	119.59	143.14

DAY	NNMC BUILDING 12 ELECTRICAL LOAD				AVERAGE DAILY LOADS		
	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
WED PM	59.73	0.93	22.73	122.80	163.29	166.61	194.98
THURSDAY	57.17	0.93	22.00	122.73	157.71	164.25	177.69
FRIDAY	55.04	0.92	22.18	123.12	160.78	154.27	171.71
SATURDAY	44.45	0.90	21.43	123.32	121.93	127.49	151.49
SUNDAY	48.55	0.90	23.08	122.86	138.02	140.20	158.06
MONDAY	62.85	0.92	25.10	123.05	178.02	180.05	193.60
TUESDAY	60.94	0.92	24.05	122.98	166.60	178.23	191.68
WED AM	43.48	0.89	21.71	123.48	120.54	126.79	151.02


NNMC BUILDING 14 ELECTRICAL LOAD

AVERAGE DAILY PROFILES



NNMC BUILDING 14 ELECTRICAL LOAD

15-MINUTE TIME SERIES




NNMC BUILDING 14 ELECTRICAL				AVERAGE WEEKDAY PROFILE			
TIME	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	12.88	0.83	8.76	124.42	29.04	46.70	51.31
2	12.98	0.83	8.84	124.55	28.20	47.92	50.81
3	13.12	0.82	8.98	124.34	29.65	49.36	51.54
4	13.42	0.83	9.19	124.15	29.83	51.76	51.01
5	18.01	0.75	16.20	124.08	55.24	83.53	78.14
6	39.99	0.88	17.45	123.71	92.94	147.30	139.33
7	52.98	0.90	18.49	123.54	128.73	171.17	166.82
8	54.20	0.90	18.84	123.72	134.40	168.51	170.13
9	54.90	0.90	19.04	123.47	138.54	173.16	171.64
10	55.84	0.90	19.21	123.36	138.18	174.25	171.86
11	57.14	0.91	19.78	123.45	141.77	178.51	180.23
12	57.24	0.91	20.48	123.48	144.29	175.66	183.56
13	56.44	0.90	20.97	123.39	146.62	174.79	182.34
14	56.98	0.89	21.05	123.74	144.29	171.65	176.91
15	52.67	0.89	20.39	123.60	128.71	161.95	163.00
16	39.98	0.87	19.31	123.47	91.53	130.24	135.89
17	35.22	0.86	18.82	123.40	85.44	119.47	123.37
18	37.05	0.87	18.31	124.10	85.61	123.44	126.74
19	33.45	0.95	8.68	124.63	63.89	106.34	105.97
20	32.55	0.95	7.94	124.22	62.97	102.11	100.60
21	17.22	0.86	8.88	124.58	34.75	56.35	57.91
22	15.47	0.85	9.11	124.49	33.19	59.63	53.24
23	13.41	0.83	8.93	124.46	29.85	48.47	51.56
24	12.96	0.83	8.84	124.29	30.14	46.90	50.09


NNMC BUILDING 14 ELECTRICAL				AVERAGE WEEKEND PROFILE			
TIME	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
	13.02	0.83	8.67	124.44	32.51	46.71	47.70
2.00	13.43	0.82	9.21	124.46	32.44	51.48	47.17
	13.14	0.82	9.01	124.67	35.56	44.46	48.79
4.00	13.05	0.83	8.85	124.59	33.30	46.42	47.16
	12.90	0.83	8.50	124.46	31.98	46.41	49.36
6.00	13.33	0.82	9.15	124.21	32.97	54.54	48.97
	13.27	0.82	9.18	124.21	35.36	46.10	48.81
8.00	13.58	0.84	8.74	123.99	36.76	44.36	50.93
	13.31	0.85	8.12	124.42	33.54	42.07	50.98
10.00	14.69	0.86	8.55	124.46	38.11	47.27	54.14
	15.00	0.86	8.65	124.26	37.33	49.16	50.59
12.00	14.78	0.85	8.98	124.43	37.78	50.63	52.61
	14.37	0.84	8.97	124.46	35.04	49.17	50.79
14.00	14.78	0.84	9.41	124.30	34.82	54.89	49.85
	12.03	0.82	8.47	124.24	29.04	47.55	45.54
16.00	12.59	0.81	9.04	124.02	29.72	48.13	47.14
	13.16	0.82	9.14	124.30	29.20	52.04	45.70
18.00	13.29	0.81	9.45	124.53	31.88	51.38	48.07
	12.86	0.82	8.85	124.67	29.76	47.98	47.97
20.00	12.88	0.82	8.83	124.77	27.49	51.16	47.35
	12.76	0.83	8.70	124.48	28.60	48.95	47.05
22.00	12.99	0.82	9.03	124.75	31.67	49.69	48.11
	12.97	0.82	9.09	124.53	31.20	47.43	47.25
24.00	13.42	0.82	9.24	124.45	33.24	51.42	48.45

NNMC BUILDING 14 ELECTRICAL				DAILY AVERAGES			
DAY	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
THURSDAY	46.24	0.91	19.56	123.59	111.20	146.58	147.51
FRIDAY	38.38	0.88	17.85	123.71	93.72	125.99	125.95
SATURDAY	14.20	0.84	9.01	124.36	35.85	49.67	51.50
SUNDAY	12.61	0.82	8.81	124.48	29.93	47.78	46.05
MONDAY	16.68	0.70	18.52	124.38	55.26	73.02	74.23
TUESDAY	38.15	0.91	12.33	123.95	85.23	120.40	119.58
WEDNESDAY	38.63	0.91	12.55	123.92	89.02	120.46	124.34
THURSDAY	38.12	0.92	12.20	123.95	85.50	122.50	120.31
FRIDAY	40.61	0.91	12.91	123.87	96.02	124.49	131.90

AVERAGE DAILY PROFILES



TIME SERIES




NNMC BUILDING 50 ELECTRICAL LOADS					AVERAGE WEEKDAY LOADS		
TIME	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	30.25	0.83	20.62	123.23	71.14	113.15	117.15
2	30.46	0.83	21.00	123.16	74.38	115.89	114.54
3	29.75	0.82	20.59	123.06	68.35	113.59	113.05
4	30.80	0.83	20.57	122.88	76.73	111.56	114.09
5	32.26	0.85	20.32	123.13	72.57	120.85	122.27
6	35.99	0.88	19.80	122.92	74.50	117.83	133.17
7	28.56	0.84	18.74	123.09	65.15	102.19	110.87
8	29.36	0.84	19.00	123.39	69.34	104.85	109.94
9	28.38	0.85	17.93	123.40	67.84	97.16	108.72
10	29.56	0.85	18.56	123.33	73.20	111.55	108.61
11	33.25	0.86	19.44	123.15	82.53	115.68	118.12
12	34.77	0.86	20.12	123.34	81.35	124.17	117.07
13	32.47	0.86	19.64	123.00	76.89	116.13	111.86
14	31.55	0.85	19.48	123.21	73.07	109.33	112.51
15	37.94	0.86	22.48	123.29	95.38	150.12	129.27
16	46.52	0.88	24.56	123.19	119.65	170.70	137.21
17	46.71	0.88	25.03	123.23	121.36	170.25	144.06
18	51.13	0.89	25.78	123.13	131.84	186.62	152.85
19	51.57	0.89	25.76	123.00	130.64	183.20	162.02
20	49.81	0.89	25.11	123.02	125.27	174.72	154.65
21	49.91	0.89	24.98	123.21	118.96	178.03	162.52
22	46.44	0.89	24.40	122.89	99.99	162.84	154.12
23	39.65	0.87	22.11	123.07	95.35	137.10	131.64
24	33.68	0.84	21.95	123.20	76.67	127.27	121.74

NNMC BUILDING 50 ELECTRICAL LOADS					AVERAGE WEEKDAY LOADS		
TIME	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	34.26	0.86	20.63	123.10	79.56	122.91	119.50
2	31.21	0.84	19.71	122.76	74.14	120.48	116.86
3	30.39	0.84	19.71	122.78	65.59	107.66	117.97
4	28.86	0.83	19.11	122.63	63.24	106.82	112.60
5	28.87	0.83	19.11	123.12	66.76	105.26	113.62
6	32.02	0.85	19.57	123.02	75.83	118.26	120.34
7	31.74	0.84	20.16	122.91	67.82	125.30	119.19
8	36.82	0.87	21.16	122.85	89.17	148.00	122.86
9	38.63	0.88	21.21	122.52	99.48	147.05	121.25
10	46.11	0.89	23.40	123.04	116.42	172.04	124.32
11	47.24	0.89	23.46	123.02	123.33	170.84	130.56
12	44.92	0.88	24.08	123.12	114.05	172.21	141.36
13	46.11	0.88	24.84	123.42	112.63	168.42	138.14
14	46.03	0.88	24.62	123.08	110.34	172.42	146.52
15	48.96	0.87	27.01	123.14	122.94	184.70	147.47
16	49.65	0.87	27.43	123.37	140.47	185.27	148.35
17	52.26	0.87	28.78	123.50	144.60	189.19	150.31
18	50.12	0.86	29.23	123.33	136.79	191.14	157.71
19	54.92	0.88	29.45	123.11	149.17	209.00	163.72
20	54.22	0.88	28.81	122.78	134.11	185.49	168.34
21	54.65	0.88	29.06	123.56	149.00	187.97	164.45
22	45.74	0.86	26.92	123.46	113.37	155.90	154.41
23	42.49	0.85	26.03	123.28	108.93	155.67	136.15
24	35.08	0.85	21.28	123.45	84.00	122.63	127.72

NNMC BUILDING 50 ELECTRICAL LOADS					AVERAGE DAILY LOADS		
DAY	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
MONDAY PM	37.45	0.90	17.71	123.09	84.55	129.94	123.35
TUESDAY	32.48	0.89	16.64	123.00	69.35	114.14	115.97
WEDNESDAY	33.53	0.87	18.29	123.40	75.88	118.05	116.50
THURSDAY	39.54	0.86	22.75	123.36	96.18	141.42	132.77
FRIDAY	44.74	0.87	25.15	122.83	115.63	168.97	139.21
SATURDAY	41.90	0.85	25.62	123.12	103.97	157.22	138.73
SUNDAY	41.86	0.83	27.36	123.00	110.96	155.29	142.22
MONDAY AM	33.54	0.81	24.42	123.47	91.16	118.41	128.50


NNMC BUILDING 55B ELECTRICAL LOADS

AVERAGE DAILY PROFILES



NNMC BUILDING 55B ELECTRICAL LOADS

TIME SERIES



NNMC BUILDING 55B ELECTRICAL LOADS AVERAGE WEEKDAY PROFILE							
TIME	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	95.66	0.91	44.84	285.12	108.37	123.66	137.50
2	95.88	0.90	45.36	285.41	108.92	125.39	138.34
3	95.63	0.90	45.64	285.65	108.59	125.41	138.15
4	96.02	0.90	45.64	285.33	108.76	124.64	137.98
5	95.69	0.90	45.47	284.90	108.30	125.46	138.09
6	95.74	0.91	45.08	284.94	106.46	126.23	138.40
7	74.24	0.83	43.92	284.76	81.22	98.07	105.91
8	59.65	0.77	44.45	285.48	76.00	93.37	99.19
9	56.35	0.76	43.91	285.13	73.82	90.72	95.94
10	55.17	0.76	43.32	285.34	73.12	90.17	95.24
11	58.85	0.77	45.91	285.02	73.68	91.06	96.44
12	50.30	0.75	40.38	285.03	65.95	81.91	87.45
13	70.90	0.83	43.70	285.07	89.32	108.68	115.36
14	77.70	0.84	45.38	285.66	89.99	108.78	116.86
15	88.89	0.87	44.60	284.97	103.53	122.13	134.29
16	104.18	0.91	47.31	285.97	117.50	138.93	150.27
17	98.63	0.91	45.53	285.03	107.96	126.30	139.59
18	101.71	0.91	47.02	285.45	110.17	130.11	142.45
19	98.38	0.91	45.78	285.39	110.25	126.48	141.80
20	95.71	0.91	44.93	285.31	110.19	128.19	141.35
21	96.66	0.91	45.49	285.56	108.73	124.42	138.05
22	96.47	0.90	45.65	285.59	109.35	126.07	139.20
23	96.04	0.90	45.75	285.97	108.99	124.56	137.96
24	95.84	0.90	45.55	285.73	109.04	124.88	138.18

NNMC BUILDING 55B ELECTRICAL LOADS AVERAGE WEEKEND PROFILE							
TIME	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	99.37	0.90	49.18	286.70	113.67	130.89	142.91
2	100.10	0.90	49.54	285.72	114.45	131.52	144.20
3	99.07	0.90	48.67	285.79	113.89	131.91	143.51
4	99.90	0.90	49.44	286.21	115.11	131.89	144.25
5	99.70	0.90	48.97	286.12	112.75	128.19	142.41
6	102.38	0.90	49.15	285.36	112.52	131.76	143.60
7	67.62	0.79	48.25	285.62	85.82	102.24	109.68
8	50.34	0.73	47.44	285.67	68.37	81.74	88.97
9	50.57	0.73	47.80	285.63	69.49	82.70	89.51
10	52.48	0.74	47.78	285.58	80.54	95.34	102.00
11	54.41	0.74	49.07	285.91	75.40	89.04	95.90
12	50.63	0.73	47.66	285.58	68.62	82.83	89.59
13	49.82	0.73	46.12	284.46	68.69	82.49	88.99
14	65.59	0.79	47.00	285.69	85.16	99.29	109.48
15	85.48	0.85	47.94	285.82	101.03	118.40	129.94
16	102.79	0.90	48.51	285.36	122.51	143.54	151.72
17	100.76	0.90	49.11	285.79	111.55	129.52	143.11
18	97.92	0.90	47.06	285.52	111.30	129.14	142.60
19	100.65	0.90	48.70	286.04	112.12	131.46	144.32
20	98.41	0.90	48.35	285.63	111.81	129.36	142.30
21	99.22	0.90	48.05	285.54	114.45	131.90	143.11
22	99.49	0.90	47.47	284.96	113.47	129.57	142.56
23	99.21	0.90	48.05	285.47	113.69	130.96	142.20
24	99.93	0.90	49.43	285.67	114.02	130.16	142.99

NNMC BUILDING 55B ELECTRICAL LOADS AVERAGE DAILY LOADS							
DAY	KW	PF	KVAR	VOLTS	Amp-A	Amp-B	Amp-C
1	88.44	0.85	50.37	286.52	102.00	120.81	130.52
2	87.63	0.86	48.20	285.64	103.38	121.47	132.13
3	89.00	0.86	47.81	285.32	103.37	119.50	131.88
4	86.67	0.85	48.63	285.24	102.42	119.66	130.16
5	101.86	0.91	47.51	283.83	116.37	135.33	146.78
6	82.72	0.84	48.29	285.85	98.99	115.49	125.74
7	86.10	0.85	48.27	285.47	101.88	118.34	129.25
8	84.59	0.85	47.51	285.66	100.09	116.48	127.87
9	75.23	0.88	37.40	285.45	84.61	101.42	111.84
10	51.61	0.83	25.98	285.47	54.59	71.62	78.08

Attachment 7: Major Electrical Connected Loads for Selected Buildings

ATTACHMENT 7: MAJOR CONNECTED ELECTRICAL LOADS FOR SELECTED BUILDINGS

The capacities of major electrical equipment for the selected buildings were developed from construction documents and limited building surveys. The results of this analysis are indicated in a table disaggregating HVAC, lighting, and miscellaneous equipment into major categories. A total connected load for each of these end-uses and for the entire building is estimated as well. These data will be useful to disaggregate the individual building electrical loads for those buildings subjected to shared energy savings projects.

Note that for Buildings 1-10 (the largest users) lighting and HVAC loads are nearly equal and constitute approximately 90% of the connected load. These values do not include the many small and medium capacity electrical devices in the buildings such as desk lamps, medical equipment, and desktop computers.

ELECTRICAL CONSUMPTION ESTIMATES
ANNUAL MWH

BUILDING	1-8	9-10	12	14	50	54	55
AIR HANDLING UNITS	1464	182	0	77	3	34	86
RETURN FANS	644	934	0	0	0	31	67
EXHAUST FANS	103	816	83	3	5	17	155
SUPPLY FANS	129	1146	0	0	0	78	102
PUMPS	405	582	0	0	0	27	90
UNIT HEATERS	9	18	32	0	0	0	0
TOTAL HVAC	2753	3678	115	81	8	188	500
FLUORESCENT LIGHTS	1810	3197	122	79	62	175	50
INCANDESCENT LIGHTS	84	441	0	0	23	30	6
HALLIDE	42	454	0	0	0	0	0
MERCURY	196	57	0	0	0	0	283
SODIUM	0	0	0	0	0	261	24
OTHER LIGHTS	0	68	0	0	0	20	13
	0	0	0	0	0	0	0
TOTAL LIGHTING	2131	4217	122	79	85	486	376
ELEVATORS	472	267	0	0	0	88	88
KITCHEN EQUIPMENT	86	323	0	0	0	0	0
TOTAL MAJOR EQUIPMEN	558	591	0	0	0	88	88


END-USE LOAD ESTIMATES BY CATEGORY

BUILDING	1-8	9-10	12	14	50	54	55
PLUGS	4939	2125	234	25	232	193	309
LIGHTS	2131	4217	122	79	85	486	376
OTHER	540	591	0	0	0	88	88
HVAC	2696	3678	115	81	8	188	500
ESTIMATED TOTAL	10381	10611	471	184	325	955	1273

**MAJOR EQUIPMENT CONNECTED LOADS
ESTIMATED KW**

BUILDING	1-8	9-10	12	14	50	54	55	Total	Share
AIR HANDLING UNITS	310	39		17	1	7	19	392	15.2%
RETURN FANS	104	304				5	11	424	16.5%
EXHAUST FANS	22	179	19	1	1	4	34	260	10.1%
SUPPLY FANS	21	989				15	19	1044	40.5%
PUMPS	65	356				4	15	440	17.1%
UNIT HEATERS	2	4	7					14	0.5%
TOTAL HVAC	524	1872	27	17	2	36	98	2575	
FLUORESCENT LIGHTS	496	949	27	33	14	44	11	1574	71.8%
INCANDESCENT LIGHTS	29	159			6	11	2	207	9.4%
HALLIDE	15	163						178	8.1%
MERCURY	53	16				62	6	135	6.2%
SODIUM						6	4	67	3.1%
OTHER LIGHTS		20						30	1.4%
TOTAL LIGHTING	592	1307	27	33	20	123	90	2191	
ELEVATORS	416	244				80	80	820	77.2%
KITCHEN EQUIPMENT	50	192						242	22.8%
TOTAL MISC EQUIPMENT	466	436				80	80	1062	
GRAND TOTALS	1582	3614	53	50	22	238	268	5828	

MAJOR EQUIPMENT CONNECTED LOADS
END-USE ELECTRICAL LOAD ESTIMATES



Attachment 8: Field Notes

ATTACHMENT 8: FIELD NOTES

This attachment contains copies of the original field notes made by PNL staff members.



Pacific Northwest Laboratories

ENGINEERING WORKSHEET

Page 1 of 1

Prepared By:

Richman, Wahlstrom

Date:


8/2/91

Project:

NNMC

Title/Subject:

Electrical Service Diagram (Medical Holding Facility) NNMC



BUILDING TITLE:

MEDICAL HOLDING FACILITY

BUILDING NUMBER:

~~12~~ NNMC 12

CONTACT LISTING

DATE	NAME	PHONE

BUILDING ADDRESS

BLDG 12

BUILDING SITE DESCRIPTION

FRONT ENTRANCE FACES NORTH TOWARDS HOSPITAL (#10)
BACK TERRAIN SLOPES DOWN TOWARDS GAS PUMPS & PARKING

BUILDING USE SUMMARY

MEDICAL HOLD

BUILDING CONSTRUCTION SUMMARY

1940'S WOOD CONSTRUCTION W/ MASON PANELS ADDED, LIGHTING
UPGRADED, PORCH ONLY WINDOWS REPLACED

HVAC SYSTEM SUMMARY

2 PIPE FAN COIL AND CONVECTION UNITS

MAJOR ENERGY USING EQUIPMENT SUMMARY

LIGHTS, HVAC PUMPS

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

ELECTRIC METERED

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

LIGHT RETROFITS

8.4

PREPARED BY: E. RICHMAN DATE: _____ BUILDING NUMBER: 12

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

		ROOF
GLASS :	N = 768 #	10'
	S = 1004 #	2 nd
	E = 410 #	11'
	W = 420 #	1 st
		BASE 18'

VERTICAL ARROW:

SCALE:

8.6

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 12

5/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 12 This page covers: Before condition After ☒ Date: 7-11-89
 Building location: BETHESDA MD
 Project/program ID: _____ Prepared by: E. RICHMAN MD state zip code

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: GRAPH Total floor area: 52158 (ft²) Year of latest renovation: 1983

BECA Building Type Codes			
ASEM - Assembly Buildings	AUTO - Auto Sales and Service	GROC - Grocery Stores	RETL - Retail Stores
REST - Restaurants	SECN - Second Schools & Colleges	HOTL - Hotels/Motels	WARE - Warehouses
ELEM - Elementary Schools	NURS - Nursing Homes	HOSP - Hospitals	CLIN - Clinics
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	INDS - Conditioned Industrial	SHCN - Shopping Centers
			OTHR - Other
			CORR - Correction Centers

Floor area of latest additions: ALL (ft²) _____ (ft²) _____ (ft²) Number of stories: 3 INCL. BASEMENT
 Year completed: 1983 _____

Floor area and volume: Heated Cooled Unconditioned Stories above ground:

Above grade: 43375 / 43375 43375 / 43375 43375 / 43375 2 1/2
 Below grade: 8783 / 8783 8783 / 8783 _____
 Atrium: _____

Roof pitch: _____ (in./in.) Exposed roof area: 17566 (ft²) Roof insulated at: ceiling level ☒ roof level _____
 Average roof estimated U-value (Btu/h-ft²-F) .09 Ground-coupled floor area: 17566 (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) .14 Common walls: 0 (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

W/ PRECAST CONCR. PANELS
 Above grade walls: 1 Doors: 1
 Below grade walls: 3 Roof: 2
 Atrium walls: 1 Floor: 1, 2
 (If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: _____ (ft²)

Wall/glazing information

Primary glazing type: 80% of total glazing) Est. U-value _____ (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: 20% of total glazing) Est. U-value _____ (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	<u>1968</u>	<u>7980</u>	<u>1968</u>	<u>5320</u>
Glazing area (ft ²)	<u>480</u>	<u>1004</u>	<u>480</u>	<u>768</u>
Shading by overhangs (y or n)	<u>N</u>	<u>N</u>	<u>N</u>	<u>N</u>
Shading by fins (y or n)	<u>N</u>	<u>N</u>	<u>N</u>	<u>N</u>
Photos attached showing facade (y or n)				

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. _____ (%) Contr., as needed _____ (%) Owner/tenant 20 (%) Other _____ (%)
 Description of variances: _____

Building ID: NNMC 12 This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of floor area): _____ % leased/rented _____ % owner-occupied _____ % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	NNMC MED. HOLD	ALL		

Total floor area (ft^2): _____

Description of variances:

3. Building Zone Information (minimum zone size is 10% of tenant area)

HALL/BATH
SLEEPING
GARAGE
PUBLIC FAC.

Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling
1	111	17504	10'				
2	700	17088	11'				
3	603	4272	11'				
4	105/06	13294	11'				

Description of variances:

4. Zone Schedule and Occupancy

(use times from 00:00-23:59)

Day of week:		Mon	Tues	Wed	Thu	Fri	Sat	Sun	Hol
Tenant/Zone No.:	1	Hour open							
		Hour closed							
		Occupant-hrs							
Tenant/Zone No.:	2	Hour open							
		Hour closed							
		Occupant-hrs							
Tenant/Zone No.:	3	Hour open							
		Hour closed							
		Occupant-hrs							
Tenant/Zone No.:	4	Hour open							
		Hour closed							
		Occupant-hrs							
Tenant/Zone No.:		Hour open							
		Hour closed							
		Occupant-hrs							
Tenant/Zone No.:		Hour open							
		Hour closed							
		Occupant-hrs							

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC 12 This page covers: Before condition After Date:

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							

Description of variances and zones with variable occupancy:

SCHEDULE HOURS ARE ESTIMATED

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scndy (see codes)	Fuel Code
S1	TPFC/TPIU	3	TOP FLOOR				S/CH
S2	TPIU	3	GROUND FLOORS				S/CH
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)

Single supply duct types:
SZRH, PSZ, HP, HPWS, SZCI,
RHFS, VAVS, PUI, PVAVS,
CBVAV, VVT
Air mixing types: MZS, PMZS,
DGS
Terminal unit types: TPFC,
EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR,
FPH, HVSYS, UHT, UVT, WS

Controls Codes

h-heating, c-cooling, b-both
1-none (on/off manual),
2-timeclock, 3-thermostat,
4-smart thermostat, 5-EMCS

Pkg/Scndy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by
primary system (below)
p+s-packaged + secondary

Fuel Codes

e-electricity, g-natural gas,
o-distillate fuel oil (#1 or 2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from
outside the building, s-steam
from outside the building

Primary System Codes

BW-hot water boiler, BS-steam
boiler, F-furnace, CC-centrifugal
chiller, CA-absorption
chiller, CAR-air-cooled reciprocating
chiller, CWR-water-cooled
reciprocating chiller,
CAS-air-cooled screw chiller,
CWS-water-cooled screw
chiller, CT-cooling tower,
EC-evaporative condenser,
EV-evaporative cooler

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				S1 S2
CC/CA	E/BS				S1 S2

OFF
SITE

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
ALL	IF/IFH	80/FIX.	246 /	M	

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight
dimming, O-other

2/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 12 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: TOTAL ESTIMATED LIGHTING WATTS
INCAN. 7000
FLOUR. 28,160

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
HVAC PUMPS(2)		HVAC	E	5 hp EA

Type Codes for Other Energy Systems

FOD-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electric/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel- Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
PEPCO PEPCO	E		1 (#272)


7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr

Description of variances:

ENGINEERING WORKSHEET

Prepared By:	Richman, Wahlstrom	Date:	8/2/91	Project:	NNMC
Title/Subject: Electrical Service Diagram (Public Works office /shops, NNMC 14)					



BUILDING TITLE:

PUBLIC WORKS OFFICE/SHOPS

BUILDING NUMBER:

~~5~~ NNMC 14

CONTACT LISTING

DATE

NAME

PHONE

BUILDING ADDRESS

BLDG # 14

BUILDING SITE DESCRIPTION

FRONT FACES ~~BLDG # 14~~ SUBSTATION PAD
BETWEEN BUILDINGS 54 & 55 (WEST)
BACK SLOPES DOWN

BUILDING USE SUMMARY

TOP FLOOR - OFFICES & COMPUTER ROOM
BASEMENT - MAINT. SHOPS, STORAGE

BUILDING CONSTRUCTION SUMMARY

CONCRETE/BLOCK w/ DBL WINDOWS

HVAC SYSTEM SUMMARY

TWO PIPE FAN COIL & CONVECTION (TOP FLOOR)
~~W/~~ EXHAUST VENTILATION ONLY IN SHOPS

MAJOR ENERGY USING EQUIPMENT SUMMARY

SHOP EQUIP, COMPUTER

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE


NOT METERED

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW




TRUE NORTH ARROW:

SCALE: 1" = 10' x 10'
8.14

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC 1

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

$\frac{1}{2}$ SLATS ON GRADE
 $\frac{1}{2}$ " below "



VERTICAL ARROW:

SCALE:

8.15

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 14

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 14 This page covers: Before condition After ☒ Date: 7-10-89
 Building location: BETHESDA MD
 Project/program ID: _____ Prepared by: E. RICHMAN MD _____

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: LOFF Total floor area: 27558 (ft²) Year of latest renovation: 1978

BECA Building Type Codes			
ASEM - Assembly Buildings	AUTO - Auto Sales and Service	GRCS - Grocery Stores	RETL - Retail Stores
REST - Restaurants	SECN - Second, Schools & Colleges	HOTL - Hotels/Motels	WARE - Warehouses
ELEM - Elementary Schools	NURS - Nursing Homes	HOSP - Hospitals	CUN - Clinics
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (> 10,000 ft ²)	INDS - Conditioned Industrial	SHCN - Shopping Centers
			OTHR - Other
			CORA - Correction Centers

Floor area of latest additions: _____ (ft²) _____ (ft²) _____ (ft²) Number of stories: _____
 Year completed: _____

Floor area and volume: Heated Cooled Unconditioned VENT. ONLY Stories above ground: 1 1/2
 Above grade: 13779 / 179133 13779 / 179133 13779 / 137790
 Below grade: _____ / _____ / _____
 Atrium: _____ / _____ / _____
 Roof pitch: FLAT (in./in.) Exposed roof area: 13779 (ft²) Roof insulated at: ceiling level ☒ roof level _____
 Average roof estimated U-value (Btu/h-ft²-F) _____ Ground-coupled floor area: 13779 (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) 0.9 Common walls: _____ (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 2 Doors: 1
 Below grade walls: 3 Roof: 3
 Atrium walls: 1 Floor: 1/2

(If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-all doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: _____ (ft²)

Wall/glazing information

Primary glazing type: 88 (%) of total glazing Est. U-value _____ (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: 12 (%) of total glazing Est. U-value _____ (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

	Orientation			
	East	South	West	North
Above grade gross wall area (ft ²)	<u>585</u>	<u>952</u>	<u>2170</u>	<u>952</u>
Glazing area (ft ²)	<u>4340</u>	<u>147</u>	<u>355</u>	<u>183</u>
Shading by overhangs (y or n)	<u>N</u>	<u>N</u>	<u>N</u>	<u>N</u>
Shading by fins (y or n)	<u>N</u>	<u>N</u>	<u>N</u>	<u>N</u>
Photos attached showing facade (y or n)				

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100% Contr., cont. _____ (%) Contr., as needed _____ (%) Owner/tenant _____ (%) Other _____ (%)

Description of variances: _____

8.17

7/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC 14 This page covers: Before condition After Date:

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week:	Mon	Tues	Wed	Thu	Fri	Sat	Sun	Hol
Tenant/Zone No.: <u> </u>	Hour open									
	Hour closed									
	Occupant-hrs									
Tenant/Zone No.: <u> </u>	Hour open									
	Hour closed									
	Occupant-hrs									

Description of variances and zones with variable occupancy:

~~SCHEDULE~~ SCHEDULE HOURS ARE ESTIMATED

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scndy (see codes)	Fuel Code
S1	TPFC/APU	3	TOP FLR (1)				S/CH
S2							
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)

Single supply duct types:
SZAH, PSZ, HP, HPWS, SZCI,
RHFS, VAVS, PIU, PVAVS,
CBVAV, VWT
Air mixing types: MZS, PMZS,
DCS
Terminal unit types: TPFC,
EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, JR,
FPH, HVSYS, UHT, UVT, WS

Controls Codes

h-heating, c-cooling, b-both
1-none (on/off manual),
2-timer, 3-thermostat
4-smart thermostat, 5-EMCS

Pkg/Scndy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by pri-
mary system (below)
p+s-packaged + secondary

Fuel Codes

e-electricity, g-natural gas,
o-distillate fuel oil (#1 or 2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from
outside the building, s-steam
from outside the building

Primary System Codes

BW-hot water boiler, BS-steam
boiler, F-furnace, CC-centrifugal
chiller, CA-absorption
chiller, CAR-air-cooled recipro-
cating chiller, CWR-water-
cooled reciprocating chiller,
CAS-air-cooled screw chiller,
CWS-water-cooled screw
chiller, CT-cooling tower,
EC-evaporative condenser,
EV-evaporative cooler

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				S1
CC/CA	E/ES				S1

OFF SITE

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
1, 2, 3	IF/IFH		268	M	

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHD	EHD
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight
dimming, O-other

8/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: PNMC 14 This page covers: Before condition ___ After ___ Date: _____

5. Systems (cont'd)

Lighting (cont'd))

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: TOTAL ESTIMATED LIGHTING WATTS
FLOOR, 31,040

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connect kW
--------------	----------------------	--------------	--------------	---------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances: _____

Monthly Energy and Fuel

Energy Utility or Supplier	Fuel- Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	---------------	---	---------------------


7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances: _____

ENGINEERING WORKSHEET

Prepared By:	Richman, Wahlstrom	Date:	8/2/91	Project:	NNMC
Title/Subject: Electrical Service Diagram (BEQ. Barracks, NNMC 50)					



BUILDING TITLE:

BEQ.

BARRACKS

BUILDING NUMBER:

NNMC 50

CONTACT LISTING

DATE

NAME

PHONE

BUILDING ADDRESS

BLDG #50

BUILDING SITE DESCRIPTION

BUILDING USE SUMMARY

HOUSING

BUILDING CONSTRUCTION SUMMARY

CONCRETE BLOCK

HVAC SYSTEM SUMMARY

2 PIPE FAN COIL

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.21

PREPARED BY: E. RICHMANDATE: 7-11-84BUILDING NUMBER: ~~50~~ 50

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE


ELEC METERED

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW



SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

⁵ 12	⁴ 12	³ 24	S = 576 ϕ
		¹	N = 672 ϕ
		²	E = ϕ
		⁷	W = ϕ

PART 1 45' X 119'

L = 28
S = 20
-21

		⁵	S = ϕ
	¹²	¹	N = 252 ϕ
⁸ 18	⁴ 18	⁴	E = 864 ϕ
	²⁶	⁶	W = 1008 ϕ

PART 2 45' X 178'

VERTICAL ARROW:

SCALE:

8.24

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 50

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 50 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: city Prepared by: E. RICHMAN state zip code

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: GRPH Total floor area: 44,260 (ft²) Year of latest renovation:

ASEM - Assembly Buildings REST - Restaurants ELEM - Elementary Schools SOFF - Small Office Building ($\leq 10,000$ ft ²)	AUTO - Auto Sales and Service SECN - Second, Schools & Colleges NURS - Nursing Homes LOFF - Large Office Building ($\geq 10,000$ ft ²)	BECA Building Type Codes GROC - Grocery Stores HOTL - Hotels/Motels HOSP - Hospitals INDS - Conditioned Industrial	RETL - Retail Stores WARE - Warehouses CLIN - Clinics	SHCN - Shopping Centers OTHR - Other CORR - Correction Centers
---	---	--	---	--

GRPH - GROUP HOUSING

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:

Above grade: 41,020 / 41,020 41,020 / 41,020 /
 Below grade: / / 3240 / 32400

Atrium: / / /

Roof pitch: (in./in.) Exposed roof area: 41,020 (ft²) Roof insulated at: ceiling level ☒ roof level

Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: (ft²)

Average estimated opaque wall U-value (Btu/h-ft²-F) .09 Common walls: (%)

Describe variances in roof, walls, and floor below.

Building shell construction codes

BASE
MECH
ROOM
Above grade walls: 2 Doors: 1
Below grade walls: 3 Roof:
Atrium walls: 1 Floor:

(If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: Single (% of total glazing) Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: Single (% of total glazing) Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	<u>6940</u>	<u>4920</u>	<u>6940</u>	<u>4920</u>
Glazing area (ft ²)	<u>864</u>	<u>572</u>	<u>1008</u>	<u>924</u>

Shading by overhangs (y or n) Y

Shading by fins (y or n) Y

Photos attached showing facade (y or n)

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 50 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant 50 (%) Other (%)

Description of variances:

6/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 2

Building ID: NNMC #50 This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of floor area): % leased/rented % owner-occupied % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	NNMC QUARTERS	ALL		

Total floor area (ft²):

Description of variances:

3. Building Zone Information (minimum zone size is 10% of tenant area)

Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling
Corridor	1	10350	60'				
Rooms	2	30670	10'				
Mech	3	3240	10'				

Description of variances:

4. Zone Schedule and Occupancy

(use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.:	1	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	2	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	3	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:		Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:		Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:		Hour open						
		Hour closed						
		Occupant-hrs						

7/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC 50 This page covers: Before condition ___ After ___ Date: _____

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week:	Mon	Tues	Wed	Thu	Fri	Sat	Sun	Hol
Tenant/Zone No.: _____	Hour open									
	Hour closed									
	Occupant-hrs									
Tenant/Zone No.: _____	Hour open									
	Hour closed									
	Occupant-hrs									

Description of variances and zones with variable occupancy: SCHEDULE HOURS ARE ESTIMATED

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scondy (see codes)	Fuel Code
S1	TPFC	3	1&2 1&2				5/44
S2							
S3							
S4							
S5							
S6							

HVAC Type Codes (see p.5)

Single supply duct types: SZRH, PSZ, HP, HPWS, SZCI, RHFS, VAVS, PIU, PVAVS, CBVAV, VWT
Air mixing types: MZS, PMZS, DCS
Terminal unit types: TPFC, EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR, FPH, HVSYS, UHT, UVT, WS

Controls Codes

h-heating, c-cooling, b-both
1-none (on/off manual),
2-timeclock, 3-thermostat,
4-smart thermostat, 5-EMCS

Pkg/Scondy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by primary system (below)
p+s-packaged + secondary

Fuel Codes

e-electricity, g-natural gas,
o-distillate fuel oil (#1 or 2),
o-other fuel oil, c-coal,
w-wood, ch-chilled water from outside the building,
s-steam from outside the building

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				5/
CC/CA	e/MS				5/

Primary System Codes

BW-hot water boiler, BS-steam boiler, F-furnace, CC-centrifugal chiller, CA-absorption chiller, CAR-air-cooled reciprocating chiller, CWR-water-cooled reciprocating chiller, CAS-air-cooled screw chiller, CWS-water-cooled screw chiller, CT-cooling tower, EC-evaporative condenser, EV-evaporative cooler

Description of variances: _____

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
1,2	IF, II		140	M	
3	II		282	M	

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

2 - PIPE
FAN
COIL

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 50 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: TOTAL ESTIMATED LIGHTING WATTS
INCAN. 12,700
FLOUR. 3,200

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electric/electronic equipment (including video games); SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPB-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel


Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
<u>PEPCO</u>	<u>E</u>		<u>1 (#244)</u>

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr

Description of variances:

Prepared By: Richman, Wahlstrom Date: 8/2/91 Project: NNMC
 Title/Subject: Electrical Service Diagram (Parking Structure, NNMC 54)



BUILDING TITLE:

PARKING STRUCTURE

BUILDING NUMBER:

NNMC 54

CONTACT LISTING

DATE	NAME	PHONE

BUILDING ADDRESS

BUILDING SITE DESCRIPTION

BUILDING USE SUMMARY

PARKING + STORAGE & SHOP

BUILDING CONSTRUCTION SUMMARY

CONCRETE

HVAC SYSTEM SUMMARY

SINGLE ZONE W/REHEAT IN SOME ZONES

MAJOR ENERGY USING EQUIPMENT SUMMARY

HVAC, ELEVATORS

8.30

PREPARED BY: E. RICHMANDATE: 7-14-89 BUILDING NUMBER: 54

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

NONE

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

LIGHTING CONTROL


SITE DESCRIPTION - PLAN VIEW

BASEMENT FLOOR - WAREHOUSE / SHOP 367' X 122' 44,774 ϕ
 MEZZ. - OFFICE 54' X 196' 10,584 ϕ
 2 PARKING - 367' X 122'
 1 PARKING - 367' X 122'
 4 PARKING - "
 5 PARKING - "

IN PARKING :
 323 ~~250~~ - 1.75W MERC. VAP. ??
 24 - 2 BULB 4' FL.
 20 - 1 BULB 4' FL.

IN BASEMENT FLOOR
 26 - 500W QUARTZ
 15 - 400W HPS
 66 - 250W HPS
 186 - 2 BULB 4' FL
 14 - 4 BULB 4' FL
 30 - 150W INC.
 10 - 50W INC.

IN MEZZ
 160 4 BULB 4' FL
 5 2 BULB 4' FL
 36 150W INC.
 29 100W MERC. VAP. EXTERIOR
 3 150W INC.




TRUE NORTH ARROW:

SCALE:

8.32

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE



VERTICAL ARROW:

SCALE:

8.33

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 54

5/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 54 This page covers: Before condition After Date:
Building location: BETHESDA MD
Project/program ID: Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
(circle one)
BECA building type code: WARE Total floor area: 55,358 (ft²) Year of latest renovation: 234454

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	RETL - Retail Stores	SHCN - Shopping Centers
REST - Restaurants	SECN - Second. Schools & Colleges	GROC - Grocery Stores	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes	HOTL - Hotels/Motels	CJN - Clinics	CORR - Correction Centers
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	HOSP - Hospitals		
		INDS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:

Above grade: 55,358 / 1,001,320 55,358 / 1,001,320 179,096 / 1,790,960 4
Below grade: 55,358 / 1,001,320 55,358 / 1,001,320 /

Atrium: / / /

Roof pitch: FLAT (in./in.) Exposed roof area: 44,774 (ft²) Roof insulated at: ceiling level roof level

Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: 44,774 (ft²)

Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)

Describe variances in roof, walls, and floor below.

ROOF OVER OPEN AIR GARAGE

Building shell construction codes

Above grade walls: 3 Doors: 1
Below grade walls: 3 Roof: 1
Atrium walls: Floor: 2

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

(If code '0' is used, describe below.)

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: (%) of total glazing

Est. U-value (Btu/h-ft²-F)

(circle those that apply) Single Double? Triple

Clear Tinted Reflective Other Fixed Operable

Secondary glazing: (%) of total glazing

Est. U-value (Btu/h-ft²-F)

(circle those that apply) Single Double Triple

Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Glazing area (ft ²)	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Shading by overhangs (y or n)	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Shading by fins (y or n)	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Photos attached showing facade (y or n)	<u> </u>	<u> </u>	<u> </u>	<u> </u>

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)

Description of variances:

Building ID: NNMC 54 This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of floor area): _____ % leased/rented _____ % owner-occupied _____ % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	NNMC PARKING/SHOP	ALL		

Total floor area (m^2): _____

Description of variances:-

3. Building Zone Information (minimum zone size is 10% of tenant area)

	Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
					heating	cooling	heating	cooling
PARKING, WAREHOUSE OFFICE	1	603	179,096	10'				
	2	202	44,774	20'				
	3	300	10,584	10'				

Description of variances: CELLING HEIGHTS ESTIMATED

4. Zone Schedule and Occupancy

(use times from 00:00-23:59)

		Day of week:							
		Mon	Tues	Wed	Thu	Fri	Sat	Sun	Hol
Tenant/Zone No.:	<u>1</u>								
	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.:	<u>2</u>								
	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.:	<u>3</u>								
	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.:	<u>1</u>								
	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.:									
	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.:									
	Hour open								
	Hour closed								
	Occupant-hrs								

7/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC 54 This page covers: Before condition After Date:

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week: Mon	Tues	Wed	Thu	Fri	Sat	Sun	Hol
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								

Description of variances and zones with variable occupancy:

SCHEDULE HOURS ESTIMATED

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scndy (see codes)	Fuel Code
S1	SZRH	2/3/4	WARR/MSE2				CH/S
S2							
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)

Single supply duct types:
SZRH, PSZ, HP, HPWS, SZCI,
RHFS, VAVS, PIU, PVAVS,
CBVAV, VWT
Air mixing types: MZS, PMZS,
DGS
Terminal unit types: TPFC,
EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR,
FPH, HVSYS, UNT, UVT, WS

Controls Codes

h-heating, c-cooling, b-both
1-none (on/off manual),
2-timed clock, 3-thermostat
4-smart thermostat, 5-EMCS

Pkg/Scndy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by pri-
mary system (below)
p+s-packaged + secondary

Fuel Codes

e-electricity, g-natural gas,
o-distillate fuel oil (#1 or 2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from
outside the building, s-steam
from outside the building

Primary System Codes

BW-hot water boiler, BS-steam
boiler, F-furnace, CC-centrifugal
chiller, CA-absorption
chiller, CAA-air-cooled recipro-
cating chiller, CWA-water-
cooled reciprocating chiller,
CAS-air-cooled screw chiller,
CWS-water-cooled screw
chiller, CT-cooling tower,
EC-evaporative condenser,
EV-evaporative cooler

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				S1
CC/CA	E/S				S1

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
	HERC				
	QUANT				
	HRS				
	EXT	EO 400		P?	
3/2/1	IF/1HID		918	M/P?	

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight
dimming, O-other

40% of
HALL LOCATED
photo
control?

8/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 54 This page covers: Before condition ___ After ___ Date: _____

5. Systems (cont'd)

Lighting (cont'd))

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: TOTAL LIGHTING WATTS (ESTIMATED)
INCAN, 10,850
FLOUR, 43,120
HID, 95,025

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
ELAV.				

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances: _____

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr

Description of variances: _____



Pacific Northwest Laboratories

ENGINEERING WORKSHEET

Page 1 of 1

Prepared By:

Richman, Wahlstrom

Date:


8/2/91

Project:

NNMC

Title/Subject:

Electrical Service Diagram (Parking, NNMC 55)



BUILDING TITLE:

PARKING

BUILDING NUMBER:

NNMC 55

CONTACT LISTING

DATE	NAME	PHONE

BUILDING ADDRESS

BLOCK # 55

BUILDING SITE DESCRIPTION

~~PARKING WITH DAYCARE & FEW OFFICES~~

BUILDING USE SUMMARY

PARKING WITH DAYCARE & FEW OFFICES

BUILDING CONSTRUCTION SUMMARY

CONCRETE

HVAC SYSTEM SUMMARY

SINGLE ZONE W/SOME REHEAT

MAJOR ENERGY USING EQUIPMENT SUMMARY

HVAC, ELEVATORS

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

~~TEST~~ METERS NOT CURRENTLY READ
(# 436 & 174)

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

LIGHTING CONTROLS

SITE DESCRIPTION - PLAN VIEW

TOTAL LEVELS OF PAVEMENT & STAIRS, ETC.
 DAYCARE ONE LEVEL "5" 100 #
 164475

PARKING: 280 175 w. MECH. VAP.
 ELEC/MECH: 14 400 w. HPS
 42 100 w. INC.
 8 2 TUBE 4' FL

LAUND: 3P 2 TUBE 4' FL
 DRY CARE: 18 4 TUBE 4' FL
 PUBS: WKS 6 4 TUBE 4' FL
 7 2 TUBE 4' FL

143' SQUARE 15' & 16' SECTIONS (17' & 18' ONLY)

422'


TRUE NORTH ARROW:

SCALE: ☐ = 20' x 20'

8.41

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC 5

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE



VERTICAL ARROW:

SCALE:

8.42

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 55

5/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 55 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: any Prepared by: E. RICHMAN state ZIP code

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: WARE Total floor area: (ft²) Year of latest renovation:

ASSEMB - Assembly Buildings REST - Restaurants ELEM - Elementary Schools SOFF - Small Office Building ($\leq 10,000$ ft ²)	AUTO - Auto Sales and Service SECN - Second, Schools & Colleges NURS - Nursing Homes LOFF - Large Office Building ($\geq 10,000$ ft ²)	BECA Building Type Codes GROC - Grocery Stores HOTL - Hotels/Motels HOSP - Hospitals INDS - Conditioned Industrial	RETL - Retail Stores WARE - Warehouses CLIN - Clinics	SHOP - Shopping Centers OTHR - Other CORR - Correction Centers
---	---	--	---	--

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories: 8
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
 Above grade: m²m³ m²m³ m²m³
 Below grade:
 Atrium:
 Roof pitch: FLAT (in./in.) Exposed roof area: 51062 (ft²) Roof insulated at: ceiling level roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 3 Doors: 1
 Below grade walls: 3 Roof: 1
 Atrium walls: Floor: 2/1

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

(If code '0' is used, describe below.)

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: (% of total glazing) Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: (% of total glazing) Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)				
Glazing area (ft ²)				
Shading by overhangs (y or n)				
Shading by fins (y or n)				
Photos attached showing facade (y or n)				

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

6/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 2

Building ID: NNMC 55 This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of floor area): % leased/rented % owner-occupied % other

Tenant No.	Tenant Name	Area (ft²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
<u>0</u>	<u>COMMON</u>			
<u>1</u>	<u>PARKING</u>			
<u>2</u>	<u>DAYCARE</u>			

Total floor area (ft²):

Description of variances:

3. Building Zone Information (minimum zone size is 10% of tenant area)

Tenant/Zone No.	Use Code	Zonal Area (ft²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling
<u>PARKING 1/1</u>	<u>603</u>	<u>408,396</u>	<u>10'</u>				
<u>DAYCARE 2/1</u>	<u>900</u>	<u>100+</u>	<u>10'</u>				

Description of variances: ESTIMATED VALUES

4. Zone Schedule and Occupancy

(use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.: <u>1/1</u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u>2/1</u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							

7/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC 55 This page covers: Before condition After Date:

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							

Description of variances and zones with variable occupancy:

SCHEDULE ESTIMATED

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scondy (see codes)	Fuel Code
S1	SERH	2/3	DAYCARE				S/CH
S2							
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)

Single supply duct types: SZRH, PSZ, HP, HPWS, SZCI, RHFS, VAVS, PIU, PAVS, CBVAV, VVT
Air mixing types: MZS, PMZS, DCS
Terminal unit types: TPFC, EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR, FPH, HVSYS, UHT, UVT, WS

Controls Codes

h-heating, c-cooling, b-both
1-none (on/off manual),
2-timed clock, 3-thermostat
4-smart thermostat, 5-EMCS

Pkg/Scondy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by primary system (below)
p+s-packaged + secondary

Fuel Codes

e-electricity, g-natural gas,
o-distillate fuel oil (#1 or 2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from outside the building, s-steam from outside the building

Primary System Codes

BW-hot water boiler, BS-steam boiler, F-fumace, CC-centrifugal chiller, CA-absorption chiller, CAR-air-cooled reciprocating chiller, CWR-water-cooled reciprocating chiller, CAS-air-cooled screw chiller, CWS-water-cooled screw chiller, CT-cooling tower, EC-evaporative condenser, EV-evaporative cooler

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				S1
CLCA	E/S				S1

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
1	I/HID		294		
2	IF/11		488		

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	I1	E1
Neon	IN	EN
HID	I/HID	E/HID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

8/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 55 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd))

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHI	EHI
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: TOTAL LIGHTING WATTS ESTIMATED
INCAND. 4200
FLOOR. 8080
HID- 54,600

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for food generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

PEPCO

E

2 (#436,13)

7. Energy Improvements Being Evaluated

CURRENTLY NOT
READ OR RECORDED
BY NNMC

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances:

BUILDING TITLE:

CENTRAL STEAM / CHILLER PLANT

BUILDING NUMBER:

NNMC 16

CONTACT LISTING

DATE	NAME	PHONE
	JOHN HOWARD	
	BILL	

BUILDING ADDRESS

BLDG # 16

BUILDING SITE DESCRIPTION

SLOPING TOWARDS STONEY CREEK

BUILDING USE SUMMARY

STEAM & CHILLED WATER PRODUCTION

BUILDING CONSTRUCTION SUMMARY

CONCRETE

HVAC SYSTEM SUMMARY

FEW UNIT HEATERS
TPFC IN OFFICE AREA

MAJOR ENERGY USING EQUIPMENT SUMMARY

CHILLERS

8.47

PREPARED BY: E. RICHMANDATE: 7-14-89 BUILDING NUMBER: NNMC 16

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

ELECTRIC NOT METERED

6 STEAM & 4 CHILLED WATER RECORDERS EXIST
BUT THEIR ACCURACY IS IN QUESTION


QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

NO BUILDING ENVELOPE CONS. OPPORTUNITIES
APPEAR PRACTICAL

SITE DESCRIPTION - PLAN VIEW




TRUE NORTH ARROW:

SCALE:

8.49

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NUMC 16

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE



VERTICAL ARROW:

SCALE:

8.50

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 16

5/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 16 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: OTHR Total floor area: (ft²) Year of latest renovation:

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	GROC - Grocery Stores	RETL - Retail Stores	SHCN - Shopping Centers
REST - Restaurants	SECN - Second Schools & Colleges		MOTL - Motels/Motels	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes		HOSP - Hospitals	CLIN - Clinics	CORR - Correction Centers
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)		INDS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
 Above grade: (ft²) (ft²) (ft²)
 Below grade: (ft²) (ft²) (ft²)
 Atrium: (ft²) (ft²) (ft²)
 Roof pitch: (in./in.) Exposed roof area: (ft²) Roof insulated at: ceiling level roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 3 Doors: 1
 Below grade walls: 3 Roof: 1
 Atrium walls: Floor: 2

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

(If code '0' is used, describe below.)

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Glazing area (ft ²)	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Shading by overhangs (y or n)	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Shading by fins (y or n)	<u> </u>	<u> </u>	<u> </u>	<u> </u>
Photos attached showing facade (y or n)	<u> </u>	<u> </u>	<u> </u>	<u> </u>

Floor plan sketch(es) attached (y or n)

Maintenance: In-house (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

6/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 2

Building ID: NNMC 16 This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of floor area): % leased/rented % owner-occupied % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
<u>0</u>	<u>COMMON</u>			

Total floor area (ft²):

Description of variances:

3. Building Zone Information (minimum zone size is 10% of tenant area)

Tenant/Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling

Description of variances:

4. Zone Schedule and Occupancy

(use times from 00:00–23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol							
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								

24 HOUR OPERATION

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

7/8

Building ID: NNMC-16 This page covers: Before condition ___ After ___ Date: ___

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol							
Tenant/Zone No.: _____	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: _____	Hour open								
	Hour closed								
	Occupant-hrs								

Description of variances and zones with variable occupancy:

MAJORITY OF LIGHTING IS HID & FLOUR.

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

OFFICE ONLY

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scondy (see codes)	Fuel Code
S1	UHT/TPC						5/CH
S2							
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)

Single supply duct types:
SZRH, PSZ, HP, HPWS, SZCI,
RHFS, VAVS, PUI, PVAVS,
CBVAV, VWT
Air mixing types: MZS, PMZS,
DDS
Terminal unit types: TPFC,
EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR,
FPH, HVSYS, UHT, LVT, WS

Controls Codes

h-heating, c-cooling, b-both
1-none (on/off manual),
2-timedlock, 3-thermostat
4-smart thermostat, 5-EMCS

Pkg/Scondy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by pri-
mary system (below)
p+s-packaged + secondary

Fuel Codes

e-electricity, g-natural gas,
o-distillate fuel oil (#1 or 2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from
outside the building, s-steam
from outside the building

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above

Primary System Codes

BW-hot water boiler, BS-steam
boiler, F-furnace, CC-centrifugal
chiller, CA-absorption
chiller, CAR-air-cooled recipro-
cating chiller, CWR-water-
cooled reciprocating chiller,
CAS-air-cooled screw chiller,
CWS-water-cooled screw
chiller, CT-cooling tower,
EC-evaporative condenser,
EV-evaporative cooler

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
------------------	---------------	-------------	--------------------------------	---------------	------------------------

HID & FLOUR

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight
dimming, O-other

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 16 This page covers: Before condition ___ After ___ Date: _____

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: _____

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances: _____

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
<u>NNMC</u>	<u>S</u>		<u>6</u>
<u>NNMC</u>	<u>CH</u>		<u>4</u>

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

_____/____ to ____/
 _____/____ to ____/
 _____/____ to ____/
 _____/____ to ____/

Description of variances: _____

BUILDING TITLE:

UNIFORMED UNIVERSITY "A"

BUILDING NUMBER:

NNMC 70

CONTACT LISTING

DATE

NAME

PHONE

	JERRY HOOPINGARDNER	

BUILDING ADDRESS

BLDG # 70 ("A")

BUILDING SITE DESCRIPTION

EAST OF MAIN HOSPITAL AREA

BUILDING USE SUMMARY

MEDICAL UNIVERSITY FOR UNIFORMED PERSONNEL
INCLUDES REGULAR CLASSROOM AND LAB FACILITIES

BUILDING CONSTRUCTION SUMMARY

CONCRETE / MASONRY OVER UNDERGROUND PARKING
AREA

HVAC SYSTEM SUMMARY

SINGLE ZONE w/ SOME REHEAT

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.55

PREPARED BY: E. RICHMAN

DATE: 7-14-89 BUILDING NUMBER: NNMC 70

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

ok

QUALITY AND SOURCE OF MEASURED ENERGY USE


network w/ # 71, 72, 73

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW




TRUE NORTH ARROW:

SCALE: = 20' x 20'

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 70

SITE DESCRIPTION - PLAN VIEW




TRUE NORTH ARROW:

SCALE: = 20' x 20'

8.58

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 70

SITE DESCRIPTION - PLAN VIEW




TRUE NORTH ARROW:

SCALE:

8.59

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 70

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE



VERTICAL ARROW:

SCALE:

8.60

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 70

7/10

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 70 This page covers: Before condition After Date:
 Building location: UNIT BETHESDA MD
 Project/program ID: city state ZIP code
 Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: SECN Total floor area: 241848 (ft²) Year of latest renovation:

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	RETL - Retail Stores	SMCN - Shopping Centers
REST - Restaurants	SECN - Second, Schools & Colleges	GROC - Grocery Stores	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes	HOTL - Hotels/Motels	CUN - Clinics	CORR - Correction Centers
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	HOSP - Hospitals		
		INDS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:

Above grade: 241848 (ft²) 241848 (ft²) (ft²) 4
 Below grade: (ft²) (ft²) (ft²)
 Atrium: (ft²) (ft²) (ft²)

Roof pitch: FLAT (in./in.) Exposed roof area: 56204 (ft²) Roof insulated at: ceiling level roof level

Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: 56204 (ft²)

Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)

Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 3 Doors: 1
 Below grade walls: 3 Roof: 1
 Atrium walls: Floor: 1

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

(If code '0' is used, describe below.)

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 00 (% of total glazing)

Est. U-value (Btu/h-ft²-F)

Single Double Triple

Clear Tinted Reflective Other Fixed Operable

Secondary glazing: (% of total glazing)

Est. U-value (Btu/h-ft²-F)

Single Double Triple

Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North	
Above grade gross wall area (ft ²)	21890	8442	21890	8442	
Glazing area (ft ²)	2420	2000	1470	2070	
Shading by overhangs (y or n)	Y	Y	Y	Y	INSET
Shading by fins (y or n)	Y	Y	Y	Y	INSET
Photos attached showing facade (y or n)	N	N	N	N	

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)

Description of variances:

MAINTAINED BY OWN CREWS
SEPARATE FROM REST OF NNMC

8/10

2. Tenant Information

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	UH UHS	ALL		

Description of variances: _____

Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling
1	111	45,000	VAR.				
2	110	10,128	VAR.				
3	202	10,062	18'				
4	502	27,350	18'				
5	300	62,264	VAR.				
6	103/502	80,224	15'				
7	505	8660	18'				

(use times from 00:00-23:59)

8.62

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

Description of variances and zones with variable occupancy:

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

HVAC Type Codes (see p 5)

Single supply duct types:
SZRM, PSZ, HP, HPWS, SZQ,
RMFS, VAVS, PIU, PVAVS,
CBVAV, WT
Air mixing types: MZS, PMZS,
DCS
Terminal unit types: TPFC,
EPFC, TPIU, FPIU, PTAC, WHF
Heating only types: EBB, IR,
FPH, HVSYS, UNT, UWT, WS

Controls Coders

h-heating, c-cooling, b-both,
1-none (or/off manual),
2-timer/clock, 3-thermostat
4-smart thermostat, 5-EMCS

Practical Sendv Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by primary system (below)
p+s-packaged + secondary

Fuel Codes

s-electricity, g-natural gas,
o-distillate fuel oil (#1 or 2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from
outside the building, s-steam
from outside the building

Primary System Codes

BW-hot water boiler, BS-steam boiler, F-furnace, CC-centrifugal chiller, CA-absorption chiller, CWR-air-cooled recirculating chiller, CWS-water-cooled reciprocating chiller, CAS-air-cooled screw chiller, CWS-water-cooled screw chiller, CT-cooling tower, EC-evaporative condenser, EV-evaporative cooler

Primary HVAC Systems Serving Secondary Units

Description of variances: _____

Lighting

Lighting Coder

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	I	EI
Neon	IN	EN
HID	IHI	EHI
Other	X	EO

Control Codes

M-manual, T-timer, P-photocell/daylight
dimming, O-other

8.63

10/10

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 70 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photos/daylight dimming, O-other

Description of variances: ESTIMATE TOTAL LIGHTING WATTS
FLOOR = 390,000
IFH LIGHTING WAS TRIED BUT NOT WITH FAVORABLE RESULTS PER
OCCUPANTS

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTP-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances:

BUILDING TITLE:

UNIFORMED UNIVERSITY "B"

BUILDING NUMBER:

NNMC 71

CONTACT LISTING

DATE	NAME	PHONE

BUILDING ADDRESS

BLDG # 71

BUILDING SITE DESCRIPTION

SEE # 70

BUILDING USE SUMMARY

LABS AVAIL. 24 HOUR

BUILDING CONSTRUCTION SUMMARY

SEE # 70

HVAC SYSTEM SUMMARY

SEE # 70

MAJOR ENERGY USING EQUIPMENT SUMMARY

LARGE COMPUTER USE

8.65

PREPARED BY: E. RICHMANDATE: 7-14-89 BUILDING NUMBER: 71

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE


METERED WITH BLDG # 70, 72, 73

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW



TRUE NORTH ARROW:




SCALE: $\square = 20' \times 20'$

8.67

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC 71

PLAN

SITE DESCRIPTION - ~~ELEVATION~~ FOR _____ ~~FACING FACADE~~



NORTH
~~VERTICAL~~ ARROW: ↑

SCALE: □ = 20' × 20'

8.68

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NMCC 7

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

GLASS :		4th	15'
S =	4550 #	3rd	15'
N =	3190 #	2nd	19'
W =	300 #	1st	19'
E =	980 #		

VERTICAL ARROW:

SCALE:

8.69

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 71

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

6/9

Building ID: ANMC 71 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: city Prepared by: E. RICHMAN state zip code

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: SECN Total floor area: 153,386 (ft²) Year of latest renovation:

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	GROC - Grocery Stores	RETL - Retail Stores	SHCN - Shopping Centers
REST - Restaurants	SECN - Second, Schools & Colleges		HOTL - Hotels/Motels	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes		HOSP - Hospitals	CUN - Clinics	CORR - Correction Centers
SOPF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)		INDS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
 Above grade: 153,386 / 2,563,710 153,386 / 2,563,710 / 4
 Below grade: / / /
 Atrium: / / /
 Roof pitch: FLAT (in./in.) Exposed roof area: 43,828 (ft²) Roof insulated at: ceiling level ☒ roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 2/3 Doors: 1
 Below grade walls: Roof: 1
 Atrium walls: Floor: 1/2
 (If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 100 (% of total glazing) Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: (% of total glazing) Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

	East	South	West	North	
Above grade gross wall area (ft ²)	10,764	23,626	10,764	23,626	
Glazing area (ft ²)	980	4550	300	3190	
Shading by overhangs (y or n)	Y	Y	Y	Y	INSET
Shading by fins (y or n)	Y	Y	Y	Y	INSET
Photos attached showing facade (y or n)	N				

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

8/9

Building ID: NNMC 71 This page covers: Before condition After Date:

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							

Description of variances and zones with variable occupancy: ALL AREAS MAY BE AVAILABLE 24 HOURS
SCHEDULE HOURS ARE ESTIMATED

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scondy (see codes)	Fuel Code
<u>S1</u>	<u>SZRH</u>	<u>4</u>	<u>ALL</u>				<u>S/CH</u>
<u>S2</u>							
<u>S3</u>							
<u>S4</u>							
<u>S5</u>							
<u>S6</u>							

HVAC Type Codes (see p 5)
Single supply duct types: SZRH, PSZ, HP, HPWS, SZCH, RHFS, VAVS, PIU, PAVS, CBVAV, VVT
Air mixing types: MZS, PMZS, DCS
Terminal unit types: TPFC, EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR, FPH, HVSYS, UHT, UVT, WS

Controls Codes
h-heating, c-cooling, b-both
1-none (on/off manual),
2-timed clock, 3-thermostat
4-smart thermostat, 5-EMCS

Pkg/Scondy Codes
p-packaged unit (unitary eqpt.)
s-secondary unit served by primary system (below)
p+s-packaged + secondary

Fuel Codes
e-electricity, g-natural gas, o-distillate fuel oil (#1 or 2), oh-other fuel oil, c-coal, w-wood, ch-chilled water from outside the building, s-steam from outside the building

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
<u>B5</u>	<u>DL</u>				<u>S1</u>
<u>CC/CA</u>	<u>E/S</u>				<u>S1</u>

Primary System Codes
BW-hot water boiler, BS-steam boiler, F-furnace, CO-centrifugal chiller, CA-absorption chiller, CAR-air-cooled reciprocating chiller, CWR-water-cooled reciprocating chiller, CWS-water-cooled screw chiller, CT-cooling tower, EC-evaporative condenser, EV-evaporative coils

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
<u>ALL</u>	<u>IF</u>		<u>≈ 2045</u>		

Lighting Codes
Type Interior Exterior
Standard fluorescent IF EF
High-eff. fluorescent IFH EFH
Incandescent II EI
Neon IN EN
HID IHID EHID
Other IO EO

Control Codes
M-manual, T-timer, P-photocell/daylight dimming, O-other

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

9/9

Building ID: NNMC 71 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: ESTIMATED TOTAL LIGHTING WATTS

FLOOR. = 275,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOC-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances:

COMMERCIAL BUILDING CHARACTERISTICS SURVEY FORM

Page 1 of 8

BUILDING TITLE:

UNIFORMED UNIVERSITY "C"

BUILDING NUMBER:

NNMC 72

CONTACT LISTING

DATE

NAME

PHONE

BUILDING ADDRESS

SEE 70

BUILDING SITE DESCRIPTION

SEE 70

BUILDING USE SUMMARY

SEE 70

BUILDING CONSTRUCTION SUMMARY

SEE 70

HVAC SYSTEM SUMMARY

SEE 70

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.74

PREPARED BY: E. RICHMANDATE: 7-14-89 BUILDING NUMBER: NNMC

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

57

QUALITY AND SOURCE OF MEASURED ENERGY USE

METERED WITH BLDG# 70, 71, 73

DATE: 10/10/2019 TIME: 10:11 AM

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

NR


SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

This image shows a single sheet of white paper with horizontal ruling lines. The lines are evenly spaced and run across the width of the page. There is no handwriting or other markings on the paper.

8.75

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NPMC 72

SITE DESCRIPTION - PLAN VIEW



TRUE NORTH ARROW:



SCALE: $\square = 20' \times 20'$

8.77

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC 72

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

5/8

Building ID: NNMC 72 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: city state zip code
 Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 (circle one)
 BECA building type code: SECN Total floor area: 70,520 (ft²) Year of latest renovation:

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	GROC - Grocery Stores	RETL - Retail Stores	SHCN - Shopping Centers
REST - Restaurants	SECN - Second Schools & Colleges		MOTL - Motors/Motels	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes		HOSP - Hospitals	CJUN - Clinics	CORR - Correction Centers
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)		INGS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
 Above grade: 70520 / 1339800 70520 / 1339800
 Below grade:
 Atrium:
 Roof pitch: FLAT (in./in.) Exposed roof area: 53840 (ft²) Roof insulated at: ceiling level X roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: 53840 (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 2 Doors: 1
 Below grade walls: Roof: 1
 Atrium walls: Floor: 1/2

(If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 100 (% of total glazing)
 (circle those that apply) Single Double Triple
 Secondary glazing: (% of total glazing)
 (circle those that apply) Single Double Triple

Est. U-value (Btu/h-ft²-F)
 Clear Tinted Reflective Other Fixed Operable
 Est. U-value (Btu/h-ft²-F)
 Clear Tinted Reflective Other Fixed Operable

	East	South	West	North	
Above grade gross wall area (ft ²)	10,070	8056	10,070	8056	
Glazing area (ft ²)	2100	600	1000	1300	
Shading by overhangs (y or n)	Y				INSET
Shading by fins (y or n)	Y				INSET
Photos attached showing facade (y or n)					

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

MAINTAINED BY OWN UNIVERSITY CREWS

6/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 2

Building ID: NNMC 72 This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of total area): % leased/rented % owner-occupied % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	USUHS	ALL		

Total floor area (ft²):

Description of variances:

3. Building Zone Information (minimum zone size is 10% of tenant area)

~~24340~~ 24340 / 26390

Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling
1	502	24340					
2	300	24058					
3	105	7200					
4	111	6170					
5	900	6420					

LAB
OFFICE
LOBBY
CORR./STAIR
BOOKSTORE

Description of variances:

4. Zone Schedule and Occupancy

(use times from 00:00–23:59)

		Day of week:	Mon	Tues	Wed	Thu	Fri	Sat	Sun	Hol
Tenant/Zone No.: <u>1</u>	Hour open		7							
	Hour closed		5							
	Occupant-hrs		10							
Tenant/Zone No.: <u>2</u>	Hour open		7							
	Hour closed		3							
	Occupant-hrs									
Tenant/Zone No.: <u>3</u>	Hour open									
	Hour closed									
	Occupant-hrs									
Tenant/Zone No.: <u>4</u>	Hour open									
	Hour closed									
	Occupant-hrs									
Tenant/Zone No.: <u>5</u>	Hour open		7							
	Hour closed									
	Occupant-hrs									
Tenant/Zone No.: <u> </u>	Hour open									
	Hour closed									
	Occupant-hrs									

Manual, Timer, P-photocell/daynight dimming, Other

8/8

EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 4

Building ID: NNMC 72 This page covers: Before condition ___ After ___ Date: _____

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: ESTIMATED TOTAL LIGHTING WATTS

FLOOR = 212,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electric/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances: _____

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

_____/ ____ to ____
 _____/ ____ to ____
 _____/ ____ to ____
 _____/ ____ to ____

Description of variances: _____

BUILDING TITLE:

UNIFORMED UNIVERSITY "D"

BUILDING NUMBER:

NNMC 73

CONTACT LISTING

DATE

NAME

PHONE

BUILDING ADDRESS

see 70

BUILDING SITE DESCRIPTION

see 70

BUILDING USE SUMMARY

see 70

BUILDING CONSTRUCTION SUMMARY

see 70

HVAC SYSTEM SUMMARY

see 70

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.82

PREPARED BY: E. RICHMANDATE: 7-14-89 BUILDING NUMBER: 73

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

METERED WITH BLDG # 70, 71, 72


QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

8.83

SITE DESCRIPTION - PLAN VIEW



SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

GLASS :

N = 1750 ϕ
S = 1650 ϕ
E = ϕ
W = 280 ϕ

Same elev.
as 71 "B"

VERTICAL ARROW:

SCALE:

8.85

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 73

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 73 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 city state ZIP code
 Project/program ID: Prepared by:

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: SECN Total floor area: 46,675 (ft²) Year of latest renovation:

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	RETL - Retail Stores	SHCN - Shopping Centers
REST - Restaurants	SECN - Second, Schools & Colleges	GRCC - Grocery Stores	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes	HOTL - Hotels/Motels	CUN - Clinics	CORR - Correction Centers
SOFF - Small Office Building ($\leq 10,000$ ft ²)	LOFF - Large Office Building ($\geq 10,000$ ft ²)	HOSP - Hospitals		
		INDS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:

Above grade: 46,675 (ft²) 830,425 (ft³) 46,675 (ft²) 830,425 (ft³) (ft²) (ft³)
 Below grade:
 Atrium:

Roof pitch: 4/12 (in./in.) Exposed roof area: 19,800 (ft²) Roof insulated at: ceiling level X roof level

Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: 14,575 (ft²)

Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)

Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 2 Doors: 1
 Below grade walls: 1 Roof: 1
 Atrium walls: Floor: 1/2

(If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 00 (% of total glazing)

(circle those that apply) Single Double Triple

Secondary glazing: (% of total glazing)

(circle those that apply) Single Double Triple

Est. U-value (Btu/h-ft²-F)

Clear Tinted Reflective Other Fixed Operable

Est. U-value (Btu/h-ft²-F)

Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	6280	9990	6280	9990
Glazing area (ft ²)	0	1650	280	1750

Shading by overhangs (y or n) Y Y Y Y IN SET

Shading by fins (y or n) Y Y Y Y IN SET

Photos attached showing facade (y or n)

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 00 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)

Description of variances:

MAINTAINED BY OWN UNIVERSITY CREWS

6/8

8.87

$7/8$

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

Tenant/Zone No.: _____	Hour open								
.....	Hour closed --								
	Occupant-hrs								
Tenant/Zone No.: _____	Hour open								
.....	Hour closed								
	Occupant-hrs								

SCHEDULE HOURS - ESTIMATED

HVAC Type Codes (see p 5)

Single supply dual types: SZRH, PSZ, HP, HPWS, SZCI, RHFS, VAVS, PIU, PVAVS, CBVAV, WT
Air mixing types: MZS, PMZS, DOS
Terminal unit types: TPFC, EPFC, TPIU, FPIU, PTAC, WHF
Heating only types: EBB, IR, FPH, HVSYS, UHT, UWT, WS

Controls Coding

h-heating, c-cooling, b-both
1-none (on/off manual),
2-timer/clock, 3-thermostat
4-smart thermostat, 5-EMCS

Proq/Sandy Coders

p-packaged unit (unitary eqpt.)
s-secondary unit served by primary system (below)
p+s-packaged + secondary

Fuel Coder

e-electricity, g-natural gas,
o-distillate fuel oil (1 or 2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from
outside the building, s-steam
from outside the building

Primary System Codes

BW-hot water boiler, BS-steam boiler, F-furnace, CC-continuous chiller, CA-absorption chiller, CAR-air-cooled reciprocating chiller, CWR-water-cooled reciprocating chiller, CAS-air-cooled screw chiller, CWS-water-cooled screw chiller, CT-cooling tower, EC-evaporative condenser, EV-evaporative cooler

Description of variances: _____

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	I	EI
Neon	IN	EN
HID	IHI	EHI
Other	O	EO

Control Codes

M=manual, T=timer, P=photocell/daylight dimming, O=other

~~1111~~

ALL IFH ≈ 622

8.88

8/P

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 73 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: ESTIMATED TOTAL LIGHTING WATTS

FLOOR, 84,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances:

BUILDING TITLE:

HOSPITAL/CLINIC

BUILDING NUMBER:

NNMC 9

CONTACT LISTING

DATE

NAME

PHONE

BUILDING ADDRESS

BLDG #9

BUILDING SITE DESCRIPTION

SOUTH OF ORIGINAL HOSPITAL BLDG (#1)

BUILDING USE SUMMARY

DOCTORS' OFFICES, EXAM ROOMS, LABS, OPERATING ROOMS, ETC..

BUILDING CONSTRUCTION SUMMARY

HVAC SYSTEM SUMMARY

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.90

PREPARED BY: E. RICHMANDATE: 7-14-89 BUILDING NUMBER: NNMC

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE


netted with BLDG # 10

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW



TRUE NORTH ARROW:




SCALE:

8.92

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC

SITE DESCRIPTION - PLAN VIEW



TRUE NORTH ARROW:

SCALE:

8.93

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC 9

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

		Roof
GLASS :	N = 3072 ϕ	18'
	S = 6100 ϕ	3
	E = 2500 ϕ	2 17'
	W = 1490 ϕ	Level 1 17'
		Level 0 17'

VERTICAL ARROW:

SCALE:

8.94

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 9

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

6/9

Building ID: NNMC 9 This page covers: Before condition After Date:
 Building location: BETHESDA MD
city state ZIP code
 Project/program ID: Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: HOSP Total floor area: 584,820 (ft²) Year of latest renovation:

BECA Building Type Codes			
ASEM - Assembly Buildings	AUTO - Auto Sales and Service	GROC - Grocery Stores	RETL - Retail Stores
REST - Restaurants	SECN - Second Schools & Colleges	HOTL - Hotels/Motels	WARE - Warehouses
ELEM - Elementary Schools	NURS - Nursing Homes	HOSP - Hospitals	CUN - Clinics
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	INDS - Conditioned Industrial	SHCN - Shopping Centers
			OTHR - Other
			CORA - Correction Centers

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated 438,615 m² Cooled 438,615 m² Unconditioned m² Stories above ground: 3
 Above grade: 146,205 / 2,485,485 Below grade: 146,205 / 2,485,485
 Atrium: /
 Roof pitch: FLAT (in./in.) Exposed roof area: 146,205 (ft²) Roof insulated at: ceiling level X roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 4 Doors: 1
 Below grade walls: 3 Roof: 3
 Atrium walls: Floor: 1

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

(If code '0' is used, describe below.)

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 100 (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	14,820	26,676	14,820	26,676
Glazing area (ft ²)	2,500	6,100	1,490	3,072
Shading by overhangs (y or n)	N			
Shading by fins (y or n)	N			
Photos attached showing facade (y or n)				

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

7/9

**EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 2**

Building ID: NNMC 9 This page covers: Before condition ___ After ___ Date: _____

2. Tenant Information

Tenancy breakdown (% of floor area): ___ % leased/rented ___ % owner-occupied ___ % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	NNMC	ALL		

Total floor area (ft²): _____

Description of variances: _____

3. Building Zone Information (minimum zone size is 10% of tenant area)

STORAGE
OFFICE/EXAM
OPER. RMS/LABS
FOOD PREP
DINING
COMPUTER OFFICE
MECH/ELEC
PATIENT ROOM

Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling
1	202	50,640	17'				
2	300	384,090	17'				
3	502	63,600	VAR.				
4	400	12,900	17'				
5	102	12,900	17'				
6	501	12,900	17'				
7	505	12,900	18'				
8	700	15,480	18'				

35,760

19450

Description of variances: _____

4. Zone Schedule and Occupancy

(use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.:	1	Hour open	7					
		Hour closed	5					
		Occupant-hrs	10					
Tenant/Zone No.:	2	Hour open	7					
		Hour closed	5					
		Occupant-hrs	10					
Tenant/Zone No.:	3	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	4	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	5	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	6	Hour open						
		Hour closed						
		Occupant-hrs						

8/9

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNAC 9 This page covers: Before condition After Date:

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.:	<u>7</u>	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	<u>8</u>	Hour open						
		Hour closed						
		Occupant-hrs						
Description of variances and zones with variable occupancy: <u>SCHEDULE HOURS ESTIMATED</u>								

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Servdy (see codes)	Fuel Code
S1	SERH						
S2	TPIU						
S1	SERH		ALL				S/CH
S2	TPIU		ALL				S/CH

HVAC Type Codes (see p 5)

Single supply duct types: SZRH, PSZ, HP, HPWS, SZCI, RHFS, VAVS, PIU, PVAVS, CBVAV, WT
Air mixing types: MZS, PMZS, DCS
Terminal unit types: TPFC, EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR, FPH, HVSYS, UHT, UVT, WS

Controls Codes

h-heating, c-cooling, b-both
1-none (on/off manual), 2-timerclock, 3-thermostat, 4-smart thermostat, 5-EMCS

Pkg/Servdy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by primary system (below)
p+s-packaged + secondary

Fuel Codes

e-electricity, g-natural gas, o-distillate fuel oil (#1 or 2), oh-other fuel oil, c-coal, w-wood, ch-chilled water from outside the building, s-steam from outside the building

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				52, 51
CC/CA	E/S				52, 51

Primary System Codes

BW-hot water boiler, BS-steam boiler, F-furnace, CC-centrifugal chiller, CA-absorption chiller, CAR-air-cooled reciprocating chiller, CWR-water-cooled reciprocating chiller, CAS-air-cooled screw chiller, CWS-water-cooled screw chiller, CT-cooling tower, EC-evaporative condenser, EV-evaporative cooler

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
ALL	IF		7,800	M	

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

9/9

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 9 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M=manual, T=timer, P=photocell/daylight dimming, O=other

Description of variances: LIGHTING / SOFT VALUES FOR BLDG # 70
USED HERE
ESTIM. TOTAL LIGHT. WATTS. FLOOR, = 1,048,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO=food preparation, REF=chillers, refrigerators, freezers, and other equipment for cold generation, DPT=significant computer or electrical/electronic equipment (including video games), SAN=sanitation equipment such as in a laundry or kitchen, LAB=laboratory equipment, SHP=shop or manufacturing equipment, SPE=specialty equipment not covered by other categories, VNT=ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR=vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances:

BUILDING TITLE:

HOSPITAL

BUILDING NUMBER:

NNMC 10

CONTACT LISTING

DATE

NAME

PHONE

BUILDING ADDRESS

BLDG # 10

BUILDING SITE DESCRIPTION

CONNECTED TO AND DIRECTLY SOUTH OF BLDG #9

BUILDING USE SUMMARY

HOSPITAL PATIENT ROOMS AND NURSE STATIONS

BUILDING CONSTRUCTION SUMMARY

HVAC SYSTEM SUMMARY

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.99

PREPARED BY: E. RICHMANDATE: 7-14-89BUILDING NUMBER: NNMC 10

SUMMARY OF AVAILABLE INFORMATION


QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

QUALITY AND SOURCE OF MEASURED ENERGY USE

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW




TRUE NORTH ARROW:

SCALE:

8.101

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC 10

SITE DESCRIPTION - PLAN VIEW



TRUE NORTH ARROW:

SCALE:

8.102

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NNMC

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

GLASS :		Roof
N = 10,700 ϕ	7	13'
S = 13,400 ϕ	6	13'
E = 1240 ϕ	5	13'
W = 1240 ϕ	4	13'
	3	13'
	2	17'
	1	17'
	Level 0 17'	

VERTICAL ARROW:

SCALE:

8.103

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 10

6/9

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 10 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: city state MD zip code
 Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: HOSP Total floor area: 240,230 (ft²) Year of latest renovation:

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	GAOC - Grocery Stores	RETL - Retail Stores	SHCN - Shopping Centers
REST - Restaurants	SECN - Second. Schools & Colleges		HOTL - Hotels/Motels	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes		HOSP - Hospitals	CJUN - Clinics	CORR - Correction Centers
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)		INDS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
 Above grade: 230,230 (ft²) 230,230 (ft²) (ft²)
 Below grade: 10,000 (ft²) 10,000 (ft²) 170,000 (ft²)
 Atrium: (ft²) (ft²) (ft²)
 Roof pitch: FLAT (in./in.) Exposed roof area: 32,890 (ft²) Roof insulated at: ceiling level roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: 32,890 (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 4 Doors: 1
 Below grade walls: 1 Roof: 3
 Atrium walls: Floor: 1/2
 (If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 00 (% of total glazing)
 (circle those that apply) Single Double Triple
 Secondary glazing: (% of total glazing)
 (circle those that apply) Single Double Triple

Est. U-value (Btu/h-ft²-F)
 Clear Tinted Reflective Other Fixed Operable
 Est. U-value (Btu/h-ft²-F)
 Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	<u>6435</u>	<u>50,094</u>	<u>6435</u>	<u>50,095</u>
Glazing area (ft ²)	<u>1240</u>	<u>13,400</u>	<u>1240</u>	<u>10,700</u>
Shading by overhangs (y or n)	<u>N</u>	<u> </u>	<u> </u>	<u> </u>
Shading by fins (y or n)	<u>N</u>	<u> </u>	<u> </u>	<u> </u>
Photos attached showing facade (y or n)	<u> </u>	<u> </u>	<u> </u>	<u> </u>

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

7/9

EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 2

Building ID: NNMC 10 This page covers: Before condition ___ After ___ Date: _____

2. Tenant Information

Tenancy breakdown (% of floor area): ___ % leased/rented ___ % owner-occupied ___ % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	NNMC	ALL		

Total floor area (ft²): _____

Description of variances: _____

3. Building Zone Information (minimum zone size is 10% of tenant area)

	Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
					heating	cooling	heating	cooling
PATIENT RMS.	1	700	164,450	13'				
OFFICE	2	300	15,015	17'				
LOBBY	3	105	18,720 *	17' *				
STORAGE	4	202	11,765	17'				
MECH	5	505	210,000	17'				
CONF./CLASSROOMS	6	103	20,280	17'				

Description of variances: * 2 ~~FLOOR~~ STORY @ 9,360 X 17'

4. Zone Schedule and Occupancy

(use times from 00:00–23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.:	1	Hour open	24 HOUR					
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	2	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	3	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	4	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	5	Hour open						
		Hour closed						
		Occupant-hrs						
Tenant/Zone No.:	6	Hour open						
		Hour closed						
		Occupant-hrs						

8/9

9/9

**EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 4**

Building ID: NNMC 10 This page covers: Before condition ___ After ___ Date: _____

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: LIGHT DATA TAKEN ON SQFT BASIS FROM
BLDG # 70
ESTIM. TOTAL WATTS FLOR. = 430,500

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances: _____

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances: _____

BUILDING TITLE:

ORIGINAL HOSPITAL BUILDING

BUILDING NUMBER:

NNMC1

CONTACT LISTING

DATE

NAME

PHONE

BUILDING ADDRESS

BLDG # 1

BUILDING SITE DESCRIPTION

ORIGINAL NNMC SITE WITH VIEW TO WEST
OF LAKE ELEANOR

BUILDING USE SUMMARY

ADMINISTRATION OFFICES & MEDICAL EXAM/OFFICE

BUILDING CONSTRUCTION SUMMARY

MASONRY

HVAC SYSTEM SUMMARY

SINGLE ZONE REHEAT AND RADIATOR UNITS

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.108

PREPARED BY: E. RICHMAN

DATE: 7-14-84 BUILDING NUMBER: 1

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

METERED BY 2 METERS IN BASEMENT SUBSTATION

→ PROZENT = $\frac{\text{Zahl}}{\text{Gesamtzahl}} \cdot 100$

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES


NA

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

This image shows a single sheet of white paper with horizontal blue or grey ruling lines. The lines are evenly spaced and run across the width of the page. There is no handwriting or other markings on the paper.

SITE DESCRIPTION - PLAN VIEW




TRUE NORTH ARROW:

SCALE:

8.110

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 1

SITE DESCRIPTION - PLAN VIEW




TRUE NORTH ARROW:

SCALE:

8.111

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 1

SITE DESCRIPTION - PLAN VIEW



TRUE NORTH ARROW:



SCALE:

\square 20' x 20'

8.112

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: NMNC

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

12 FT. FLOORS BASE → 4th11 FT. FLOORS ST → 17th17' 18th24' 19th12' 20thELEVATIONSSQ. FOOTAGESW = 37,760 GLASS = ~~5446~~ 5446

E = 35,072 GLASS = 5204

N = ~~30,420~~ 30,420 GLASS = 4657S = ~~30,420~~ 30,420 GLASS = 4657

VERTICAL ARROW:

SCALE:

8.113

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 1

7/10

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC | This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: city state zip code
 Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: Total floor area: 243,525 (ft²) Year of latest renovation: 1980

BECA Building Type Codes			
ASEM - Assembly Buildings	AUTO - Auto Sales and Service	GROC - Grocery Stores	RETL - Retail Stores
REST - Restaurants	SECN - Second Schools & Colleges	HOTL - Hotels/Motels	WARE - Warehouses
ELEM - Elementary Schools	NURS - Nursing Homes	HOSP - Hospitals	CUN - Clinics
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	INDS - Conditioned Industrial	SHCN - Shopping Centers
			OTHR - Other
			CORR - Correction Centers

Floor area of latest additions: ALL (ft²) (ft²) (ft²) Number of stories: 20
 Year completed: 1980

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
 Above grade: 217,610 / 3,619,157 217,610 / 3,619,157 /
 Below grade: 25,915 / 310,980 25,915 / 310,980 /
 Atrium: / / /
 Roof pitch: FLAT (in./in.) Exposed roof area: 25,915 (ft²) Roof insulated at: ceiling level roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 2/3 Doors: 1
 Below grade walls: 3 Roof: 1
 Atrium walls: Floor:
 (If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

	Orientation			
	East	South	West	North
Above grade gross wall area (ft ²)	<u>35,072</u>	<u>30,420</u>	<u>37,760</u>	<u>39,420</u>
Glazing area (ft ²)	<u>5204</u>	<u>4657</u>	<u>5446</u>	<u>4657</u>
Shading by overhangs (y or n)	<u>N</u>	<u> </u>	<u> </u>	<u> </u>
Shading by fins (y or n)	<u>N</u>	<u> </u>	<u> </u>	<u> </u>
Photos attached showing facade (y or n)	<u> </u>	<u> </u>	<u> </u>	<u> </u>

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 00 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

8/10

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 2

Building ID: NNMC 1 This page covers: Before condition ___ After ___ Date: _____

2. Tenant Information

Tenancy breakdown (% of floor area): ___ % leased/rented ___ % owner-occupied ___ % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	NNMC			

Total floor area (ft²): _____

Description of variances: _____

3. Building Zone Information (minimum zone size is 10% of tenant area)

Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling
1	111	24352	VAR.				
2	300	219,173	VAR.				

HALL
STAIR
OFFICE
CLASS
EXAM

Description of variances: HALL ESTIMATED AT 10%
ZONE 2 IS MIXTURE OF VARIOUS HOSPITAL FACILITIES

One Schedule and Occupancy

(use times from 00:00-23:59)

Tenant/Zone No.:		Day of week:							
		Mon	Tues	Wed	Thu	Fri	Sat	Sun	Hol
1	Hour open	7							
	Hour closed	6							
	Occupant-hrs	11							
2	Hour open								
	Hour closed								
	Occupant-hrs								
	Hour open								
	Hour closed								
	Occupant-hrs								
	Hour open								
	Hour closed								
	Occupant-hrs								
	Hour open								
	Hour closed								
	Occupant-hrs								
	Hour open								
	Hour closed								
	Occupant-hrs								

BASIC OFFICE
HOURS PLUS
SOME SHIFT
HOURS?

9/10

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC This page covers: Before condition ___ After ___ Date: _____

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00–23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.: _____	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: _____	Hour open							
	Hour closed							
	Occupant-hrs							

Description of variances and zones with variable occupancy: _____

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scndy (see codes)	Fuel Code
S1	S2RH	3	ALL				S/CH
S2	TPIU	3	ALL				S/CH
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)

Single supply duct types:
SZRH, PSZ, HP, HPWS, SZCH,
RHFS, VAVS, PIU, PAVS,
CBVAV, VWT
Air mixing types: MZS, PMZS,
DGS
Terminal unit types: TPFC,
EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR,
FPH, HVSYS, UNT, UNT, WS

Controls Codes

h-heating, c-cooling, b-boil
1-none (on/off manual),
2-timer, 3-thermostat,
4-smart thermostat, 5-EMCS

Pkg/Scndy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by pri-
mary system (below)
p+s-packaged + secondary

Fuel Codes

e-electricity, g-natural gas,
o-distillate fuel oil (#1 or 2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from
outside the building, s-steam
from outside the building

Primary System Codes

BW-hot water boiler, BS-steam
boiler, F-furnace, CC-centrifugal
chiller, CA-absorption
chiller, CAR-air-cooled reciprocating
chiller, CWR-water-cooled
reciprocating chiller, CAS-
air-cooled screw chiller,
CWS-water-cooled screw
chiller, CT-cooling tower,
EC-evaporative condenser,
EV-evaporative cooler

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				S1 S2
CC/CA	E/S				S1 S2

Description of variances: _____

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
ALL	IF		≈ 3250	M	

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHD	EHD
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight
dimming, O-other

10/10

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC1 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: THE LIGHTING ESTIMATED BASED ON BLDG 70 DATA

ESTIM. TOTAL LIGHTING WATTS FLOOR, = 436,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances:

BUILDING TITLE:

HOSPITAL/CLINIC

BUILDING NUMBER:

NNMC 2

CONTACT LISTING

DATE

NAME

PHONE

BUILDING ADDRESS

BLDG # 2

BUILDING SITE DESCRIPTION

DIRECTLY EAST OF ORIGINAL BLDG #1

BUILDING USE SUMMARY

MEDICAL OFFICES, CLINICS, AND EXAM ROOMS
INCL. LARGE AUDITORIUM.

BUILDING CONSTRUCTION SUMMARY

BLOCK/CONCRETE
DBL WINDOWS

HVAC SYSTEM SUMMARY

SINGLE ZONE REHEAT WITH RADIATOR UNITS

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.118

PREPARED BY: E. RICHMAN

DATE: 7-14-89

BUILDING NUMBER: NNMC

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

METERED WITH BLOCS 7, 8

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW

FOOTAGES

<u>LEVEL</u>		<u>Φ</u>		
1	BASE	41,056		
2	X	36,128		
3	X	23,092		
4	X	13,280		
		<u>113,556</u>		

TRUE NORTH ARROW:

SCALE:

8. 120

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 1

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

ELEV. ϕ

ABOVE GRADE

GLASS LP

N = 13,056

N = 686

S = ~~12,472~~ 104

S = 1040

E = 2500

E = ~~UNKNOWN~~ CLOSE TO ϕ

W = 5060

W = 875

VERTICAL ARROW:

SCALE:

8.121

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 1

5/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 2 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: Total floor area: 113,556 (ft²) Year of latest renovation: 1980's

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	RETL - Retail Stores	SHCN - Shopping Centers
REST - Restaurants	SECH - Second Schools & Colleges	GROC - Grocery Stores	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes	MOTL - Hotels/Motels	CLIN - Clinics	CORA - Correction Centers
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	HOSP - Hospitals		
		INDS - Conditioned Industrial		

Floor area of latest additions: ALL (ft²) (ft²) (ft²) Number of stories:
 Year completed: 1980's

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
 Above grade: 113,556 113,556 113,556 4
 Below grade:
 Atrium:
 Roof pitch: FLAT (in./in.) Exposed roof area: (ft²) Roof insulated at: ceiling level roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 2 Doors: 1
 Below grade walls: Roof: 1
 Atrium walls: Floor: 1
 (If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 100 (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	2500	13,104	5060	13,056
Glazing area (ft ²)	(0)*	1040	875	686
Shading by overhangs (y or n)	N			
Shading by fins (y or n)	N			
Photos attached showing facade (y or n)				

* EST.

Floor plan sketch(es) attached (y or n) Y see as-built drawings

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

6/8

EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 2

Building ID: NNMC 2 This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of floor area): % leased/rented % owner-occupied % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
<u>0</u>	<u>COMMON</u>	<u> </u>	<u> </u>	<u> </u>
<u>1</u>	<u>NNMC</u>	<u>ALL</u>	<u> </u>	<u> </u>

Total floor area (ft²):

Description of variances:

3. Building Zone Information (minimum zone size is 10% of tenant area)

Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling

Description of variances:

4. Zone Schedule and Occupancy

(use times from 00:00–23:59)

STANDARD
OFFICE
OR
CLINIC
HOURS
WITH
POSSIBLE
24 HOUR
OPERATION

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol							
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								
Tenant/Zone No.: <u> </u>	Hour open								
	Hour closed								
	Occupant-hrs								

7/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC 2 This page covers: Before condition After Date:

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							

Description of variances and zones with variable occupancy:

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Sandy (see codes)	Fuel Code
S1	SZRH		ALL				5/CH
S2	TPIU		ALL				5/CH
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)
Single supply duct types: SZRH, PSZ, HP, HPWS, SZCH, RPHS, VAVS, PIU, PAVS, CBVAV, WT
Air mixing types: MZS, PMZS, DCS
Terminal unit types: TPFC, EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: BBS, IR, FPH, HVSYS, UHT, UVT, WS

Controls Codes
h-heating, c-cooling, b-both
1-none (on/off manual),
2-timed clock, 3-thermostat
4-smart thermostat, 5-EMC2

Pkg/Sandy Codes
p-packaged unit (unitary eqpt.)
s-secondary unit served by primary system (below)
p+s-packaged + secondary

Fuel Codes
e-electricity, g-natural gas,
o-distillate fuel oil (#1 or #2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from outside the building, s-steam from outside the building

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	oL				51, 52
cc/CH	E/S				51, 52

Primary System Codes
BW-hot water boiler, BS-steam boiler, F-furnace, CC-centrifugal chiller, CA-absorption chiller, CAR-air-cooled reciprocating chiller, CWR-water-cooled reciprocating chiller, CAS-air-cooled screw chiller, CWS-water-cooled screw chiller, CT-cooling tower, EC-evaporative condenser, EV-evaporative cooler

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
ALL	IF		~1500	M	

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

8/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NM C 2 This page covers: Before condition ___ After ___ Date: _____

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	I	E
Neon	IN	EN
HID	IHD	EHD
Other	O	EO

Control Codes

M-manual, T-timer, P-photosell/daylight dimming, O-other

Description of variances: LIGHTING EST. PER BLDG # 70 DATA
EST. TOTAL LIGHT WATTS FLUOR. = 204,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, CPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances: _____

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

_____/ 10 /_____
_____/ 10 /_____
_____/ 10 /_____
_____/ 10 /_____

Description of variances: _____

BUILDING TITLE:

HOSPITAL / CLINIC

BUILDING NUMBER:

NNMC 7

CONTACT LISTING

DATE	NAME	PHONE

BUILDING ADDRESS

BLDG # 7

BUILDING SITE DESCRIPTION

ATTACHED TO ORIGINAL BLDG # 2

BUILDING USE SUMMARY

MEDICAL OFFICE / CLINIC / LAB

BUILDING CONSTRUCTION SUMMARY

BLOCK MASONRY

DOUBLE WINDOWS

HVAC SYSTEM SUMMARY

SINGLE ZONE REHEAT w/ RADIATOR UNITS AT PERIMETER

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.126

PREPARED BY: E. RICHMANDATE: 7-14-89 BUILDING NUMBER: NNMC

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

METERED WITH 2,8

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW

SEE AS-BUILTS

$$\begin{array}{r} \text{GROUND} = 31232 \text{ } \phi \\ 1 = 8448 \text{ } \phi \\ \hline 39680 \text{ } \phi \end{array}$$

TRUE NORTH ARROW:

SCALE:

8.128

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 7

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

$$N (5\frac{1}{2} + 1\frac{1}{2}) \times 32 \times 12 = 2688$$

$$E (5 + 5) \times 32 \times 12 = 3840$$

$$W (4) \times 32 \times 12 = 1536$$

VERTICAL ARROW:

SCALE:

8.129

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 7

5/8

EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 1

Building ID: NNMC 7 This page covers: Before condition: MD After: MD Date: MD
Building location: BETHESDA city
Project/program ID: MD Prepared by: E. RICHMAN state ZIP code

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
(circle one)
BECA building type code: HOSP Total floor area: 39,680 (ft²) Year of latest renovation: MD

BECA Building Type Codes			
ASEM - Assembly Buildings	AUTO - Auto Sales and Service	GROC - Grocery Stores	RETL - Retail Stores
REST - Restaurants	SECN - Second Schools & Colleges	HOTL - Hotels/Motels	WARE - Warehouses
ELEM - Elementary Schools	NURS - Nursing Homes	HOSP - Hospitals	CJUN - Clinics
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	INDS - Conditioned Industrial	SHCN - Shopping Centers
			OTHR - Other
			CORR - Correction Centers

Floor area of latest additions: _____ (ft²) _____ (ft²) _____ (ft²) Number of stories: _____
Year completed: _____

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
Above grade: 39,680 / 476,160 39,680 / 476,160 _____ / _____ 2
Below grade: _____ / _____ _____ / _____ _____ / _____
Atrium: _____ / _____ _____ / _____ _____ / _____
Roof pitch: FLAT (in./in.) Exposed roof area: 31,232 (ft²) Roof insulated at: ceiling level _____ roof level _____
Average roof estimated U-value (Btu/h-ft²-F) _____ Ground-coupled floor area: 31,232 (ft²)
Average estimated opaque wall U-value (Btu/h-ft²-F) _____ Common walls: _____ (%)
Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 2 Doors: 1
Below grade walls: _____ Roof: 1
Atrium walls: _____ Floor: 1
(If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: _____ (ft²)

Wall/glazing information

Primary glazing type: 100 (%) of total glazing Est. U-value _____ (Btu/h-ft²-F)
(circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
Secondary glazing: _____ (%) of total glazing Est. U-value _____ (Btu/h-ft²-F)
(circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	<u>3840</u>	<u>0</u>	<u>1536</u>	<u>2688</u>
Glazing area (ft ²)				
Shading by overhangs (y or n)	<u>N</u>			
Shading by fins (y or n)	<u>N</u>			
Photos attached showing facade (y or n)				

UNKNOWN

Floor plan sketch(es) attached (y or n) N

Maintenance: In-house 100 (%) Contractor, cont. _____ (%) Contractor, as needed _____ (%) Owner/tenant _____ (%) Other _____ (%)
Description of variances: _____

6/8

EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 2

Building ID: NNMC 7 This page covers: Before condition ___ After ___ Date: _____

2. Tenant Information

Tenancy breakdown (% of floor area): ___ % leased/rented ___ % owner-occupied ___ % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	NNMC			

Total floor area (ft²): _____

Description of variances: _____

3. Building Zone Information (minimum zone size is 10% of tenant area)

Tenant/ Zone No.	Use Code	Zonal Area (ft ²)	Zonal Ceiling height (ft)	Occupied Setpoint (F)		Unoccupied Setpoint (F)	
				heating	cooling	heating	cooling

Description of variances: _____

4. Zone Schedule and Occupancy

(use times from 00:00–23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol							
STANDARD OFFICE CLINIC LAB HOURS w/24 hour USE POSSIBLE	Tenant/Zone No.:	Hour open							
		Hour closed							
		Occupant-hrs							
	Tenant/Zone No.:	Hour open							
		Hour closed							
		Occupant-hrs							
	Tenant/Zone No.:	Hour open							
		Hour closed							
		Occupant-hrs							
	Tenant/Zone No.:	Hour open							
		Hour closed							
		Occupant-hrs							
	Tenant/Zone No.:	Hour open							
		Hour closed							
		Occupant-hrs							
	Tenant/Zone No.:	Hour open							
		Hour closed							
		Occupant-hrs							

7/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC-7 This page covers: Before condition ___ After ___ Date: _____

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00–23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.: _____	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: _____	Hour open							
	Hour closed							
	Occupant-hrs							

Description of variances and zones with variable occupancy: _____

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Scondy (see codes)	Fuel Code
S1	SZRH	3	ALL				5/CH
S2	TPIU	3	ALL				5/CH
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)

Single supply duct types:
SZRH, PSZ, HP, HPWS, SZCI,
RHFS, VAVS, PIU, PVAVS,
CBVAV, WT
Air mixing types: MZS, PMZS,
DCS
Terminal unit types: TPFC,
EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR,
FPH, HVSYS, UHT, UVT, WS

Controls Codes

h-heating, c-cooling, b-both
1-none (on/off manual),
2-timer, 3-thermostat,
4-smart thermostat, 5-EMCS

Pkg/Scondy Codes

p-packaged unit (unitary eqpt.)
s-secondary unit served by pri-
mary system (below)
p+s-packaged + secondary

Fuel Codes

s-electricity, g-natural gas,
o-distillate fuel oil (#1 or #2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from
outside the building, s-steam
from outside the building

Primary System Codes

BW-hot water boiler, BS-steam
boiler, F-furnace, CC-centrifugal
chiller, CA-absorption
chiller, CAR-air-cooled reciprocating
chiller, CWR-water-cooled
reciprocating chiller, CAS-
air-cooled screw chiller, CWS-
water-cooled screw chiller, CT-cooling tower,
EC-evaporative condenser,
EV-evaporative cooler

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				S1, S2
CA/CA	E/S				S1, S2

Description of variances: _____

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
ALL	IFL		~ 530	M	

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EIHD
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight
dimming, O-other

8/8

**EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 4**

Building ID: NNMC 7 This page covers: Before condition ___ After ___ Date: _____

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-int fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHD	EHD
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: LIGHT VALUES EST. BASED ON BLDG 70

EST. TOTAL WATTS FLOOR. = 71,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, OPT-significant computer or electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances: _____

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

			to		
			to		
			to		
			to		

Description of variances: _____

BUILDING TITLE:

HOSPITAL / CLINIC

BUILDING NUMBER:

NNMC 8

CONTACT LISTING

DATE	NAME	PHONE

BUILDING ADDRESS

BLDG 8

BUILDING SITE DESCRIPTION

ATTACHED TO ORIGINAL BUILDING #2

BUILDING USE SUMMARY

MEDICAL OFFICE / CLINIC / LAB

BUILDING CONSTRUCTION SUMMARY

BLOCK MASONRY

DOUBLE WINDOWS

HVAC SYSTEM SUMMARY

SINGLE ZONE REHEAT WITH RADIATOR UNITS AT PERIMETER

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.134

PREPARED BY: E. RICHMANDATE: 7-14-84 BUILDING NUMBER: 8

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

QUALITY AND SOURCE OF MEASURED ENERGY USE

metered with bldg 2,7

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW

SEE AS-BUILTS

(BASE)	25,600
1	25,600
2	7744
3	7744
4	7744
	<hr/>
	74432

TRUE NORTH ARROW:

SCALE:

8.136

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 8

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE

Elev. ϕ

$$N \quad (3 + 1\frac{1}{2}) 12 \times 12 = 1728$$

$$S \quad (5 + 5 + 1\frac{1}{2} + 1\frac{1}{2} + 1\frac{1}{2}) 12 \times 12 = 5568$$

$$E \quad (5\frac{1}{2} + 5\frac{1}{2} + 5\frac{1}{2} + 5\frac{1}{2} + 5\frac{1}{2}) 12 \times 12 = 10560$$

$$W \quad (5\frac{1}{2} + 5\frac{1}{8} + 5\frac{1}{2} + 5\frac{1}{2} + 5\frac{1}{2}) 12 \times 12 = 8688$$

VERTICAL ARROW:

SCALE:

8.137

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 8

5/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 8 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: HOSP Total floor area: 74432 (ft²) Year of latest renovation:

BECA Building Type Codes				
ASEM - Assembly Buildings	AUTO - Auto Sales and Service	GROC - Grocery Stores	RETL - Retail Stores	SHOP - Shopping Centers
REST - Restaurants	SECN - Second, Schools & Colleges	HOTL - Hotels/Motels	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes	HOSP - Hospitals	CLIN - Clinics	CORR - Correction Centers
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	INDS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:
 Above grade: 74432 (ft²) 74432 (ft²) (ft²) 5
 Below grade: (ft²) (ft²) (ft²)
 Atrium: (ft²) (ft²) (ft²)
 Roof pitch: (in./in.) Exposed roof area: 25602 (ft²) Roof insulated at: ceiling level roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: 25602 (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.

Building shell construction codes

Above grade walls: 2 Doors: 1
 Below grade walls: Roof: 1
 Atrium walls: Floor: 1
 (If code '0' is used, describe below.)

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 00 (% of total glazing) Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: (% of total glazing) Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	10560	5568	8688	1728
Glazing area (ft ²)				
Shading by overhangs (y or n)	N			
Shading by fins (y or n)	N			
Photos attached showing facade (y or n)				

- UNKNOWN

Floor plan sketch(es) attached (y or n) N

Maintenance: In-house (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 2

Building ID: NNMC 8 This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of floor area): _____ % leased/rented _____ % owner-occupied _____ % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			
1	NNMC	ALL		

Total floor area (m^2): _____

Description of variances:-

3. Building Zone Information (minimum zone size is 10% of tenant area)

[illegible]

Description of variances:

4. Zone Schedule and Occupancy

(use times from 00:00-23:59)

Day of week: Mon Tues Wed Thu Fri Sat Sun Hol

Tenant/Zone No.:

Hour open

Hour closed

Occupant-hrs

Tenant/Zone No.: _____

Hour open

Hour closed

Occupant-hrs

TenantZone No.:

Hour open

Hour closed

Occupant-hrs

Tenant/Zone No.:

Hour open

Hour closed

Occupant-hrs

STANDARD

OFFICE

CLINIC

MEDICAL

LAB

HOURS

W/ 24 HOUR

USE

POSSIBLE

Tenant/Zone No.:

Hour open

Hour closed

Occupant-hrs

Tenant/Zone No.:

Hour open

Hour closed

Occupant-hrs

7/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 3

Building ID: NNMC 8- This page covers: Before condition After Date:

4. Zone Schedule and Occupancy (cont'd) (use times from 00:00-23:59)

		Day of week: Mon Tues Wed Thu Fri Sat Sun Hol						
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							
Tenant/Zone No.: <u> </u>	Hour open							
	Hour closed							
	Occupant-hrs							

Description of variances and zones with variable occupancy:

5. Systems Data

HVAC Systems (See page 5 of the forms for descriptions of the HVAC type codes.)

System ID No.	HVAC Type Code	Controls Code	Tenant/Zones Served	Cooling (kBtu/h)	Heating (kBtu/h)	Pkg/Sendy (see codes)	Fuel Code
S1	S2RH	B3	ALL				S/C4
S2	TPIU	3	ALL				S/C4
S3							
S4							
S5							
S6							

HVAC Type Codes (see p 5)
Single supply duct types: S2RH, PS2, HP, HPWS, SZCI, RHFS, VAVS, PIU, PVAVS, CBVAV, VWT
Air mixing types: MZS, PMZS, DCS
Terminal unit types: TPFC, EPFC, TPIU, FPIU, PTAC, WHP
Heating only types: EBB, IR, FPH, HVSYS, UHT, LVT, WS

Controls Codes
h-heating, c-cooling, b-both
1-none (on/off manual),
2-timed clock, 3-thermostat
4-smart thermostat, 5-EMCS

Pkg/Sendy Codes
p-packaged unit (unitary eqpt.)
s-secondary unit served by primary system (below)
p+s-packaged + secondary

Fuel Codes
e-electricity, g-natural gas,
o-distillate fuel oil (#1 or #2),
oh-other fuel oil, c-coal,
w-wood, ch-chilled water from outside the building, s-steam from outside the building

Primary HVAC Systems Serving Secondary Units

System Code	Fuel Code	Input (kBtu/h)	Output (kBtu/h)	Pumps (kW)	Secondary Systems Served, ID Nos. Above
BS	OL				S1, S2
S/C4	E/S				S1, S2

Primary System Codes
BW-hot water boiler, BS-steam boiler, F-furnace, CC-centrifugal chiller, CA-absorption chiller, CAR-air-cooled reciprocating chiller, CWR-water-cooled reciprocating chiller, CAS-air-cooled screw chiller, CWS-water-cooled screw chiller, CT-cooling tower, EC-evaporative condenser, EV-evaporative cooler

Description of variances:

Lighting

Tenant/Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
ALL	IF		≈ 1000	M	

Lighting Codes
Type Interior Exterior
Standard fluorescent IF EF
High-eff. fluorescent IFH EFH
Incandescent II EI
Neon IN EN
HID IHID EHID
Other IO EO

Control Codes
M-manual, T-timer, P-photocell/daylight dimming, O-other

8/8

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 8 This page covers: Before condition ___ After ___ Date: _____

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.
----------------------	------------------	----------------	-----------------------------------	------------------	---------------------------

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHD	EHD
Other	IO	EO

Control Codes

M-manual, T-timer, P-photosell/daylight dimming, O-other

Description of variances: LIGHT VALUES EST. BASED ON BLDG 70

EST. TOTAL LIGHT WATTS FLOOR. = 134,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW
--------------	----------------------	--------------	--------------	-----------------

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPB-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances: _____

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters
-------------------------------	--------------	---	---------------------

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

Description of variances: _____

BUILDING TITLE:

HOSPITAL/CLINIC

BUILDING NUMBER:

NNMC 4 & 6

CONTACT LISTING

DATE	NAME	PHONE

BUILDING ADDRESS

BLOG. # 4 & 6

BUILDING SITE DESCRIPTION

ATTACHED TO BUILDING 2 ON SOUTH SIDE

BUILDING USE SUMMARY

MEDICAL OFFICE AND CLINICS

BUILDING CONSTRUCTION SUMMARY

MASONRY

DOUBLE WINDOWS

HVAC SYSTEM SUMMARY

SINGLE ZONE REHEAT WITH RADIATOR UNITS

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.142

PREPARED BY: E. RICHMANDATE: 7-14-89 BUILDING NUMBER: 4 & 6

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK


QUALITY AND SOURCE OF MEASURED ENERGY USE

NOT METERED

QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

SITE DESCRIPTION - PLAN VIEW



TRUE NORTH ARROW:

SCALE: $\square = 10' \times 10'$

8.144

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: 4 & 6

4/7

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC 46 This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: Prepared by: E. RICHMAN

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 1961-1970 1971-1973 1974-1980 1981-present
 (circle one)
 BECA building type code: HOSP Total floor area: 35,600 (ft²) Year of latest renovation: 1980

BECA Building Type Codes			
ASEM - Assembly Buildings	AUTO - Auto Sales and Service	GROC - Grocery Stores	RETL - Retail Stores
REST - Restaurants	SECN - Second Schools & Colleges	MOTL - Motels/Motels	WARE - Warehouses
ELEM - Elementary Schools	NURS - Nursing Homes	HOSP - Hospitals	CUN - Clinics
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)	INOS - Conditioned Industrial	SHCN - Shopping Centers
			OTHR - Other
			CORR - Correction Centers

Floor area of latest additions: ALL (ft²) (ft²) (ft²) Number of stories: 4
 Year completed: 1980's

--- Floor area and volume: --- Heated --- Cooled --- Unconditioned --- Stories above ground:
 Above grade: 35,600 / 427,200 35,600 / 427,200 3 1/2
 Below grade:
 Atrium:
 Roof pitch: CLM (in./in.) Exposed roof area: 9348 (ft²) Roof insulated at: ceiling level X roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: 8956 (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below.
9348

Building shell construction codes

Above grade walls: 2 Doors: 1
 Below grade walls: Roof: 1
 Atrium walls: Floor: 1

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

(If code '0' is used, describe below.)

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: 100 (%) (circle those that apply) Single Double Triple
 Secondary glazing: (%) (circle those that apply) Single Double Triple
 Est. U-value (Btu/h-ft²-F) Clear Tinted Reflective Other Fixed Operable
 Est. U-value (Btu/h-ft²-F) Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)	5208	9024	5208	9024
Glazing area (ft ²)	226	1229	662	1631
Shading by overhangs (y or n)	N			
Shading by fins (y or n)	N			
Photos attached showing facade (y or n)				

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house 100 (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

6/7

Description of variances and zones with variable occupancy: _____

7/7

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 4

Building ID: NNMC 4 & 6 This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd)

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HID	IHID	EHID
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, O-other

Description of variances: LIGHT VALUES EST. BASED ON BLDG # 70

EST. TOTAL LIGHT WATTS = 64,000

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electrical/electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTR-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

 / to /
 / to /
 / to /
 / to /

Description of variances:

BUILDING TITLE:

UNIFORMED UNIVERSITY BELOW GRADE

BUILDING NUMBER:

~~UNIFORMED~~ NNMC USUHS "G"

CONTACT LISTING

DATE	NAME	PHONE

BUILDING ADDRESS

USUHS "G"

BUILDING SITE DESCRIPTION

BELOW USUHS "A", "B", "C", "D"

BUILDING USE SUMMARY

MAJORITY PARKING WITH SMALL ANIMAL LAB

BUILDING CONSTRUCTION SUMMARY

CONCRETE

HVAC SYSTEM SUMMARY

NA

MAJOR ENERGY USING EQUIPMENT SUMMARY

8.149

PREPARED BY: E. RICHMAN

DATE: _____ BUILDING NUMBER: ~~UNIFORMED~~ "G"

SUMMARY OF AVAILABLE INFORMATION

QUALITY AND SOURCE OF CONSTRUCTION DOCUMENTS

OK

[illegible]

QUALITY AND SOURCE OF MEASURED ENERGY USE

METERED WITH BLP6 # 70 - 73


QUALITY AND SOURCE OF PREVIOUS ENERGY STUDIES

NA

SUMMARY OF POTENTIAL CONSERVATION OPPORTUNITIES

This image shows a single sheet of white paper with horizontal ruling lines. The lines are evenly spaced and run across the width of the page. There are no margins, text, or other markings on the paper.

SITE DESCRIPTION - PLAN VIEW



TRUE NORTH ARROW:

SCALE:


8.151

PREPARED BY: _____

DATE: _____

BUILDING NUMBER: USVHS ^{ANAC} _{GR}

SITE DESCRIPTION - ELEVATION FOR _____ FACING FACADE



VERTICAL ARROW:

SCALE:

8.152

PREPARED BY: _____ DATE: _____ BUILDING NUMBER: G

EBER Nonresidential Energy Performance Monitoring BUILDING CORE DATA FORM — page 1

Building ID: NNMC V4VKS G This page covers: Before condition After Date:
 Building location: BETHESDA MD
 Project/program ID: Prepared by:

1. General Data and Building Envelope

Age category: 1900 or before 1901-1920 1921-1945 1946-1960 ~ 780,000 1961-1970 1971-1973 1974-1980 1981-present
 BECA building type code: Total floor area: 780,000 (ft²) Year of latest renovation:

ASEM - Assembly Buildings	AUTO - Auto Sales and Service	BECA Building Type Codes	GROC - Grocery Stores	RETL - Retail Stores	SHOP - Shopping Centers
REST - Restaurants	SECN - Second. Schools & Colleges		HOTL - Hotels/Motels	WARE - Warehouses	OTHR - Other
ELEM - Elementary Schools	NURS - Nursing Homes		HOSP - Hospitals	CLIN - Clinics	CORA - Correction Centers
SOFF - Small Office Building (< 10,000 ft ²)	LOFF - Large Office Building (≥ 10,000 ft ²)		INDS - Conditioned Industrial		

Floor area of latest additions: (ft²) (ft²) (ft²) Number of stories:
 Year completed:

Floor area and volume: Heated Cooled Unconditioned Stories above ground:

Above grade: (m²/m³) (m²/m³) (m²/m³)
 Below grade: 780,000 / 23,400,000
 Atrium:

Roof pitch: (in./in.) Exposed roof area: (ft²) Roof insulated at: ceiling level roof level
 Average roof estimated U-value (Btu/h-ft²-F) Ground-coupled floor area: (ft²)
 Average estimated opaque wall U-value (Btu/h-ft²-F) Common walls: (%)
 Describe variances in roof, walls, and floor below:

Building shell construction codes

Above grade walls: Doors:
 Below grade walls: 3 Roof:
 Atrium walls: Floor: 2

Walls: 0-other, 1-wood frame, 2-masonry, 3-concrete, 4-metal, 5-glass, 6-none
 Doors: 0-other, 1-standard doors (including mixed wood, metal, or glass), 2-large roll-up, 3-air doors
 Roof: 0-other, 1-concrete deck, 2-wood deck, 3-metal deck, 4-mixed
 Floor: 0-other, 1-slab on grade, 2-slab below grade, 3-suspended with insulation, 4-suspended without insulation

(If code '0' is used, describe below.)

For exterior doors type 2 or type 3 next to conditioned space, total area is: (ft²)

Wall/glazing information

Primary glazing type: (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable
 Secondary glazing: (%) of total glazing Est. U-value (Btu/h-ft²-F)
 (circle those that apply) Single Double Triple Clear Tinted Reflective Other Fixed Operable

Orientation

	East	South	West	North
Above grade gross wall area (ft ²)				
Glazing area (ft ²)				
Shading by overhangs (y or n)				
Shading by fins (y or n)				
Photos attached showing facade (y or n)				

Floor plan sketch(es) attached (y or n) Y

Maintenance: In-house (%) Contr., cont. (%) Contr., as needed (%) Owner/tenant (%) Other (%)
 Description of variances:

EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 2

Building ID: USUHS "G" This page covers: Before condition After Date:

2. Tenant Information

Tenancy breakdown (% of floor area): _____ % leased/rented _____ % owner-occupied _____ % other

Tenant No.	Tenant Name	Area (ft ²)	SIC code (see App. B)	Utilities paid by tenant (y or n)
0	COMMON			

Total floor area (ft²): _____

Description of variances: _____

3. Building Zone Information (minimum zone size is 10% of tenant area)

[illegible]

Description of variances: _____

4. Zone Schedule and Occupancy

(use times from 00:00-23:59)

Day of week: Mon Tues Wed Thu Fri Sat Sun Hol

Tenant/Zone No.: _____ Hour open _____

Hour open

Hour closed

Occupant-hrs

Tenant/Zone No.: _____ Hour open _____

Hour open

Hour closed

Occupant-hrs

Tenant/Zone No.: _____ Hour open _____

Hour open

Hour closed

Occupant-hrs

Tenant/Zone No.: _____ Hour open _____

Hour open

Hour closed

Occupant-hrs

Tenant/Zone No.: _____ Hour open _____

Hour open

Hour closed

Occupant-hrs

Tenant/Zone No.: _____ Hour open _____

Hour open

Hour closed

Occupant-hrs

**EBER Nonresidential Energy Performance Monitoring
BUILDING CORE DATA FORM — page 4**

Building ID: USUHS "G" This page covers: Before condition After Date:

5. Systems (cont'd)

Lighting (cont'd))

Tenant/ Zone Nos.	Lighting Code	Watts /Unit	No. of Units Total/Not working	Controls Code	Percent On Occ./Unocc.

Lighting Codes

Type	Interior	Exterior
Standard fluorescent	IF	EF
High-eff. fluorescent	IFH	EFH
Incandescent	II	EI
Neon	IN	EN
HIO	IHIO	EHIO
Other	IO	EO

Control Codes

M-manual, T-timer, P-photocell/daylight dimming, C-other

Description of variances: LIGHTING IS PREDOMINANTLY 2-TUBE, 8' CEILING MOUNTED FIXTURES W/ WHITE PLASTIC COVERS

Other Major Energy Consuming Systems

System ID	Tenant/ Zone Nos.	Type Code	Fuel Code	Connected kW

Type Codes for Other Energy Systems

FOO-food preparation, REF-chillers, refrigerators, freezers, and other equipment for cold generation, DPT-significant computer or electronic equipment (including video games), SAN-sanitation equipment such as in a laundry or kitchen, LAB-laboratory equipment, SHP-shop or manufacturing equipment, SPE-specialty equipment not covered by other categories, VNT-ventilation equipment not part of the HVAC supply system, such as return or exhaust fans and exhaust hoods, VTP-vertical transport such as elevators and escalators

Description of variances:

6. Monthly Energy and Fuel

Energy Utility or Supplier	Fuel Code	System ID Nos. of Supplied HVAC or Other Systems	Number of Meters

7. Energy Improvements Being Evaluated

Energy Imp. Code	Description	Tenant/Zone Nos. or System ID Nos. Affected	Installation Day or Period	Cost (\$000's)	Savings (\$000's)/yr
---------------------	-------------	--	-------------------------------	-------------------	-------------------------

_____ / to _____
 _____ / to _____
 _____ / to _____
 _____ / to _____

Description of variances:

84	BLDG	METER TYPE
70	50	S, CH
23	12	S, CH
56	11	S
	60	S, CH
	90	

BLDG 14 FAX

202-295-6461

STEAM FLOW METERS

WESTINGHOUSE

RB-3008 HT-IG

STEAM HEADERS

#2 BYPASS OLD TO NEW
HOSPITAL

#3 OLD HOSP.

#1 NEW HOSP.

#5 BLDG 23, UNIV., BOWLIN

#6 BLDG 21

#7 BLDG 17, GROUNDS AREA

CHILL HEADERS

OLD HOSP.

NEW HOSP.

UNIV.

BLDG 21 NMRI

8.157

headers
not

{ BLDG 60
n. . .

NNMC

NOTES

— 2 ELEC. SERVICES (PEPCO) KWH & KW

MAIN BLDG

USVHS

SUBMETERING TO: (BLDGs)

~~RUNNING 9 which is sub~~

9 (incl. 10) ???

14

54

70, 71, 72, 73 ???

— CBAS NOT OPERATING

— STEAM SUBMETERING: (BLDGs)

9

14

54

} ORIFACE PLATE UNKNOWN

— CHILL H₂O SUMM: (BLDGs)

9

14

54

— NRESA sees ~~food~~ possibilities in BLDG 9, 10 AHU'S.

J. HOWARD OFF ON VAC JUN 2-18
EMCO METERS

5 SC 12 12 12 12 12 12
11, 60, 12, 50, 57, 56, 23, 70-77

STEAM TRAPS & LEAKS FIXED

DO NOT
DO NOT

DRAWINGS
BOB MIELSON

MEET
DO NOT

DRAWINGS TO GET COPIES OF

SINGLE LINE for: steam
chilled water
ELEC
RISER FOR EACH BLDG
PIPE LAYOUT AT MAIN PLANTS

INFO TO GET OFF DRAWINGS:

HVAC CAPACITIES
HVAC SYSTEM FUNCTION/LAYOUT
COUNTS OF fan coils, etc...
LIGHT TYPE & COUNTS
FOOTAGES
FLOORS
CONSTRUCTION details

AT PLANT GET: 8.159

BOILER INFO

METER POINTS

METER READ DATA

LOG DATA INCL, FUEL USE

SEASONAL (DAYS)
MONTHLY TOTAL

DENNIS

PHONE #

ELECTRONIC :

- MONTHLY CONSUMPTION BY SUBSTATION
ALL YEARS

- ALL METERS CONSUMPTION

CHECK DATES/YEARS
DEMAND?

- DEMAND FOR SUBSTATIONS?

off, on, MID KWH NUMBERS?

AND
~~IT~~ COPY OF LAST 12 MONTHS BILLS
AND COPY OF DEMAND PAGES

JULY/AUGUST

DEC/JAN

MAR/APR

OCT/NOV

ELECTRONIC

✓ MONTHLY KWH CONSUMPTION BY SUBSTATION
ALL YEARS

✓ MONTHLY KWH CONSUMPTION BY METER
ALL YEARS
FOR ALL ON-SITE METERS

NA MONTHLY KW DEMAND BY SUBSTATION
ALL YEARS

✓ MONTHLY KWH CONSUMPTION BY SUBSTATION
for "off", "on", and "mid" PEAK
ALL YEARS

PAPER

○ LAST 12 MONTH ELECTRIC BILLS FOR BOTH SUBSTATIONS

✓ SELECTED PAGES FROM DEMAND REPORT

✓ PRINTOUT OF ALL SUB METERS

TO TRACK DOWN AND COMPLETE:

— HVAC SYSTEM TYPES

* COPY 12 MONTHLY BILLS...

* GET SIMPLE BLDG 2, 4, 6, 7, 8 DIAGRAMS
GET CLAS #3 ON FIRST FLOORS #1, 7, 8

— WALK BLDGS

* BOILER ~~LOG~~ MIN OUTPUT LEVELS BY MONTH (IF AVAIL.)

* CHECK STEAM METERS

* BOILER DAILY HI, LOW, AVE TEMPS (IF AVAIL.) (BASE USED FOR DD)
* RECORD BOILER DATA

— BOILER LOG COPIES OF HOURLY READINGS FOR PROFILES (IF AVAIL.)

* GET COPY OF STEAM METER IN PROPOSAL

* RESOLVE ELEC. DIST. & METERING QUESTIONS

X — DO THE 8 METERS ON BLDG 9 BASEMENT EQUIP.
COVER ALL ENERGY TO BLDG #9 & 10??

X — DO THE 6 METERS ON "SUB #2" EQUIP IN
BASE OF BLDG 2 & 2 METERS ON "SUB #1" EQUIP. IN BLDG 1
COVER ALL ENERGY TO THE #1 & #2 SECTIONS BLDG
SECTIONS?? HOW ABOUT 4 & 6??

* WHAT DO METERS 436 & 134 ON THE 202. STATION PAD COVER (NOT AFRI)??
#7 & 8??

X DO METERS 242, 258, & 261 COVER THE
ENTIRE GROUP OF BLDGS BEHIND AND
INCL. BLDG 17??

X WHERE ARE BLDGS 54 & 55 POWERED FROM???

X DO METERS 246 & 265 COVER ALL BUILDINGS AT
END OF GROUNDS ROAD??

— GET USUALLY PERCO DEMAND FROM PERCO

NNMC

DATA TO COLLECT

* DEMAND PROFILE INFO (DAILY PROFILES)
FALL, SPRING, WINT., SUMM FOR BOTH STATIONS

* DEMAND PROFILES FOR SUB-METERS, IF AVAIL.

WE KNOW ONLY
* MONTHLY ELEC. USE FOR PAST YEAR AT ALL POINTS

* CURRENT ELEC. RATES

AVE * COPY OF 1 OR 2 CURRENT BILLS

* DISTRIBUTION LAYOUT SHOWING TRANSFORMERS AND
ASSOCIATED SERVICE AREAS

* BUILDINGS ASSOCIATED W/ SUBMETERING

* CURRENT GAS RATES? COVEN ALSO? OIL RATE?

* DEMAND PROFILE INFO ON STEAM & CHILLED WATER
(DAILY PROFILES) FOR SEASONS

WE FOR 86 → PRESENT
* MONTHLY STEAM & CHILL USE AT MAIN PLANT ~~AND~~
~~ANY POINTS~~

WE FOR 84 → PRESENT
* MONTHLY ~~OR DAILY~~ ~~GAS~~ OIL USAGE BY PLANT ~~OTHERS~~
" " " GAS " " " "

* STEAM & CHILL PIPING

* LOCATION OF PROPOSED STEAM & CHILL SUBMETERING

* LOCATION, HOOKUPS AND SIZE OF PROPOSED ADDITIONS
TO LOADS

* BUILDING AUDIT OF 18 BUILDING

* LOCATION OF METERABLE POINTS ON EACH OF 18 BLDGS.

NNMC

TO VERIFY :

- * CORRECT SQ. FOOTAGES
- * CORRECT SINGLE LINE ELEC. FEED
2 SUBSTATIONS
- * submeter to BLDG. 9 which includes 10 also??
- * UNITS ON STEAM & CHILL DATA
- * LOCATION ASSOCIATED w/ SUBMETERS PRINTOUT

NNMC Lighting/HVAC Notes - EER 9/13/90

Bldg. 3 & 5

Most hallway and office lights off at night except main common hall. Since each "wing" tends to be an autonomous office area the last out apparently takes care of all the lights in their area. Relatively high office plugs in most areas. HVAC is mixed with some main air handlers and many window air conditioners

<u>area</u>	<u>footcandles</u>	<u>comments</u>
office	25 - 46	fair daylight
hall	8 - 10	much daylight
stairwell	35+	much overlit (reflectors installed in fixtures)

Bldg. 5 (second floor)

Newly remodeled but yet unoccupied patient exam and office space.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
exam room/office	55 - 104	(without task lightson) Very overlit for routine exam and office functions. Light switches are set up to illuminate only 1/2 of lamps (55 fc).

Bldg. 2

Mall area in middle of 1-8 complex with food service, barber, post office, etc. Main cafeteria is closed on weekends.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
ice cream store	33	(2 more footcandles than flavors)

Bldg. 1-8 (in general)

Spaces include primarily office and clinic type operations that operate a standard 8 hour workday. Some areas operate on weekends (mall area, dental clinic). All closed offices and clinics appeared to have lights off during weekends. Hallway and open area lights are run 24 hours per day. Hallways and most open areas are well populated during working hours but are virtually vacant on "off" hours. HVAC is primarily 24 hour constant volume with main steam/chilled water air handlers for interior zones and fan coil units at windows. Building 2 areas have simple hot water convectors at windows. Controls are said to be in good condition and < 5 years old.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
library	7.7	poorly lit for reading
hall	13 - 20	mixed areas
library	30	small bldg. 1 library
hall	27	with daylight
hall	15	no daylight
office	50 - 90	

Watts per square foot were calculated in one area in the 1-8 complex and found to be 0.63 W/ft² for hall and 1.67 W/ft² for office. The 1-8 complex contains many varied office, hallway, and other spaces that make a representative watts per foot value impossible to measure.

Bldg. 9

Primarily an office, laboratory, and clinic area. Operation is primarily 8 hours on weekdays. Hall and atrium lights are on 24 hours per day. HVAC is 24 hour chilled water VAV with steam reheat at main air handlers and hot water reheat at individual rooms/areas. Timeclocking office areas off on nights has been tried but found to be impractical. Areas that were turned off required a very long lead time to recover prompting numerous complaints. Certain non-essential areas (mall, open waiting) have hvac timeclocked off on weekends. These are primarily smaller interior spaces.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
lab	86	

Patient/employee food service is a full scale operation operating most of every day. Posted employee food service hours are 0600 - 0800, 1100 - 1300, and 1700 - 1830.

Bldg. 10

Lower 2 floors are clinic and office operations with a large atrium space. Much daylighting is provided to this space but many overhead halide lights remain lit 24 hours per day. Upper five floors are primarily patient rooms and nurses stations. Floors 5 and 6 are mostly empty and some of the hall lights are down to night lights only. Night lights in hallways in most areas appear to be 1 of every four fixtures. Other floors and areas have 100 percent hall lights on. HVAC is 24 hour chilled water VAV with steam reheat at main air handlers and hot water reheat at individual rooms/areas.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
atrium	20 - 23	much daylight
hall	10 - 30	6 foot wide hall

Bldg. 12

This building includes 3 tenants on the ground floor (printing and office areas) in addition to the barracks type operation. Several windows and doors were found open during cooling. HVAC is mixed window units and fan coil units.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
hall (main)	6.5 - 15	older inefficient fixtures
office (exchange) (good clean fixtures)	70	with daylight

Bldg. 14

Lights are left on for cleaning crew (5 days a week) which stays until about 9 pm. (complete cleaning operations may not actually be needed every day - most could be done during regular working hours). One office has an occupancy sensor installed at the light switch. Unfortunately the office has two doors and the switch faces a hall. Consequently the room is lit up every time someone passes in the hall. HVAC consists of steam/chilled water VAV boxes with window convectors.

Bldg. 50

Lights are typical fluorescents in typical hotel type room setups. Exterior walkway lights are on 24 hours per day. HVAC is fan coil units with outside air intake for makeup air to exhaust fans.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
lobby	10 - 30	

Bldg. 54

Parking light controls are set up to run on a photocell with a timeclock override to eliminate cloudy condition operation. The Photocell appears to be defective as lights were on late in the morning and early in the evening. The timeclock appears to be permanently set to inter hours. Building includes office and warehousing activities. HVAC is VAV in conditioned areas.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
warehouse	26	HID
office	40 - 48	clean fixtures
storage racks	16	between rows with lights
storage racks	2 - 7	between rows w/o lights (racks were recently moved and lights are now incorrectly placed)
hall	2 - 10	
office	48 - 50	cubicles w/task lights

Bldg. 55

Parking light controls are set up to run on a photocell with a timeclock override to eliminate cloudy condition operation. The Photocell appears to be defective as lights were on late in the morning and early in the evening. The timeclock appears to be permanently set to winter hours. Building includes office and warehousing activities. Exterior lights are on most of day. HVAC is VAV in conditioned areas.

<u>area</u>	<u>footcandles</u>	<u>comments</u>
office	45 - 50	

NNMC Selected Building Lighting Summary - EER 9/13/90

<u>BUILDING</u>	<u>LIGHT SOURCE</u>	<u>HALLWAY KW</u>	<u>OFFICE/OTHER KW</u>
1-8	Hallide	0	14.5
1-8	Mercury	13.8	39.2
1-8	Fluorescent	78.4* ¹	417.4* ¹
1-8	Incandescent	0.8	27.9
	TOTAL	93.0	499.0
9,10	Mercury	1.4	14.2
9,10	Quartz	0	20.2
9,10	Halogen	0	163.3
9,10	Fluorescent	118.9	829.8
9,10	Incandescent	12.8	145.9
	TOTAL	133.1	1173.4
12	Fluorescent	4.2* ²	22.3* ²
	TOTAL	4.2	22.3
14	Fluorescent	NA* ³	32.5
	TOTAL	-	32.5
16	NA	NA	NA
50	Fluorescent	1.9* ²	9.9* ²
50	Exterior Fluor.	2.6	(on 24 hr/day) 0
50	Incandescent	0	6.0
	TOTAL	4.5	15.9
54	Fluorescent	NA* ³	44.4* ⁴
54	Incandescent	NA* ³	10.9
54	Quartz	NA* ³	6.0
54	HPS	NA* ³	59.5
54	Exterior HPS	NA* ³	2.0
	TOTAL	-	122.8
55	Fluorescent	NA* ³	11.4* ⁵
55	Quartz	NA* ³	4.0
55	HPS	NA* ³	5.6
55	Mercury	NA* ³	66.7
55	Incandescent	NA* ³	2.3
	TOTAL	-	90.0

*¹ Hallway lighting for buildings 1,2,4,6-8 was recorded separately and found to be approximately 15.7 percent of the total lighting. This value was used to calculate the hallway lighting in buildings 3 and 5 and added to the 1,2,4,6-8 numbers to get the total 1-8 lighting values shown.

*² The 15.7 percent value was used here to estimate hallway lights.

*³ Mostly open office, shop, or parking with no appreciable hallway areas.

*⁴ 2.9 kW of this is stairwell lighting that appears to be on 24 hours/day.

*⁵ 4.4 kW of this is stairwell lighting that appears to be on 24 hours/day.

Attachment 9: PEPCO Incentives and FEMP Model Program

ATTACHMENT 9: PEPCO INCENTIVES AND FEMP MODEL PROGRAM

This attachment contains descriptions of the incentive plans offered by PEPCO for commercial lighting, thermal energy storage, and curtailable load programs. Also enclosed is a description of the Federal Energy Management Program's Proposed Federal Agency Energy Efficiency Model Program.

COMMERCIAL LIGHTING REBATE PROGRAM

PEPCO grants rebates for upgrading lighting systems to more energy efficient systems. The available options for potential rebates are shown below:

<u>Equipment Installed</u>	<u>Rebate - Conditions</u>
Daylighting Controls	\$30 - per control installed
Occupancy Sensors	\$60 - per sensor installed
Efficient Fluorescent Ballasts	\$8-\$12 - depending on type installed
Optical Reflectors	\$20 - in combination with removal of lamps and ballasts
Exit Sign Conversions	\$10 - replace incandescent with fluorescent
Compact Fluorescent Lamps	\$6 - per incandescent replaced with compact fluorescent
Energy Efficient Fluorescent Lamps	\$1-\$2 - when replacing conventional fluorescent with high efficiency fluorescent lamps
Incandescent Fixture Replacements	\$300 per kW reduced - when replacing with high efficiency fluorescent lamp
High Intensity Discharge Fixtures	\$300 per kW reduced - when replacing incandescent, fluorescent, and less efficient HID mercury vapor lamps with metal halide and high pressure sodium
Custom Programs	\$300 per kW reduced - on many items not listed above that meet program guidelines.

For projects that include two or more improvements to each lighting fixture, PEPCO will give a 10% greater rebate for that fixture.

To qualify for these rebates, complete the Commercial Lighting Program Application from PEPCO. Also, complete the Rebate Worksheet for intended improvements. Once these are completed, return them to PEPCO. PEPCO will

review the application and conduct an inspection of the existing lighting conditions if they deem necessary. Once approved, energy efficient equipment may be purchased.

After installation of the equipment, inform PEPCO of completion. Complete a Request for Payment form and return it to PEPCO. The quantity and price of each item should be clearly noted. PEPCO, at their discretion, may conduct an inspection of the completed project. After all items are satisfactory, PEPCO will mail out a rebate check.

THERMAL ENERGY STORAGE REBATE PROGRAM

PEPCO offers an attractive rebate program for commercial customers located in their service area. Essentially, the Thermal Energy Storage (TES) rebate program has three main components. TES will save money for the customer by reducing capital costs, reducing utility bills, along with improving the overall comfort of the occupants involved. The main components of the TES rebate program are outlined below:

1. PEPCO will fund 50% of the feasibility study up to \$5,000 provided the analysis is performed by a professional engineer that is licensed in the appropriate jurisdiction (in this case, Washington, D.C., or Maryland). TES requirements for a feasibility study will be explained in more detail below.
2. Once the feasibility study determines that a TES system is both technically and economically feasible, PEPCO will grant approval to proceed with the envisioned system. PEPCO will pay \$250 per kilowatt of peak load deferred (defined as load from June - October between the hours of 12:00 noon to 8:00 p.m.) for the first 500 kilowatts. Additionally, \$200 per kilowatt of peak deferred load in excess of the first 500 kilowatts will be paid according to the terms of this rebate offer.
3. All applications and documentation will be reviewed by PEPCO for accuracy. After reviewing the information, PEPCO will send qualifying customers a Thermal Energy Storage Agreement stating the estimated rebate upon completion of the proposed project. If a customer is rejected for any reason, PEPCO will notify the party stating the reason for the rejection.
4. After the TES container has been installed, an arrangement will be made with PEPCO to inspect the system to determine the actual rebate amount. Half the rebate will be paid following the inspection of the system, with the balance being paid upon permanent hook-up of electricity for new facilities or system start-up for existing structures.
5. In the case of disputes regarding the program, customers may submit documentation to support their case, but the final decision regarding interpretations rests with PEPCO.
6. As directed by the public service commission in the jurisdictions served by PEPCO, this rebate program is subject to change at any time.
7. PEPCO does not warrant the design or installation of the chosen TES system.

As stated above, a more detailed description of the requirements for a TES feasibility study is needed at this point. First of all, an hourly simulation model must calculate a 24 hour chiller load profile showing the maximum peak. System sizing and peak kilowatt savings for the cooling plant, air handling systems, and the corresponding auxiliaries must also be analyzed.

Existing facilities should have the auxiliary equipment peak load (electric) based upon name-plate data. Additionally, all values should be converted to kilowatts using conversion factors provided by an energy management engineer at PEPCO.

Assumptions regarding operating conditions must be the same for the TES system and the base case scenario. Some examples would include humidity requirements, interior temperature, hours of equipment operation, etc. Also, the number of fan systems should be identical in the base case and TES simulations. Finally, the ratio of equipment capacity to load should be the same in both cases.

The appropriate PEPCO commercial time-of-use rate schedules will be incorporated in the life cycle cost analysis when it is performed.

If all of the above mentioned requirements are met for the TES feasibility study, a refund will be granted, regardless of whether or not the TES project proves to be feasible. Programs that would potentially qualify include eutectic salt, chilled water, and ice systems.

CURTAILABLE LOAD PROGRAM

PEPCO, has recently established a voluntary Load Curtailment Program. Since PEPCO must provide the generating capabilities for the largest (peak) demand required, curtailment during peak summer loads is advantageous to them to hold down this peak as much as possible. Through programs such as this, PEPCO is able to delay new construction of generation plants which in turn keep the customer's rates lower.

Participants in the program voluntarily reduce at least 100 kW of demand during peak weekdays (June - September or October, depending on customer jurisdiction) between the hours of 12:00 noon and 8:00 p.m. for no longer than 6 hours each time. Load reduction requests will be made 15 times or less during the curtailment season. The customer will receive a credit on their electric bill on a dollar per kW basis during the on-peak time. Payment will be made for the kW actually reduced, except for any kW that exceeds a mutually agreed upon level. The customer helps to determine this level by finding out potential kW reduction from the monthly on-peak demand and subtracting this value. The difference obtained is the Firm Service Level (FSL). If two or more curtailments are made in one month, the least amount of kW curtailed will be used in computing the credit for that month.

FEDERAL AGENCY ENERGY EFFICIENCY MODEL PROGRAM

In partnership with the
SERVICING UTILITY

Introduction

The Federal Energy Management Program of the U.S. Department of Energy [DOE-FEMP], through its lead laboratory, Pacific Northwest Laboratory [PNL], is supporting the design and implementation of a model program for federal customers in partnership with their servicing utility. This approach comprises identification and characterization of all cost-effective energy efficiency measures (or assets) on federal installations and subsequent "sale" of those efficiency assets to the servicing utility(s). The primary objectives of the model program are to:

- identify all electric and nonelectric life cycle cost-effective energy efficiency *projects* at one or more federal installations served by a common utility
- negotiate with the servicing utility to purchase the energy efficiency from its federal customers
- develop a schedule for each federal customer for project acquisition considering project *type, size, timing, capital requirements, and energy and dollar savings*
- design and implement a model DSM approach which the utility could propose to its regulatory agency for application to all its federal customers.

Background

Projects in this model program are any actions which support the installation's mission and result in a reduction in energy costs and/or energy demand and usage. Examples of projects include energy end-use technology retrofits, onsite generation, cogeneration, O&M, innovative scheduling and operations, fuel switching, and rate structure analysis and renegotiation.

A facility-wide, fuel-neutral approach to identifying and acquiring energy projects yields the greatest savings and greatest return on taxpayer investments. FEMP and PNL have developed and successfully applied this approach. Experience at over 25 federal installations indicates that the typical federal installation could invest from one to two times the installation's annual energy bill in cost-effective projects. Benefits are significantly increased when combined with creatively designed utility programs.

The FEMP Model Program Approach

Major constraints faced by federal installations in identifying and acquiring life cycle cost-effective energy projects are: 1) installations have poor access to capital for modernization; 2) are required to follow procurement procedures that can take a year or more to implement; and 3) are not organized around a systematic approach to managing all aspects of their energy portfolio. The model program will address each of these constraints. PNL provides direct support to the installations to:

1. Understand and characterize all requirements for energy services. Energy services are those benefits provided by energy systems such as lighting, space heating, refrigeration, and process heat.
2. Understand and characterize the life cycle cost-effective energy efficiency opportunities. These opportunities are assets that can be sold to utilities in need of additional energy capacity, to the federal government as a means to reduce annual energy expenditures, and potentially to private sector companies who will invest capital in return for a share of the energy cost savings.

3. Understand and characterize all potential sources of implementation funding for energy system modernization projects.
4. Understand, characterize and prioritize alternative energy projects.
5. Implement the selected projects.

The most promising approach for federal energy systems modernization is direct negotiation with the installation's electrical utility under a customized DSM program. The basic elements necessary for a DSM program to be successful in the federal sector are:

- The utility should target all cost-effective energy system modernization opportunities on the installation. Participation in the utility DSM program has a high transaction cost for the federal installation, and a relatively low transaction cost for the utility considering the size of large one-owner federal installations.
- The utility needs to *up-front finance 100%* of the site modernization activities.
- The utility needs to *fund a significant portion* (at least 50%) of the total installed cost of new technologies. The utility can afford to spend up to its long-run avoided cost to acquire energy efficiency.
- The utility needs to be able to *contract for the energy service company* for project implementation. Federal procurement rules make it difficult and time consuming for installations to hire their own contractors. An installation can however sole-source with its electric utility.

Experience

Innovative utilities currently working with FEMP and PNL to design and implement this prototype program for their federal customers include Tacoma Public Utilities, Niagara Mohawk Power Company, Georgia Power Company, Pacific Gas and Electric, and Florida Power and Light.

The program being undertaken with Tacoma Public Utilities and Fort Lewis is the most mature. The first two activities above produced energy conservation supply curves for the Fort showing the amount of electric and non-electric energy savings that can be achieved at different prices for energy saved and from fuel switching. From these data, a proposal was prepared for approximately 43,000 kWh (~4 MW) of annual cost-effective electric energy savings which TPU presented to the Bonneville Power Administration (the regional power marketing agency who supplies power to TPU). This proposal identifies investment requirements at the Fort and the likely energy and dollar savings which will result from the investment. Approximately \$10 million of investment in energy efficient end-use technology is cost-effective at Fort Lewis under this arrangement.

In the agreement with Fort Lewis, TPU will finance 100% of this investment and will procure the energy services contractor who will conduct the detailed audits and install the technologies. The Fort will sign off on all proposed retrofits and on the acceptance of the installed technology. The Fort will repay TPU 15% of the total installed cost of the technology through a separate sole-source contract with TPU, and make annual payments of 15% of the installed cost for each year the program is being implemented.

The result is that the Fort would see a significant, and immediate, reduction in its annual electric bill of between \$500 thousand and \$1 million depending on the final program design. Expectations are that agreements can be reached and an implementation plan prepared by the second quarter of FY 1992 and technologies will be installed starting the fourth quarter of FY 1992.

DISTRIBUTION

No. of
Copies

No. of
Copies

OFFSITE

12 DOE/Office of Scientific and
Technical Information

K. Dean DeVine
Federal Energy Management
Program
U.S. Department of Energy
1000 Independence Avenue SW
CE-10.1
6A-034/FORS
Washington, DC 20585

T. Collins
Federal Energy Management
Program
U.S. Department of Energy
1000 Independence Avenue SW
CE-10.1
46A-034/FORS
Washington, DC 20585

2 C. Chiu
Naval Civil Engineering
Command
Chesapeake Division
Washington Navy Yard
Building 212 Code 112
Washington, DC 20374-2121

R. Mazzucchi
SBW Incorporated
2820 Northrup Way
Suite 230
Bellevue, WA 98004

2 P. Whittington
National Naval Medical Center
Facilities Management Division
Bethesda, MD 20814-5000

ONSITE

DOE Richland Field Office

D. L. Segna

22 Pacific Northwest Laboratory

R. Bartlett
J. W. Currie
M. A. Halverson
B. L. Mohler
G. B. Parker (5)
D. R. Payson
W. F. Sandusky
R. W. Reilly
J. L. Stoops
R. F. Szydlowski
Project File (2)
Publishing Coordination
Technical Report Files (5)

END

**DATE
FILMED**

5 / 21 / 92

